

MCCURTAIN COUNTY AP, OK, USA

WMO: 723759

Lat: 33.909N

Lon: 94.859W

Elev: 472

StdP: 14.45

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 53990

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.0	26.5	8.6	8.7	30.5	11.9	10.3	32.6	23.2	54.0	20.5	52.4	4.9	340	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.5	99.1	74.8	96.9	74.7	94.6	74.2	78.5	88.9	77.2	90.0	76.3	88.8	6.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.6	141.4	82.5	73.2	125.5	81.9	72.5	122.4	81.2	42.4	91.8	40.9	89.0	39.9	89.3	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.4	17.0	15.2	14.5	103.7	4.5	4.7	11.2	107.1	8.5	109.8	6.0	112.4	2.7	115.8	
			13.3	80.0	4.3	3.2	10.3	82.2	7.8	84.1	5.4	85.9	2.3	88.1	
			DB												
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.0	42.6	46.6	55.4	61.7	70.0	78.7	81.4	81.8	75.3	63.6	53.2	45.2	(6)
	DBStd	15.77	9.20	9.82	9.27	7.46	6.51	4.03	4.14	4.43	5.91	8.45	8.82	8.84	(7)
	HDD50	768	265	168	52	8	0	0	0	0	0	5	64	206	(8)
	HDD65	2824	697	518	317	145	30	0	0	0	4	130	366	617	(9)
	CDD50	5527	34	72	219	359	621	860	974	987	760	426	159	56	(10)
	CDD65	2108	1	2	19	46	186	410	509	522	313	87	11	2	(11)
	CDH74	21648	5	13	149	414	1580	4169	5616	5850	2949	812	84	7	(12)
	CDH80	10143	0	1	15	48	478	1914	2944	3154	1341	237	11	0	(13)
(14) Wind	WSAvg	6.4	6.9	7.6	8.0	7.9	6.6	5.7	5.1	4.9	5.1	5.8	6.5	6.6	(14)
(15) Precipitation	PrecAvg	54.7	3.9	3.8	5.2	4.6	5.8	4.2	3.5	2.8	4.4	5.4	4.6	4.8	(15)
	PrecMax	75.7	8.1	8.9	10.0	10.8	14.4	9.8	9.3	7.2	10.3	15.2	15.7	8.5	(16)
	PrecMin	36.9	0.4	0.8	2.2	1.9	2.5	1.1	0.1	0.3	1.2	0.1	1.4	0.3	(17)
	PrecStd	9.6	2.0	2.2	2.4	2.5	3.0	2.3	2.8	1.9	2.2	3.8	3.4	2.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.9	75.5	82.1	84.2	90.4	97.5	101.8	101.6	99.6	89.8	81.5	73.2	(19)
		MCWB	59.8	61.3	67.4	67.0	71.3	73.7	74.1	75.3	72.7	67.3	68.4	62.4	(20)
	2%	DB	68.2	71.9	78.8	81.3	88.1	94.8	98.8	99.3	94.7	86.1	76.7	69.9	(21)
		MCWB	58.6	59.4	63.3	64.9	71.4	74.5	74.0	75.7	71.8	69.6	64.3	60.8	(22)
	5%	DB	63.4	68.0	73.4	79.1	85.8	91.2	95.5	97.2	90.7	81.9	72.2	64.2	(23)
		MCWB	54.6	58.7	60.9	64.3	70.7	74.2	74.6	75.8	71.4	66.4	62.9	57.1	(24)
	10%	DB	59.2	63.5	71.6	76.7	82.0	90.1	92.8	94.8	88.3	78.9	68.3	61.1	(25)
		MCWB	50.1	55.7	60.9	63.5	69.3	73.9	74.4	74.9	71.4	65.0	60.3	54.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.1	66.2	72.0	71.2	75.4	78.1	78.5	85.3	76.5	74.0	72.8	66.1	(27)
		MCDB	70.0	72.5	76.8	78.9	84.9	90.4	91.2	96.1	87.9	83.3	76.1	71.9	(28)
	2%	WB	61.1	63.5	66.2	69.1	73.8	77.0	77.4	81.9	75.1	72.2	68.2	63.0	(29)
		MCDB	65.9	67.5	74.4	77.6	83.4	89.6	90.8	90.7	86.7	81.2	74.2	66.9	(30)
	5%	WB	56.6	60.5	64.1	67.5	72.4	76.0	76.5	78.1	74.0	70.6	64.6	59.5	(31)
		MCDB	61.9	65.1	71.4	76.0	81.8	87.8	89.9	88.9	85.6	77.7	69.4	63.8	(32)
	10%	WB	51.6	57.2	62.0	66.0	71.3	75.0	75.6	76.7	72.9	68.7	61.8	54.8	(33)
		MCDB	57.3	63.1	68.9	73.2	80.2	86.1	88.8	89.3	83.9	74.7	67.1	59.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.9	20.3	22.2	22.3	20.6	20.6	21.8	22.5	22.4	23.7	22.8	19.7	(35)
		MCDBR	28.3	26.4	25.1	25.1	23.2	22.9	25.2	26.3	26.4	26.2	25.6	25.9	(36)
		MCWBR	18.7	17.0	14.0	12.3	9.5	7.4	6.8	7.7	8.3	11.3	15.3	17.9	(37)
	5% WB	MCDBR	23.5	21.0	20.8	19.1	19.3	20.2	21.8	23.1	21.0	20.3	20.6	22.2	(38)
		MCWBR	18.8	16.3	13.6	11.4	9.3	7.6	7.3	8.8	7.7	10.2	15.5	17.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.319	0.328	0.357	0.392	0.427	0.442	0.460	0.457	0.401	0.357	0.335	0.317	(40)
	taud		2.493	2.476	2.420	2.320	2.288	2.281	2.263	2.261	2.376	2.479	2.495	2.510	(41)
	Ebn at Noon		284	292	291	284	274	268	263	262	273	279	275	278	(42)
	Edh at Noon		27	30	35	41	42	43	43	43	36	30	27	25	(43)
(44) All-Sky Solar Radiation	RadAvg		836	958	1327	1636	1794	2008	2010	1870	1574	1230	890	727	(44)
	RadStd		78	145	102	109	167	207	130	140	143	174	111	95	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (31 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page