

EDWARDS AFB, CA, USA

WMO: 723810

Lat: 34.900N

Lon: 117.867W

Elev: 2311

StdP: 13.51

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23114

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.7	25.3	-6.1	4.3	39.7	-1.3	5.6	42.8	30.6	51.0	27.4	51.6	3.1	0	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.0	105.0	64.6	102.3	63.7	100.0	63.0	68.9	92.8	67.5	93.5	66.0	93.2	12.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.6	89.2	76.5	57.6	77.2	78.3	54.7	69.2	77.4	34.3	92.1	33.0	93.7	31.8	92.8	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.2	25.7	23.5	14.8	109.6	4.4	2.0	11.6	111.1	9.1	112.2	6.6	113.4	3.4	114.8
			12.5	71.9	4.3	1.8	9.4	73.2	6.9	74.3	4.4	75.3	1.3	76.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.1	45.6	48.6	54.9	60.3	67.6	77.6	83.9	83.0	75.3	62.9	52.1	43.8
	DBStd	15.21	5.73	6.13	6.31	7.46	7.47	7.09	4.49	4.31	6.24	6.44	6.61	6.27
	HDD50	551	158	91	27	9	0	0	0	0	0	2	54	210
	HDD65	2787	602	460	317	177	61	6	0	0	7	114	387	656
	CDD50	5318	21	52	178	317	547	829	1051	1022	760	404	118	19
	CDD65	2076	0	0	3	35	142	385	586	557	317	50	1	0
	CDH74	30067	1	17	211	741	2086	5453	8260	7755	4298	1130	114	1
	CDH80	17657	0	2	36	252	983	3310	5267	4940	2429	428	10	0
(14) Wind	WSAvg	10.0	7.0	9.1	10.4	12.7	13.5	13.1	11.7	10.7	9.0	8.2	7.1	7.1
(15) Precipitation	PrecAvg	5.7	1.1	1.4	0.6	0.3	0.1	0.0	0.2	0.1	0.2	0.3	0.3	0.8
	PrecMax	13.0	5.9	6.0	2.3	1.0	0.9	0.5	0.9	0.4	1.3	2.0	1.1	3.6
	PrecMin	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.4	1.5	1.5	0.6	0.3	0.2	0.1	0.2	0.2	0.4	0.5	0.3	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.3	76.4	84.2	90.9	98.8	107.1	108.9	107.8	101.5	93.2	81.4	70.8
		MCWB	50.7	51.6	54.5	57.7	61.6	64.8	65.6	65.8	64.2	58.9	54.0	51.3
	2%	DB	66.1	72.3	79.6	86.5	93.8	102.7	105.4	104.2	98.8	89.1	77.4	64.9
		MCWB	47.9	50.3	53.0	55.7	59.2	62.4	64.9	64.6	63.3	58.0	52.0	48.1
	5%	DB	63.0	68.0	75.5	82.4	90.1	99.6	102.5	101.8	96.3	85.1	73.1	61.1
		MCWB	46.9	49.1	51.7	54.3	58.3	61.5	64.1	63.7	62.3	56.1	51.0	46.6
	10%	DB	59.1	63.3	71.6	78.1	85.9	96.2	99.9	99.4	93.2	81.1	68.1	57.1
		MCWB	46.0	47.3	50.8	53.1	57.2	60.7	63.5	62.9	61.0	54.9	49.0	45.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.7	55.4	57.1	60.2	63.8	67.8	71.4	70.4	69.3	64.0	57.3	55.5
		MCDB	62.5	66.5	73.4	84.1	93.5	100.2	91.0	93.6	90.7	80.7	68.4	61.6
	2%	WB	52.6	52.9	55.1	57.9	61.2	65.2	69.3	68.6	67.5	60.9	54.5	52.5
		MCDB	59.6	64.4	72.8	80.3	88.4	95.6	92.0	94.1	87.7	79.4	71.2	60.1
	5%	WB	50.3	50.9	53.5	56.1	59.6	63.5	67.7	66.9	65.7	58.7	52.6	50.1
		MCDB	57.1	63.4	71.3	77.6	85.9	93.8	94.2	95.1	87.2	79.2	68.3	57.1
	10%	WB	48.2	49.2	51.9	54.4	58.1	62.1	66.1	65.2	63.8	56.7	50.8	47.6
		MCDB	55.6	60.7	68.0	74.7	82.6	91.3	94.0	94.7	86.2	75.9	65.2	54.7
(35) Mean Daily Temperature Range	5% DB	MDBR	26.9	26.3	28.6	28.6	29.0	32.2	32.0	33.2	32.7	32.6	31.1	26.6
		MCDBR	33.8	35.3	36.8	36.3	35.1	36.0	34.7	35.3	35.6	39.0	37.9	32.4
	5% WB	MCWBR	19.2	17.6	16.2	14.7	12.6	11.5	11.0	12.1	13.4	17.4	20.2	18.9
		MCWBR	23.3	27.7	31.2	31.9	32.9	33.8	29.0	30.6	29.2	31.4	31.7	23.5
(40) Clear-Sky Solar Irradiance	taub		0.273	0.283	0.298	0.320	0.335	0.330	0.353	0.340	0.325	0.302	0.277	0.276
		taud	2.548	2.538	2.485	2.424	2.405	2.432	2.414	2.429	2.464	2.515	2.560	2.556
	Ebn at Noon		301	309	311	306	301	300	293	296	297	297	296	293
		Edh at Noon	25	28	32	36	37	36	37	36	33	29	24	23
(44) All-Sky Solar Radiation	RadAvg		986	1284	1750	2166	2445	2661	2502	2348	2003	1512	1125	898
	RadStd		74	128	88	89	106	105	107	65	49	80	46	65

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-5.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)	+1.10	N/A	-3.35	+1.15	N/A	N/A	N/A	-202	+392	+189

Nomenclature: See separate page