

MEADOWS FIELD, CA, USA

WMO: 723840

Lat: 35.434N

Lon: 119.054W

Elev: 489

StdP: 14.44

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23155

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	33.3	36.0	17.7	13.6	59.7	22.5	17.2	55.6	24.6	60.4	19.7	58.2	2.6	130	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.7	103.2	69.8	100.9	69.0	98.6	68.0	73.4	96.8	71.6	95.4	70.1	93.7	11.3	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.9	93.7	87.5	62.3	85.4	85.2	60.3	79.5	83.8	37.1	97.1	35.6	96.0	34.2	93.6	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	15.5	12.9	DB	29.2	108.2	3.3	1.8	26.8	109.5	24.8	110.5	23.0	111.5	20.5	112.9	
			WB	27.4	75.4	3.2	3.9	25.1	78.2	23.3	80.4	21.5	82.6	19.2	85.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.2	49.8	53.5	58.7	63.2	70.8	78.7	84.9	83.4	78.0	67.3	56.4	49.2
	DBStd	13.88	5.53	5.27	6.15	7.35	7.34	7.18	5.32	5.03	6.44	6.30	6.05	5.68
	HDD50	199	72	22	5	1	0	0	0	0	0	0	15	84
	HDD65	1957	472	323	211	120	27	3	0	0	1	48	264	488
	CDD50	6122	65	119	275	397	644	860	1081	1037	841	537	206	60
	CDD65	2406	0	0	16	66	206	413	616	572	392	120	5	0
	CDH74	31099	3	22	245	817	2448	5420	8649	7596	4616	1201	81	1
	CDH80	17111	0	1	53	302	1122	3038	5262	4467	2427	427	12	0
(14) Wind	WSAvg	5.8	4.6	5.2	5.7	6.8	7.1	7.2	6.9	6.3	5.8	5.1	4.3	4.5
(15) Precipitation	PrecAvg	6.1	1.0	1.2	1.1	0.6	0.2	0.1	0.0	0.1	0.1	0.3	0.7	0.7
	PrecMax	13.3	3.9	5.4	4.3	2.6	2.4	0.5	0.3	1.2	1.1	1.8	3.0	1.8
	PrecMin	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.2	0.8	1.2	0.9	0.6	0.4	0.2	0.0	0.2	0.3	0.4	0.7	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.0	77.3	85.7	92.8	99.4	105.2	106.7	106.0	102.0	94.1	81.2	70.4
		MCWB	52.9	57.1	61.2	62.3	67.2	69.9	70.4	71.4	69.0	65.4	59.6	54.5
	2%	DB	66.7	72.0	80.2	87.9	94.6	101.3	103.4	102.4	98.6	88.8	75.9	66.0
		MCWB	53.7	55.8	59.8	61.0	65.5	69.1	69.9	69.1	67.1	63.1	57.8	52.7
	5%	DB	63.1	67.7	76.0	83.2	90.6	98.0	101.2	99.7	95.9	84.7	71.8	62.5
		MCWB	53.0	54.3	57.7	59.8	63.3	67.3	69.5	68.1	66.6	61.7	56.5	51.8
	10%	DB	59.8	64.1	71.9	78.3	86.5	94.4	98.5	97.0	92.6	80.9	67.8	59.4
		MCWB	51.6	53.1	56.5	58.3	62.2	65.8	68.7	67.5	65.8	60.4	55.3	51.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.2	60.7	64.7	66.0	70.9	73.9	76.4	75.3	74.3	68.3	62.5	58.9
		MCDB	65.9	70.3	80.3	82.7	95.6	100.8	96.9	97.9	93.1	87.2	74.1	65.4
	2%	WB	56.2	58.1	61.9	63.2	67.8	71.1	73.5	72.4	71.1	66.0	60.1	56.2
		MCDB	62.0	67.7	76.3	82.7	91.0	96.8	97.5	96.8	90.3	84.2	72.3	61.6
	5%	WB	54.4	56.2	59.5	61.0	65.3	69.1	71.8	70.5	68.7	63.8	58.2	54.1
		MCDB	60.3	65.0	72.5	80.2	86.7	93.6	95.6	94.7	90.0	81.2	69.3	59.8
	10%	WB	52.5	54.3	57.5	59.2	63.2	67.4	70.2	68.9	66.9	61.8	56.3	52.0
		MCDB	58.3	62.1	69.2	76.0	83.6	91.3	94.2	92.7	89.6	78.1	65.8	57.8
(35) Mean Daily Temperature Range	5% DB	MDBR	17.3	19.6	22.4	23.9	24.6	26.1	25.7	25.8	25.1	23.5	20.2	17.9
		MCDBR	22.8	25.3	28.8	30.1	28.4	28.0	25.8	27.0	27.4	28.5	26.1	22.0
		MCWBR	12.8	12.9	12.9	12.3	11.2	10.7	9.7	10.1	10.4	12.6	13.3	12.2
	5% WB	MCDBR	18.0	22.1	26.1	28.1	27.3	27.1	24.9	26.1	25.7	25.1	22.7	17.1
		MCWBR	11.3	12.1	12.9	12.1	11.4	11.2	10.8	10.9	10.2	11.3	12.2	10.5
(40) Clear-Sky Solar Irradiance	taub		0.326	0.338	0.343	0.372	0.379	0.369	0.400	0.376	0.372	0.370	0.342	0.328
	taud		2.443	2.415	2.407	2.329	2.336	2.364	2.316	2.351	2.373	2.344	2.401	2.447
	Ebn at Noon		277	286	294	289	287	288	279	284	280	270	267	268
	Edh at Noon		28	32	35	40	40	39	41	38	36	34	29	26
(44) All-Sky Solar Radiation	RadAvg		863	1188	1656	2091	2435	2690	2549	2371	2000	1470	1045	799
(45)	RadStd		85	129	118	118	120	87	92	61	48	76	49	79

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47) Regional (40 neighbors)	+1.42	N/A	-3.55	N/A	-1.58	-1.76	-65	-306	+490	+268
	+1.10	N/A	-2.66	+1.17	N/A	N/A	N/A	-232	+392	+160

Nomenclature: See separate page