

MEADOWS FIELD, CA, USA

WMO: 723840

Lat: 35.434N

Lon: 119.054W

Elev: 149

StdP: 99.55

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23155

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	0.7	2.2	-8.0	1.9	15.4	-5.3	2.5	13.1	11.0	15.8	8.8	14.6	1.2	130	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	39.6	21.0	38.3	20.5	37.0	20.0	23.0	36.0	22.0	35.2	21.1	34.3	5.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	13.4	30.8	16.8	12.2	29.6	15.7	11.4	28.8	68.5	36.2	64.8	35.6	61.7	34.2	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	6.9	5.7	DB	-1.6	42.3	1.8	1.0	-2.9	43.1	-4.0	43.6	-5.0	44.2	-6.4	44.9	(4)
(5)			WB	-2.6	24.1	1.8	2.2	-3.8	25.6	-4.8	26.9	-5.8	28.1	-7.1	29.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	9.9	11.9	14.8	17.3	21.5	25.9	29.4	28.6	25.6	19.6	13.5	9.6		
	DBStd	7.71	3.07	2.93	3.42	4.08	4.08	3.99	2.95	2.80	3.58	3.50	3.36	3.16		
	HDD10.0	111	40	12	3	1	0	0	0	0	0	0	8	47		
	HDD18.3	1087	262	179	117	67	15	2	0	0	1	27	147	271		
	CDD10.0	3401	36	66	153	221	358	478	601	576	467	298	114	33		
	CDD18.3	1337	0	0	9	37	114	229	342	318	218	67	3	0		
	CDH23.3	17277	2	12	136	454	1360	3011	4805	4220	2564	667	45	1		
	CDH26.7	9506	0	1	29	168	623	1688	2923	2482	1348	237	7	0		
(14) Wind	WSAvg	2.6	2.0	2.3	2.5	3.0	3.2	3.2	3.1	2.8	2.6	2.3	1.9	2.0		
(15) Precipitation	PrecAvg	156	26	31	28	14	5	2	0	2	3	7	18	17		
	PrecMax	338	99	136	110	67	61	12	8	30	27	46	77	46		
	PrecMin	50	0	1	0	0	0	0	0	0	0	0	0	0		
	PrecStd	55	21	31	23	14	11	4	1	6	7	10	17	13		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	25.2	29.9	33.8	37.4	40.6	41.5	41.1	38.9	34.5	27.3	21.3		
		MCWB	11.6	14.0	16.2	16.9	19.6	21.0	21.3	21.9	20.6	18.6	15.3	12.5		
	2%	DB	19.3	22.2	26.8	31.0	34.8	38.5	39.6	39.1	37.0	31.5	24.4	18.9		
		MCWB	12.0	13.2	15.4	16.1	18.6	20.6	21.0	20.6	19.5	17.3	14.3	11.5		
	5%	DB	17.3	19.8	24.5	28.5	32.6	36.7	38.4	37.6	35.5	29.3	22.1	16.9		
		MCWB	11.6	12.4	14.3	15.5	17.4	19.6	20.8	20.1	19.2	16.5	13.6	11.0		
	10%	DB	15.5	17.8	22.2	25.7	30.3	34.7	36.9	36.1	33.7	27.1	19.9	15.2		
		MCWB	10.9	11.7	13.6	14.6	16.8	18.8	20.4	19.7	18.8	15.8	13.0	10.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.1	16.0	18.2	18.9	21.6	23.3	24.7	24.0	23.5	20.2	17.0	15.0		
		MCDB	18.8	21.3	26.8	28.2	35.4	38.2	36.1	36.6	33.9	30.7	23.4	18.6		
	2%	WB	13.4	14.5	16.6	17.3	19.9	21.7	23.1	22.5	21.7	18.9	15.6	13.5		
		MCDB	16.6	19.8	24.6	28.2	32.8	36.0	36.4	36.0	32.4	29.0	22.4	16.5		
	5%	WB	12.4	13.5	15.3	16.1	18.5	20.6	22.1	21.4	20.4	17.7	14.6	12.3		
		MCDB	15.7	18.4	22.5	26.8	30.4	34.2	35.4	34.8	32.2	27.3	20.7	15.5		
	10%	WB	11.4	12.4	14.2	15.1	17.3	19.7	21.2	20.5	19.4	16.5	13.5	11.1		
		MCDB	14.6	16.7	20.7	24.4	28.7	32.9	34.6	33.7	32.0	25.6	18.8	14.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	10.9	12.5	13.3	13.7	14.5	14.3	14.4	13.9	13.0	11.2	9.9		
		MCDBR	12.6	14.1	16.0	16.7	15.8	15.5	14.3	15.0	15.2	15.8	14.5	12.2		
	5% WB	MCWBR	7.1	7.2	7.2	6.8	6.2	6.0	5.4	5.6	5.8	7.0	7.4	6.8		
		MCWBR	10.0	12.3	14.5	15.6	15.2	15.1	13.8	14.5	14.3	14.0	12.6	9.5		
(40) Clear-Sky Solar Irradiance	taub		0.326	0.338	0.343	0.372	0.379	0.369	0.400	0.376	0.372	0.370	0.342	0.328		
	taud		2.443	2.415	2.407	2.329	2.336	2.364	2.316	2.351	2.373	2.344	2.401	2.447		
	Ebn at Noon		872	902	928	911	905	909	879	896	884	851	842	844		
	Edh at Noon		88	101	110	126	127	123	128	121	113	107	90	83		
(44) All-Sky Solar Radiation	RadAvg		2.72	3.74	5.22	6.59	7.67	8.48	8.04	7.48	6.31	4.63	3.29	2.52		
	RadStd		0.27	0.41	0.37	0.37	0.38	0.27	0.29	0.19	0.15	0.24	0.15	0.25		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.79	N/A	-1.97	N/A	-0.88	-0.98	-36	-170	+272	+149
(47) Regional (40 neighbors)		+0.61	N/A	-1.48	+0.65	N/A	N/A	N/A	-129	+218	+89

Nomenclature: See separate page