

DESERT ROCK, NV, USA

WMO: 723870

Lat: 36.621N

Lon: 116.028W

Elev: 3230

StdP: 13.06

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 03160

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	27.7	30.3	-4.3	4.9	43.4	-0.5	6.0	45.0	28.8	53.1	25.4	52.0	5.6	30	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.3	103.9	64.6	101.5	63.8	99.4	63.0	68.4	91.9	67.2	91.3	66.0	91.1	12.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.2	94.5	75.5	58.7	83.3	79.2	55.2	73.2	81.7	34.4	91.0	33.3	91.0	32.2	90.8	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.5	23.2	20.2	DB	21.9	108.2	3.2	2.6	19.6	110.1	17.7	111.7	15.9	113.1	13.5	115.1	(4)
(5)			WB	17.5	71.0	2.6	3.1	15.6	73.2	14.1	75.0	12.6	76.7	10.7	78.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.4	46.2	48.4	55.3	60.8	69.9	80.6	86.7	84.9	77.1	64.5	52.8	44.5	(6)	
	DBStd	16.11	6.23	6.64	7.10	7.75	8.00	7.01	4.49	4.26	5.96	7.14	7.37	5.90	(7)	
	HDD50	537	149	101	32	10	0	0	0	0	0	4	54	187	(8)	
	HDD65	2678	584	464	308	169	45	4	0	0	3	96	369	636	(9)	
	CDD50	5790	30	57	195	332	618	918	1139	1083	813	452	137	16	(10)	
	CDD65	2457	0	0	6	42	198	472	674	618	366	79	2	0	(11)	
	CDH74	36284	0	2	113	570	2621	7130	10755	9377	4723	949	44	0	(12)	
	CDH80	20872	0	0	12	146	1153	4210	6900	5751	2425	274	1	0	(13)	
(14) Wind	WSAvg	8.6	7.8	8.4	9.1	10.1	9.8	9.9	8.9	8.6	8.2	7.8	7.5	7.6	(14)	
(15) Precipitation	PrecAvg	5.0	0.6	0.9	0.6	0.3	0.2	0.2	0.4	0.3	0.4	0.4	0.3	0.6	(15)	
	PrecMax	10.6	3.4	4.6	2.0	1.5	0.5	1.3	1.7	1.1	2.4	2.4	1.0	4.4	(16)	
	PrecMin	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	2.1	0.8	1.1	0.6	0.4	0.2	0.3	0.4	0.4	0.6	0.6	0.3	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.2	73.1	81.6	89.0	98.5	105.5	107.6	106.1	99.3	90.4	78.5	66.6	(19)	
		MCWB	47.2	49.1	52.2	56.9	62.9	63.9	66.4	65.6	63.5	59.4	52.0	46.2	(20)	
	2%	DB	64.2	69.3	77.2	84.1	93.6	101.5	104.9	102.3	96.5	86.3	74.6	62.8	(21)	
		MCWB	45.4	47.4	51.0	54.3	59.2	62.7	65.3	64.3	61.9	57.3	50.2	45.1	(22)	
	5%	DB	61.4	65.5	73.5	80.5	90.3	99.0	102.3	100.1	94.2	83.0	70.7	59.3	(23)	
		MCWB	44.1	46.0	49.6	52.7	57.4	61.6	64.3	63.6	61.1	55.0	49.0	43.6	(24)	
	10%	DB	57.8	61.6	70.3	76.8	86.8	96.6	100.0	98.0	91.7	79.6	66.5	56.0	(25)	
		MCWB	42.9	44.1	47.9	50.9	55.9	60.3	63.6	62.4	59.8	53.3	47.1	42.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.8	52.2	54.5	57.8	64.2	67.0	71.0	69.6	67.7	61.4	54.7	50.5	(27)	
		MCDB	60.7	66.0	74.5	86.6	97.0	102.4	96.9	89.5	86.8	82.7	71.1	60.0	(28)	
	2%	WB	48.4	49.5	52.3	55.2	60.5	64.5	68.8	68.2	65.7	59.4	52.1	48.4	(29)	
		MCDB	57.9	63.2	73.0	81.6	89.8	98.5	93.2	90.0	87.4	80.4	69.9	57.7	(30)	
	5%	WB	46.7	47.6	50.6	53.3	58.4	62.8	67.6	66.8	64.1	57.1	50.3	46.0	(31)	
		MCDB	56.8	61.4	71.0	77.4	87.4	96.0	92.1	90.3	86.2	77.3	67.9	55.2	(32)	
	10%	WB	44.7	45.7	49.0	51.5	56.6	61.2	66.4	65.6	62.4	55.1	48.4	43.7	(33)	
		MCDB	55.6	58.7	67.8	74.2	84.9	93.7	91.4	90.6	85.4	75.5	64.8	53.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	19.4	19.9	22.4	23.0	24.1	25.1	24.3	24.3	24.5	23.5	21.4	18.8	(35)	
		MCDBR	24.0	25.4	27.2	27.8	28.0	28.4	27.4	27.5	27.5	27.9	25.8	23.8	(36)	
	5% WB	MCWBR	12.7	12.1	12.4	12.8	12.6	12.9	11.4	11.0	11.7	13.1	12.6	13.0	(37)	
		MCWBR	19.6	21.9	25.6	26.5	28.4	28.0	23.4	23.8	24.0	25.2	23.7	19.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.257	0.265	0.274	0.301	0.318	0.315	0.344	0.337	0.306	0.284	0.261	0.259	(40)	
		taud	2.623	2.607	2.573	2.477	2.453	2.477	2.458	2.461	2.541	2.593	2.624	2.623	(41)	
	Ebn at Noon		305	314	318	311	305	305	295	296	302	302	301	298	(42)	
		Edh at Noon	23	26	29	34	36	35	35	34	30	26	22	21	(43)	
(44) All-Sky Solar Radiation	RadAvg		951	1256	1739	2184	2469	2706	2429	2260	1967	1462	1079	843	(44)	
	RadStd		78	117	78	92	131	117	117	107	74	88	44	62	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.24	+1.44	N/A	N/A	-0.97	N/A	N/A	-229	+263	N/A
(47) Regional (12 neighbors)		+1.03	N/A	-2.41	N/A	N/A	N/A	N/A	-182	+293	+137

Nomenclature: See separate page