

DESERT ROCK, NV, USA

WMO: 723870

Lat: 36.621N

Lon: 116.028W

Elev: 985

StdP: 90.04

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 03160

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.4	-0.9	-20.2	0.7	6.3	-18.1	0.9	7.2	12.9	11.7	11.3	11.1	2.5	30	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	40.0	18.1	38.6	17.7	37.4	17.2	20.2	33.3	19.5	32.9	18.9	32.8	5.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	13.5	24.2	14.9	11.9	26.2	12.9	10.5	27.6	62.2	32.8	59.6	32.8	57.1	32.7	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	10.4	9.0	DB	-5.6	42.3	1.8	1.5	-6.9	43.4	-8.0	44.3	-9.0	45.1	-10.3	46.1	(4)
(5)			WB	-8.1	21.6	1.5	1.7	-9.1	22.9	-10.0	23.9	-10.8	24.8	-11.8	26.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.0	7.9	9.1	12.9	16.0	21.1	27.0	30.4	29.4	25.1	18.0	11.5	6.9	(6)	
	DBStd	8.95	3.46	3.69	3.94	4.31	4.45	3.90	2.49	2.37	3.31	3.97	4.09	3.28	(7)	
	HDD10.0	298	83	56	18	6	0	0	0	0	0	2	30	104	(8)	
	HDD18.3	1488	324	258	171	94	25	2	0	0	2	53	205	353	(9)	
	CDD10.0	3217	17	32	108	184	343	510	633	602	452	251	76	9	(10)	
	CDD18.3	1365	0	0	3	23	110	262	374	343	203	44	1	0	(11)	
	CDH23.3	20158	0	1	63	317	1456	3961	5975	5209	2624	527	24	0	(12)	
	CDH26.7	11596	0	0	7	81	641	2339	3833	3195	1347	152	1	0	(13)	
(14) Wind	WSAvg	3.9	3.5	3.7	4.1	4.5	4.4	4.4	4.0	3.8	3.7	3.5	3.4	3.4	(14)	
(15) Precipitation	PrecAvg	127	16	24	14	8	4	4	10	8	9	10	7	16	(15)	
	PrecMax	269	86	118	52	38	13	32	44	28	60	62	25	113	(16)	
	PrecMin	38	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	54	21	28	15	10	4	8	11	9	15	15	7	22	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	22.8	27.5	31.6	37.0	40.8	42.0	41.1	37.4	32.4	25.8	19.2	(19)	
		MCWB	8.4	9.5	11.2	13.9	17.2	17.7	19.1	18.7	17.5	15.2	11.1	7.9	(20)	
	2%	DB	17.9	20.7	25.1	28.9	34.2	38.6	40.5	39.1	35.8	30.1	23.7	17.1	(21)	
		MCWB	7.4	8.5	10.6	12.4	15.1	17.1	18.5	17.9	16.6	14.1	10.1	7.3	(22)	
	5%	DB	16.3	18.6	23.1	27.0	32.4	37.2	39.1	37.8	34.6	28.3	21.5	15.2	(23)	
		MCWB	6.7	7.8	9.8	11.5	14.1	16.4	17.9	17.5	16.1	12.8	9.4	6.4	(24)	
	10%	DB	14.4	16.5	21.3	24.9	30.5	35.9	37.8	36.6	33.2	26.4	19.2	13.3	(25)	
		MCWB	6.1	6.7	8.8	10.5	13.3	15.7	17.6	16.9	15.5	11.8	8.4	5.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	11.2	12.5	14.4	17.9	19.4	21.7	20.9	19.8	16.4	12.6	10.3	(27)	
		MCDB	15.9	18.9	23.6	30.3	36.1	39.1	36.1	32.0	30.4	28.2	21.7	15.5	(28)	
	2%	WB	9.1	9.7	11.3	12.9	15.8	18.0	20.4	20.1	18.7	15.2	11.2	9.1	(29)	
		MCDB	14.4	17.4	22.8	27.6	32.1	36.9	34.0	32.2	30.8	26.9	21.1	14.3	(30)	
	5%	WB	8.2	8.7	10.3	11.8	14.7	17.1	19.8	19.3	17.8	14.0	10.1	7.8	(31)	
		MCDB	13.8	16.4	21.7	25.2	30.8	35.6	33.4	32.4	30.1	25.2	19.9	12.9	(32)	
	10%	WB	7.1	7.6	9.4	10.9	13.7	16.2	19.1	18.6	16.9	12.9	9.1	6.5	(33)	
		MCDB	13.1	14.8	19.9	23.4	29.4	34.3	33.0	32.5	29.7	24.1	18.2	12.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	11.1	12.5	12.8	13.4	13.9	13.5	13.5	13.6	13.0	11.9	10.4	(35)	
		MCDBR	13.3	14.1	15.1	15.5	15.6	15.8	15.2	15.3	15.3	15.5	14.3	13.2	(36)	
	5% WB	MCWBR	7.0	6.7	6.9	7.1	7.0	7.1	6.3	6.1	6.5	7.3	7.0	7.2	(37)	
		MCWBR	10.9	12.2	14.2	14.7	15.8	15.6	13.0	13.2	13.3	14.0	13.2	10.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.257	0.265	0.274	0.301	0.318	0.315	0.344	0.337	0.306	0.284	0.261	0.259	(40)	
		taud	2.623	2.607	2.573	2.477	2.453	2.477	2.458	2.461	2.541	2.593	2.624	2.623	(41)	
	Ebn at Noon		963	989	1002	981	962	960	929	932	952	952	948	938	(42)	
		Edh at Noon	71	81	92	108	112	110	111	108	94	81	70	66	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.00	3.96	5.48	6.88	7.78	8.53	7.66	7.12	6.20	4.61	3.40	2.66	(44)	
	RadStd		0.25	0.37	0.24	0.29	0.41	0.37	0.37	0.34	0.23	0.28	0.14	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.69	+0.80	N/A	N/A	-0.54	N/A	N/A	-127	+146	N/A	(46)	
(47)	Regional (12 neighbors)	+0.57	N/A	-1.34	N/A	N/A	N/A	N/A	-101	+163	+76	(47)	

Nomenclature: See separate page