

MAMMOTH YOSEMITE, CA, USA

WMO: 723894

Lat: 37.633N

Lon: 118.850W

Elev: 2173

StdP: 77.81

Time Zone: -8.00 (NAP)

Period: 08-19

WBAN: 03181

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-17.9	-15.0	-24.0	0.6	-4.1	-21.8	0.7	-3.8	15.7	6.3	12.9	5.6	1.1	350	0.643

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	30.2	12.3	29.0	11.9	27.9	11.5	14.1	25.2	13.4	25.1	12.7	24.9	5.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.5	10.3	16.4	8.8	9.2	16.5	7.4	8.3	16.0	46.9	25.1	44.6	24.7	42.5	24.9	16.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.3	8.6	DB	-24.8	32.3	4.0	1.3	-27.7	33.2	-30.0	34.0	-32.3	34.7	-35.2	35.7	(4)
(5)			WB	-25.1	15.8	4.0	0.6	-27.9	16.2	-30.2	16.6	-32.5	17.0	-35.3	17.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.3	-1.7	-0.8	2.2	6.0	9.5	15.1	18.0	17.1	13.7	8.0	2.5	-2.0	(6)
(7)		DBStd	8.11	5.14	5.35	4.22	4.09	3.59	3.46	2.35	2.14	2.96	3.25	4.41	4.89	(7)
(8)		HDD10.0	1775	363	304	242	126	52	4	0	0	8	77	227	372	(8)
(9)		HDD18.3	4056	622	537	500	369	273	106	33	50	139	321	476	631	(9)
(10)		CDD10.0	804	0	1	0	7	37	157	249	219	119	14	1	0	(10)
(11)		CDD18.3	43	0	0	0	0	0	8	24	11	1	0	0	0	(11)
(12)		CDH23.3	2382	0	0	0	1	23	461	909	736	238	13	0	0	(12)
(13)		CDH26.7	573	0	0	0	0	1	112	263	174	23	0	0	0	(13)
(14)	Wind	WSAvg	2.9	2.2	2.9	3.2	3.8	3.7	3.6	2.9	2.8	2.7	2.6	2.5	2.5	(14)
(15)	Precipitation	PrecAvg	345	57	54	44	25	21	10	13	10	11	21	26	51	(15)
(16)		PrecMax	526	152	177	172	76	52	42	28	21	36	74	88	189	(16)
(17)		PrecMin	176	5	8	3	4	4	1	3	2	1	1	2	6	(17)
(18)		PrecStd	86	43	34	40	16	12	9	7	5	8	19	21	37	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	17.3	19.0	22.5	25.9	31.4	32.2	31.2	28.7	25.1	20.2	15.1	(19)
(20)			MCWB	4.1	5.0	6.1	8.4	9.6	12.8	12.9	12.4	10.8	8.8	6.7	3.8	(20)
(21)		2%	DB	12.5	14.9	16.3	20.2	23.7	29.4	30.6	29.8	27.3	22.5	17.7	12.7	(21)
(22)			MCWB	2.7	3.8	4.3	7.0	8.7	11.9	12.6	12.0	10.7	7.9	5.6	2.6	(22)
(23)		5%	DB	10.0	12.3	14.1	18.6	22.1	27.8	29.3	28.7	26.1	20.3	15.4	10.1	(23)
(24)			MCWB	2.0	2.7	3.5	6.2	8.2	11.1	12.3	11.6	10.2	7.2	4.4	2.0	(24)
(25)		10%	DB	7.2	9.0	12.2	16.5	20.0	26.2	28.0	27.5	24.8	18.1	12.6	7.7	(25)
(26)			MCWB	0.9	1.5	3.0	5.3	7.4	10.5	12.0	11.2	9.8	6.2	3.3	1.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.8	5.6	6.4	9.2	10.5	14.0	15.3	14.5	13.5	10.4	7.6	5.4	(27)
(28)			MCD B	12.4	15.0	17.2	20.2	23.0	27.7	24.8	25.2	22.8	19.0	18.0	11.8	(28)
(29)		2%	WB	3.5	4.3	5.1	7.8	9.6	12.9	14.4	13.5	12.2	9.2	6.2	3.9	(29)
(30)			MCD B	9.9	13.1	14.9	18.4	21.2	26.7	25.0	24.9	23.7	19.2	15.9	9.9	(30)
(31)		5%	WB	2.6	3.0	4.2	6.7	8.9	12.0	13.7	12.8	11.2	8.0	5.1	2.7	(31)
(32)			MCD B	8.3	10.7	13.2	17.3	19.8	25.5	25.0	24.7	23.4	17.8	14.2	9.1	(32)
(33)		10%	WB	1.4	1.9	3.2	5.7	8.0	11.1	13.1	12.1	10.4	7.0	3.8	1.3	(33)
(34)			MCD B	6.3	8.6	10.7	15.5	18.4	24.3	24.9	24.7	22.9	16.4	12.0	7.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.6	15.0	15.5	16.6	16.8	19.2	20.0	20.9	20.6	19.4	18.3	15.7	(35)
(36)			MCDBR	19.8	19.6	20.1	20.6	20.6	21.8	21.2	22.5	22.6	23.0	22.5	19.6	(36)
(37)			MCWBR	11.6	10.5	10.1	9.7	9.3	8.8	8.1	9.0	9.8	11.1	12.0	11.2	(37)
(38)		5% WB	MCD BR	16.1	17.9	18.3	19.2	19.3	20.2	18.6	19.5	19.8	19.9	20.9	17.1	(38)
(39)			MCWBR	10.0	9.9	9.4	9.4	8.7	8.0	7.2	7.8	8.5	9.8	11.2	10.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.245	0.260	0.261	0.298	0.303	0.298	0.314	0.298	0.282	0.269	0.244	0.242	(40)	
(41)		taud	2.427	2.383	2.436	2.402	2.466	2.503	2.503	2.532	2.582	2.592	2.599	2.485	(41)	
(42)		Ebn at Noon	960	983	1011	983	976	976	957	970	976	965	963	944	(42)	
(43)		Edh at Noon	82	99	104	115	110	106	106	100	90	80	69	73	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.62	3.51	4.82	6.20	7.15	8.28	7.83	7.31	6.16	4.50	3.10	2.32	(44)	
(45)		RadStd	0.26	0.37	0.37	0.40	0.58	0.53	0.46	0.37	0.24	0.32	0.18	0.27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (18 neighbors)		+0.54	N/A	N/A	+0.44	N/A	N/A	-47	-113	+131	+66		

Nomenclature: See separate page