

POINT PIEDRAS BLANCAS, CA, USA

WMO: 723900

Lat: 35.666N

Lon: 121.285W

Elev: 21

StdP: 101.07

Time Zone: -8.00 (NAP)

Period: 90-05

WBAN: 93226

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.4	6.7	-3.4	2.9	10.0	-1.4	3.4	10.3	16.5	11.8	15.2	11.4	2.9	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	5.4	22.8	16.2	20.7	15.2	19.1	14.8	16.9	21.2	16.1	19.4	15.5	18.3	4.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.1	10.7	17.8	14.4	10.2	17.2	14.0	10.0	16.7	47.3	21.5	45.1	19.4	43.3	18.5	19.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.0	12.5	11.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	12.0	12.1	12.1	11.9	12.6	13.2	14.1	14.9	14.6	14.9	13.9	11.8
	DBStd	2.19	2.20	2.06	1.79	1.50	1.56	1.94	1.32	1.33	1.49	2.63	1.96	1.85
	HDD10.0	20	6	4	3	2	1	0	0	0	0	0	0	4
	HDD18.3	1889	195	176	193	193	179	156	130	107	111	113	134	202
	CDD10.0	1183	69	62	68	58	80	96	128	151	139	152	117	61
	CDD18.3	11	0	0	0	0	0	3	0	0	1	7	1	0
	CDH23.3	29	1	0	0	0	0	6	0	0	2	19	2	1
	CDH26.7	1	0	0	0	0	0	0	0	0	0	1	0	0
Wind	WSAvg	4.7	3.8	4.3	4.9	5.7	5.8	5.9	4.8	4.8	4.7	4.1	3.8	4.0
Precipitation	PrecAvg	448	90	87	67	31	16	3	1	1	2	23	45	83
	PrecMax	777	275	300	230	97	82	28	8	3	11	99	119	183
	PrecMin	192	11	1	1	2	0	0	0	0	0	5	5	5
	PrecStd	141	67	63	56	23	18	6	2	1	3	28	28	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.8	20.9	18.7	17.8	18.8	24.3	19.4	20.6	21.5	25.2	23.0	20.1
		MCWB	14.4	14.6	14.5	13.9	14.6	17.7	14.9	16.2	16.1	17.8	15.0	13.9
	2%	DB	18.4	17.5	17.2	16.7	17.4	19.2	18.3	19.2	19.3	23.5	20.2	16.3
		MCWB	12.8	13.5	13.6	13.4	14.0	15.1	14.8	15.3	15.2	16.9	13.7	12.4
	5%	DB	16.5	16.1	16.1	15.8	16.4	17.2	17.5	18.3	18.3	21.2	18.4	15.5
		MCWB	12.7	12.8	13.0	12.8	13.3	13.9	14.3	14.9	14.9	15.7	13.8	12.2
	10%	DB	15.3	14.9	15.1	14.9	15.4	16.1	16.7	17.5	17.4	19.0	17.2	14.7
		MCWB	12.1	12.3	12.5	12.2	12.6	12.9	13.9	14.7	14.4	14.9	13.1	11.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.6	15.7	15.1	14.6	15.6	17.7	16.2	16.9	17.0	18.0	16.5	14.7
		MCDB	19.3	19.5	17.5	16.9	18.0	23.9	18.1	19.2	20.1	24.2	19.4	18.5
	2%	WB	14.3	14.4	14.2	13.8	14.5	15.4	15.2	16.1	15.8	17.1	15.6	13.8
		MCDB	17.0	17.0	16.4	16.2	16.7	18.9	17.6	18.5	18.5	22.6	18.4	15.4
	5%	WB	13.6	13.4	13.5	13.0	13.7	14.2	14.7	15.5	15.2	16.1	14.8	13.1
		MCDB	15.6	15.3	15.5	15.3	15.8	17.0	17.0	17.7	17.7	20.4	17.4	14.6
	10%	WB	12.9	12.7	12.8	12.4	13.0	13.3	14.2	15.0	14.7	15.3	14.1	12.6
		MCDB	14.6	14.4	14.6	14.4	14.9	15.6	16.4	17.1	17.1	18.6	16.3	14.1
Mean Daily Temperature Range	5% DB	MDBR	6.1	5.2	5.2	5.2	4.8	4.8	4.2	4.7	4.9	5.4	5.9	5.7
		MCDBR	7.7	6.8	6.7	6.6	6.3	6.5	5.4	6.2	6.7	9.1	8.2	6.5
		MCWBR	5.9	5.3	5.1	4.8	4.7	4.4	3.7	4.1	4.6	5.4	6.2	5.7
	5% WB	MCDBR	6.5	5.5	5.7	6.3	5.9	6.3	5.1	5.6	5.9	8.0	6.3	5.4
		MCWBR	5.4	4.6	4.6	4.8	4.5	4.3	3.5	3.8	4.1	5.2	5.3	5.0
Clear-Sky Solar Irradiance	taub	0.312	0.323	0.333	0.347	0.363	0.339	0.364	0.341	0.350	0.344	0.316	0.317	
	taud	2.577	2.553	2.523	2.473	2.443	2.521	2.481	2.534	2.501	2.528	2.567	2.571	
	Ebn at Noon	896	923	940	936	920	937	912	931	908	886	881	865	
	Edh at Noon	77	88	98	109	114	105	109	101	99	89	77	73	
All-Sky Solar Radiation	RadAvg	2.81	3.67	5.07	6.34	7.14	7.51	6.82	6.20	5.52	4.24	3.17	2.46	
	RadStd	0.25	0.38	0.36	0.47	0.46	0.36	0.33	0.36	0.30	0.29	0.18	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.47	N/A	N/A	+0.50	N/A	N/A	N/A	-142	+169	+39

Nomenclature: See separate page