

POINT MUGU NAS, CA, USA

WMO: 723910

Lat: 34.117N

Lon: 119.117W

Elev: 13

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93111

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	38.9	41.1	8.4	8.5	62.7	14.0	11.2	64.9	28.6	63.2	26.3	61.2	4.9	10	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.2	82.7	61.8	79.4	63.2	76.7	63.3	70.1	76.7	68.5	75.1	67.2	73.7	12.5	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	101.7	73.9	65.8	95.3	72.8	64.2	90.1	70.6	34.0	75.6	32.7	75.1	31.6	73.9	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	19.1	16.5	34.8	92.2	3.0	4.6	32.6	95.5	30.9	98.2	29.2	100.8	27.0	104.1
			31.4	72.1	3.3	2.7	29.0	74.0	27.1	75.6	25.3	77.2	22.9	79.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.2	56.0	55.1	56.3	57.0	59.2	62.4	65.5	66.1	65.7	63.4	59.6	55.2
	DBStd	6.06	6.10	5.25	4.51	4.14	3.01	2.81	3.09	3.49	4.01	4.72	5.45	5.30
	HDD50	30	8	8	3	1	0	0	0	0	0	0	1	9
	HDD65	2033	292	283	273	243	181	87	30	27	37	87	182	311
	CDD50	3735	194	151	198	212	286	371	479	501	470	416	288	169
	CDD65	265	13	6	4	4	2	9	44	62	58	38	19	6
	CDH74	1291	87	50	41	52	17	21	85	180	250	290	170	48
	CDH80	247	18	13	9	11	3	3	6	12	34	87	43	8
(14) Wind	WSAvg	6.9	7.6	7.5	7.4	7.8	7.3	6.6	6.4	6.1	5.8	6.3	6.7	7.5
(15) Precipitation	PrecAvg	11.2	2.4	3.1	2.1	0.7	0.1	0.0	0.0	0.1	0.1	0.2	1.9	1.8
	PrecMax	20.6	11.6	16.6	7.3	4.2	1.5	0.3	0.2	1.2	0.9	0.8	6.4	5.3
	PrecMin	3.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	5.1	2.6	3.8	2.0	1.0	0.3	0.1	0.0	0.2	0.2	0.2	1.6	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.1	81.9	79.8	81.1	75.3	76.4	79.7	81.4	84.0	90.4	85.8	80.3
		MCWB	55.8	56.6	57.6	58.0	62.4	65.1	69.4	69.4	68.4	58.9	58.9	53.7
	2%	DB	75.5	72.6	72.4	73.0	70.6	72.6	76.3	78.1	80.0	81.7	78.7	72.7
		MCWB	53.8	54.3	55.8	58.2	61.6	64.3	67.9	68.0	68.8	60.0	56.3	52.9
	5%	DB	71.3	68.0	67.8	68.3	68.1	70.6	73.8	75.7	76.9	76.5	74.0	68.1
		MCWB	52.9	55.1	56.7	58.0	60.3	63.2	66.3	67.0	67.4	61.3	55.9	52.8
	10%	DB	66.8	64.0	64.2	65.1	66.1	69.2	72.2	73.5	74.1	72.5	70.0	64.9
		MCWB	52.6	54.5	56.7	57.4	59.4	62.4	65.4	65.8	66.0	62.0	56.6	53.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.4	61.5	62.4	62.5	65.4	67.4	72.3	70.7	71.8	70.2	64.8	62.3
		MCDB	66.8	69.3	69.0	71.1	71.1	73.2	75.0	78.6	79.8	76.6	73.8	66.1
	2%	WB	59.6	59.5	60.3	60.5	63.1	65.4	69.6	69.0	70.0	67.3	62.5	60.1
		MCDB	64.5	65.8	66.6	68.0	67.7	70.8	74.5	76.2	77.5	73.5	69.8	64.2
	5%	WB	58.3	58.1	59.1	59.3	61.8	64.1	67.6	67.8	68.3	65.2	61.0	58.3
		MCDB	63.4	63.8	64.5	65.9	66.3	68.9	73.3	74.6	75.5	71.6	67.7	62.9
	10%	WB	56.9	56.8	57.8	58.2	60.2	63.0	65.9	66.4	66.7	63.7	59.6	56.7
		MCDB	62.3	62.0	62.7	64.1	64.9	67.6	71.5	72.9	73.3	69.4	65.9	61.7
(35) Mean Daily Temperature Range	5% DB	MDBR	18.0	16.8	15.9	16.2	14.0	13.2	13.1	14.2	15.2	17.3	19.2	18.7
		MCDBR	24.1	23.5	22.9	22.6	17.3	15.8	15.1	16.5	18.9	25.0	25.9	23.5
		MCWBR	12.2	12.9	12.9	12.8	10.2	9.3	8.4	9.2	10.2	13.1	13.6	13.4
	5% WB	MCDBR	17.6	17.0	16.2	18.2	15.4	14.2	13.9	15.6	17.3	18.1	19.7	17.4
		MCWBR	12.6	11.5	11.3	11.8	9.7	8.8	8.3	8.9	10.1	12.3	13.8	12.7
(40) Clear-Sky Solar Irradiance	taub		0.309	0.320	0.334	0.375	0.394	0.390	0.418	0.387	0.381	0.360	0.314	0.316
	taud		2.579	2.566	2.518	2.387	2.355	2.376	2.352	2.412	2.429	2.477	2.590	2.576
	Ebn at Noon		288	296	299	289	283	283	274	282	279	277	284	279
	Edh at Noon		25	28	32	38	40	39	39	36	34	30	24	24
(44) All-Sky Solar Radiation	RadAvg		990	1268	1694	2096	2275	2351	2321	2198	1877	1433	1110	899
	RadStd		73	128	108	120	167	126	115	85	80	113	68	71

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)		+1.13	N/A	-3.06	+1.26	N/A	N/A	N/A	-230	+419	+173

Nomenclature: See separate page