

MERCURY 3 SSW, NV, USAWMO: **723920**Lat: **36.6240N**Lon: **116.0225W**Elev: **3284**StdP: **13.03**Time Zone: **-8.00 (NAP)**Period: **04-19**WBAN: **53136****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	25.9	28.7	-8.9	3.8	56.0	-3.6	5.1	59.0	18.5	52.2	16.4	50.5	3.7	N/A	0.457

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.9	103.7	61.9	101.4	61.3	99.4	60.7	67.2	88.2	66.0	89.0	64.8	89.4	8.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.0	90.7	75.0	57.7	80.4	77.2	54.8	72.1	79.5	33.5	88.3	32.5	89.7	31.5	89.1	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.6	15.4	13.7	20.1	107.9	3.1	1.4	17.9	108.9	16.0	109.7	14.3	110.5	12.0	111.5		
(5)			17.1	69.2	2.7	1.3	15.2	70.1	13.6	70.8	12.1	71.5	10.1	72.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.6	45.1	47.7	54.0	60.6	69.1	80.3	86.3	83.8	76.1	63.3	52.2	43.2		
	DBStd	16.11	6.29	6.61	6.71	6.95	7.52	6.23	4.14	4.02	6.28	6.74	7.16	5.98		
	HDD50	607	173	111	36	5	0	0	0	0	0	5	57	220		
	HDD65	2834	617	483	343	167	48	1	0	0	6	109	385	675		
	CDD50	5562	20	48	162	322	591	909	1127	1049	783	418	123	10		
	CDD65	2315	0	0	3	35	174	460	662	584	339	57	1	0		
	CDH74	34329	0	1	101	562	2393	6981	10453	8619	4414	757	48	0		
	CDH80	19850	0	0	11	152	1033	4184	6698	5270	2309	191	2	0		
(14) Wind	WSAvg	6.0	5.5	5.7	6.4	7.0	6.9	6.3	6.0	5.7	5.6	5.3	5.1			
(15) Precipitation	PrecAvg	5.0	0.6	0.9	0.6	0.3	0.2	0.2	0.4	0.3	0.4	0.4	0.3	0.6		
	PrecMax	10.6	3.4	4.6	2.0	1.5	0.5	1.3	1.7	1.1	2.4	2.4	1.0	4.4		
	PrecMin	1.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	2.1	0.8	1.1	0.6	0.4	0.2	0.3	0.4	0.4	0.6	0.6	0.3	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.3	72.6	82.0	89.2	95.9	105.6	107.5	103.5	99.4	88.6	78.9	66.2		
		MCWB	45.5	48.1	51.8	55.2	57.2	60.6	63.7	62.1	59.8	57.5	52.4	44.8		
	2%	DB	63.9	69.4	76.8	84.4	92.7	102.3	104.8	101.4	96.5	84.9	74.9	62.3		
		MCWB	44.2	46.8	49.9	52.6	55.5	60.0	62.8	62.2	60.1	55.5	49.5	44.3		
	5%	DB	60.8	65.7	72.9	80.5	89.6	99.6	102.4	99.7	94.4	81.8	71.0	58.9		
		MCWB	43.3	45.7	48.3	51.3	54.4	58.8	62.0	61.2	59.2	53.0	47.8	43.1		
	10%	DB	57.3	62.1	69.3	76.6	86.3	97.0	100.1	97.8	91.8	78.3	66.8	55.3		
		MCWB	41.7	44.4	47.0	49.8	53.5	57.9	61.6	60.6	58.1	51.6	46.4	41.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	51.5	52.9	56.6	57.4	64.3	68.6	68.5	66.8	61.5	53.3	50.4		
		MCDB	62.0	64.0	75.4	86.7	90.6	100.8	86.1	86.9	84.1	77.6	76.8	60.0		
	2%	WB	47.3	48.8	51.1	54.1	56.3	62.4	67.4	67.0	64.4	59.2	51.1	48.4		
		MCDB	57.0	64.3	72.7	80.4	87.8	97.3	89.0	87.6	86.3	75.0	70.9	56.7		
	5%	WB	45.6	47.3	49.6	52.3	55.1	60.4	66.3	65.9	62.8	56.9	49.3	45.7		
		MCDB	57.1	63.7	70.4	76.8	84.8	94.8	89.3	88.7	85.9	74.0	67.5	54.1		
	10%	WB	43.8	45.6	48.1	50.9	53.8	59.1	65.2	64.6	61.3	55.0	47.4	43.4		
		MCDB	55.5	60.9	67.6	74.4	81.6	94.0	89.7	88.7	83.9	72.8	65.1	52.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.8	22.0	24.2	25.4	25.5	27.6	25.9	26.2	26.4	24.6	23.9	19.9		
		MCDBR	25.4	27.8	29.3	29.6	29.7	30.9	28.6	28.3	29.2	29.1	28.8	25.4		
		MCWBR	13.1	12.9	12.1	12.3	11.5	11.2	9.2	9.5	10.7	12.0	13.8	13.5		
	5% WB	MCDBR	21.3	25.2	26.3	26.6	27.9	28.3	21.8	23.0	22.9	21.8	26.4	19.7		
		MCWBR	11.7	12.2	11.4	11.3	10.5	10.1	6.9	6.9	8.2	8.8	12.6	10.8		
(40) Clear-Sky Solar Irradiance	taub		0.256	0.265	0.274	0.300	0.317	0.314	0.343	0.336	0.305	0.284	0.261	0.258		
	taud		2.624	2.608	2.575	2.479	2.455	2.479	2.460	2.463	2.543	2.594	2.625	2.624		
	Ebn at Noon		305	314	318	312	305	305	295	296	302	302	301	298		
	Edh at Noon		22	26	29	34	36	35	35	34	30	26	22	21		
(44) All-Sky Solar Radiation	RadAvg		950	1256	1739	2184	2468	2706	2429	2259	1966	1462	1079	843		
	RadStd		78	117	78	92	131	117	117	107	74	88	44	62		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+398	N/A
(47) Regional (12 neighbors)		+1.03	N/A	-2.41	N/A	N/A	N/A	N/A	-182	+293	+137

Nomenclature: See separate page