

MERCURY 3 SSW, NV, USAWMO: **723920**Lat: **36.6240N**Lon: **116.0225W**Elev: **1001**StdP: **89.86**Time Zone: **-8.00 (NAP)**Period: **04-19**WBAN: **53136****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-3.4	-1.8	-22.7	0.5	13.3	-19.8	0.7	15.0	8.3	11.2	7.4	10.3	1.7	N/A	0.457

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	39.8	16.6	38.5	16.3	37.4	15.9	19.5	31.2	18.9	31.7	18.2	31.9	3.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.1	13.0	23.9	14.3	11.5	25.1	12.7	10.3	26.4	60.0	31.3	57.7	32.1	55.4	31.7	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.9	6.1	-6.6	42.2	1.7	0.8	-7.9	42.7	-8.9	43.2	-9.9	43.6	-11.1	44.2		
(5)			-8.3	20.6	1.5	0.7	-9.4	21.1	-10.2	21.6	-11.1	22.0	-12.2	22.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	7.3	8.7	12.2	15.9	20.6	26.8	30.2	28.8	24.5	17.4	11.2	6.2
	DBStd	8.95	3.49	3.67	3.73	3.86	4.18	3.46	2.30	2.24	3.49	3.75	3.98	3.32
	HDD10.0	337	96	62	20	3	0	0	0	0	3	32	122	
	HDD18.3	1574	343	268	191	93	27	1	0	3	61	214	375	
	CDD10.0	3090	11	27	90	179	328	505	626	583	435	232	68	6
	CDD18.3	1286	0	0	2	19	97	256	368	324	188	32	1	0
	CDH23.3	19072	0	1	56	312	1329	3878	5807	4788	2452	421	27	0
	CDH26.7	11028	0	0	6	84	574	2324	3721	2928	1283	106	1	0
(14) Wind	WSAvg	2.7	2.4	2.6	2.9	3.1	3.1	3.1	2.8	2.7	2.6	2.5	2.4	2.3
(15) Precipitation	PrecAvg	127	16	24	14	8	4	4	10	8	9	10	7	16
	PrecMax	269	86	118	52	38	13	32	44	28	60	62	25	113
	PrecMin	38	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	54	21	28	15	10	4	8	11	9	15	15	7	22
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.6	22.5	27.8	31.8	35.5	40.9	42.0	39.7	37.4	31.5	26.1	19.0
		MCWB	7.5	8.9	11.0	12.9	14.0	15.9	17.6	16.7	15.4	14.2	11.3	7.1
	2%	DB	17.7	20.8	24.9	29.1	33.7	39.0	40.5	38.6	35.9	29.4	23.8	16.8
		MCWB	6.8	8.2	9.9	11.5	13.1	15.6	17.1	16.8	15.6	13.1	9.7	6.8
	5%	DB	16.0	18.7	22.7	26.9	32.0	37.6	39.1	37.6	34.7	27.6	21.6	14.9
		MCWB	6.3	7.6	9.1	10.7	12.5	14.9	16.7	16.2	15.1	11.7	8.8	6.2
	10%	DB	14.1	16.7	20.7	24.8	30.2	36.1	37.8	36.5	33.2	25.7	19.3	12.9
		MCWB	5.4	6.9	8.3	9.9	12.0	14.4	16.4	15.9	14.5	10.9	8.0	5.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	10.8	11.6	13.7	14.1	18.0	20.4	20.3	19.4	16.4	11.9	10.2
		MCDB	16.7	17.8	24.1	30.4	32.6	38.2	30.1	30.5	28.9	25.3	24.9	15.5
	2%	WB	8.5	9.3	10.6	12.3	13.5	16.9	19.7	19.5	18.0	15.1	10.6	9.1
		MCDB	13.9	18.0	22.6	26.9	31.0	36.3	31.7	30.9	30.2	23.9	21.6	13.7
	5%	WB	7.5	8.5	9.8	11.3	12.8	15.8	19.1	18.8	17.1	13.8	9.6	7.6
		MCDB	14.0	17.6	21.3	24.9	29.3	34.9	31.9	31.5	30.0	23.3	19.7	12.3
	10%	WB	6.6	7.6	8.9	10.5	12.1	15.1	18.5	18.1	16.3	12.8	8.6	6.3
		MCDB	13.0	16.0	19.8	23.5	27.6	34.5	32.1	31.5	28.8	22.7	18.4	11.2
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	12.2	13.4	14.1	14.2	15.3	14.4	14.6	14.7	13.7	13.3	11.1
		MCDBR	14.1	15.4	16.3	16.5	16.5	17.1	15.9	15.7	16.2	16.2	16.0	14.1
	5% WB	MCWBR	7.3	7.2	6.7	6.9	6.4	6.2	5.1	5.3	6.0	6.7	7.7	7.5
		MCWBR	11.9	14.0	14.6	14.8	15.5	15.7	12.1	12.8	12.7	12.1	14.7	10.9
(40) Clear-Sky Solar Irradiance	taub		0.256	0.265	0.274	0.300	0.317	0.314	0.343	0.336	0.305	0.284	0.261	0.258
		taud	2.624	2.608	2.575	2.479	2.455	2.479	2.460	2.463	2.543	2.594	2.625	2.624
	Ebn at Noon		963	990	1003	982	963	961	930	933	953	952	949	938
		Edh at Noon	70	81	92	107	112	109	111	108	94	81	70	66
(44) All-Sky Solar Radiation	RadAvg		3.00	3.96	5.48	6.88	7.78	8.53	7.66	7.12	6.20	4.61	3.40	2.66
	RadStd		0.25	0.37	0.24	0.29	0.41	0.37	0.37	0.34	0.23	0.28	0.14	0.19

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	+221	N/A
(47) Regional (12 neighbors)		+0.57	N/A	-1.34	N/A	N/A	N/A	N/A	-101	+163

Nomenclature: See separate page