

CAMARILLO, CA, USA

WMO: 723926

Lat: 34.217N

Lon: 119.083W

Elev: 24

StdP: 101.04

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23136

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	3.2	4.5	-14.7	1.0	18.6	-11.5	1.4	17.9	15.0	17.2	13.5	18.1	1.2	70	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.3	31.0	17.2	28.7	17.1	27.2	17.4	20.9	26.7	20.2	25.8	19.6	24.9	5.8	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.6	24.2	17.9	12.9	22.8	17.4	12.5	22.0	60.4	26.9	58.0	26.0	55.8	24.9	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.1	8.9	7.3	DB	0.9	36.6	1.1	2.3	0.1	38.3	-0.5	39.6	-1.1	40.9	-1.9	42.6	(4)
(5)			WB	-1.4	22.2	1.2	1.0	-2.3	22.9	-3.0	23.4	-3.7	24.0	-4.6	24.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	13.3	13.1	14.2	15.0	16.5	18.3	20.2	20.4	20.1	18.2	15.5	12.9	(6)	
	DBStd	3.78	3.36	2.98	2.58	2.57	2.11	1.72	1.90	1.86	2.38	2.98	3.21	2.91	(7)	
	HDD10.0	16	4	4	1	1	0	0	0	0	0	0	1	5	(8)	
	HDD18.3	954	161	150	133	106	66	21	4	3	7	37	97	169	(9)	
	CDD10.0	2386	108	91	130	150	201	248	316	323	302	255	166	96	(10)	
	CDD18.3	282	7	3	3	6	8	19	61	68	58	34	13	3	(11)	
	CDH23.3	1943	67	59	71	103	87	77	249	322	357	351	165	35	(12)	
(13)	CDH26.7	494	12	16	21	32	29	12	31	53	96	137	52	4	(13)	
(14)	Wind	WSAvg	2.6	3.1	2.9	2.7	2.8	2.6	2.4	2.3	2.1	2.1	2.5	2.7	3.1	(14)
(15) Precipitation	PrecAvg	381	89	98	62	19	9	2	1	0	3	13	29	57	(15)	
	PrecMax	761	422	450	209	88	52	20	10	2	18	92	96	241	(16)	
	PrecMin	119	0	0	0	1	0	0	0	0	0	0	0	0	(17)	
	PrecStd	174	88	94	54	20	13	4	2	1	3	20	24	57	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.2	29.1	29.4	31.0	30.1	28.6	29.4	30.7	32.5	34.8	32.0	27.2	(19)	
		MCWB	12.7	13.6	14.2	15.4	15.8	19.4	20.7	20.6	19.6	16.3	15.4	12.6	(20)	
	2%	DB	25.1	24.7	25.0	26.2	25.2	25.3	27.3	27.9	29.1	30.3	27.7	23.7	(21)	
		MCWB	11.6	12.5	13.2	14.4	16.5	18.2	19.8	20.0	19.6	15.5	14.0	11.6	(22)	
	5%	DB	22.5	21.4	22.0	22.9	22.8	23.7	26.0	26.4	27.1	26.9	24.6	21.0	(23)	
		MCWB	11.5	11.9	13.2	14.0	15.9	17.7	19.4	19.5	19.1	15.8	13.1	11.2	(24)	
	10%	DB	19.8	18.6	19.7	20.7	21.2	22.5	24.5	25.0	25.1	24.1	21.9	18.8	(25)	
		MCWB	10.8	11.8	13.3	13.7	15.5	17.1	18.9	18.9	18.5	15.7	13.0	11.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.8	15.9	16.7	17.1	18.9	20.1	21.9	21.6	21.9	20.5	17.9	16.3	(27)	
		MCDB	20.3	21.0	23.4	25.0	25.8	26.6	27.1	28.4	28.4	26.5	24.6	20.0	(28)	
	2%	WB	14.8	14.9	15.5	15.8	17.6	19.0	20.7	20.6	20.7	19.1	16.7	15.1	(29)	
		MCDB	18.4	19.4	21.0	22.2	23.3	24.4	25.7	26.7	26.6	24.8	22.2	18.4	(30)	
	5%	WB	14.0	14.1	14.7	15.1	16.6	18.2	20.0	20.0	19.9	18.0	15.7	14.1	(31)	
		MCDB	17.5	18.3	19.4	20.9	21.6	22.9	25.0	25.5	25.5	23.2	20.6	17.3	(32)	
	10%	WB	13.2	13.3	14.0	14.3	15.8	17.4	19.2	19.3	19.1	17.2	15.0	13.1	(33)	
		MCDB	17.2	17.1	18.1	19.3	20.1	21.8	24.0	24.4	24.2	22.0	19.4	16.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	10.9	10.7	10.8	9.3	8.4	8.6	9.3	9.9	11.2	12.1	11.6	(35)	
		MCDBR	15.2	15.8	15.9	15.8	12.8	10.6	10.2	11.3	12.9	16.6	16.6	14.8	(36)	
	5% WB	MCWBR	7.1	7.8	8.0	7.6	6.5	5.4	4.8	5.5	6.1	7.6	8.0	7.8	(37)	
		MCWBR	10.4	11.4	11.3	11.9	10.4	9.4	9.2	10.1	10.8	11.7	12.4	10.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.311	0.323	0.337	0.380	0.400	0.396	0.425	0.392	0.386	0.365	0.317	0.319	(40)	
		taud	2.562	2.547	2.496	2.362	2.328	2.353	2.324	2.392	2.405	2.447	2.573	2.557	(41)	
	Ebn at Noon		905	930	939	907	887	887	859	884	875	867	891	873	(42)	
		Edh at Noon	80	90	102	122	128	125	128	117	111	98	78	76	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.11	3.98	5.35	6.62	7.25	7.58	7.46	7.05	6.00	4.56	3.50	2.83	(44)	
	RadStd		0.23	0.42	0.34	0.37	0.50	0.39	0.35	0.24	0.23	0.34	0.20	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.90	+0.72	-2.40	+1.37	N/A	N/A	N/A	-252	+385	+177	(46)	
(47)	Regional (47 neighbors)	+0.63	N/A	-1.70	+0.70	N/A	N/A	N/A	-128	+233	+96	(47)	

Nomenclature: See separate page