

OXNARD, CA, USA

WMO: 723927

Lat: 34.201N

Lon: 119.207W

Elev: 36

StdP: 14.68

Time Zone: -8.00 (NAP)

Period: 98-19

WBAN: 93110

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 40.8	(c) 42.9	(d) 7.9	(e) 8.3	(f) 63.5	(g) 13.6	(h) 11.0	(i) 61.5	(j) 28.4	(k) 61.4	(l) 25.9	(m) 62.4	(n) 5.8	(o) 50	(p) 0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.7	(c) 82.4	(d) 60.1	(e) 78.8	(f) 60.6	(g) 75.5	(h) 61.9	(i) 68.8	(j) 75.4	(k) 67.3	(l) 73.6	(m) 66.1	(n) 72.1	(o) 12.4	(p) 70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 66.1	(b) 96.4	(c) 72.9	(d) 64.4	(e) 90.6	(f) 70.6	(g) 63.4	(h) 87.5	(i) 68.9	(j) 33.0	(k) 75.2	(l) 31.7	(m) 73.7	(n) 30.7	(o) 72.1	(p) 74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	19.3	16.7	36.6	93.1	2.2	5.5	35.0	97.1	33.7	100.4	32.5	103.5	30.9	107.5
			31.7	69.7	2.1	1.9	30.2	71.1	29.0	72.2	27.8	73.3	26.3	74.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.6	56.3	55.5	56.8	57.8	60.3	63.1	66.2	66.1	65.8	63.5	59.4	55.6
	DBStd	5.82	5.68	4.99	4.36	4.03	3.07	2.29	2.99	2.76	3.92	4.80	5.03	4.82
	HDD50	20	6	5	1	1	0	0	0	0	0	0	0	7
	HDD65	1885	278	270	260	220	152	65	20	19	33	88	184	296
	CDD50	3876	201	159	212	236	318	394	503	473	418	283	179	179
	CDD65	268	9	5	5	5	6	9	58	54	56	41	17	3
	CDH74	1096	81	54	53	54	53	12	68	69	184	305	133	30
(13) Wind	CDH80	265	13	13	12	17	20	2	4	4	39	103	34	4
	WSAvg	6.8	7.0	7.2	7.2	7.6	7.1	6.5	6.7	6.5	6.1	6.1	6.5	7.1
(15) Precipitation	PrecAvg	15.0	3.5	3.9	2.4	0.7	0.4	0.1	0.0	0.0	0.1	0.5	1.1	2.2
	PrecMax	30.0	16.6	17.7	8.2	3.5	2.0	0.8	0.4	0.1	0.7	3.6	3.8	9.5
	PrecMin	4.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	6.9	3.5	3.7	2.1	0.8	0.5	0.2	0.1	0.0	0.1	0.8	0.9	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.8	81.7	80.6	80.6	80.6	74.9	79.2	79.8	84.4	90.6	84.8	78.4
		MCWB	54.9	55.8	56.6	57.9	57.9	64.4	68.3	68.1	66.7	59.5	57.7	53.2
	2%	DB	75.3	72.8	72.7	72.6	71.3	71.7	75.5	75.5	78.7	81.5	77.5	71.7
		MCWB	52.4	53.0	54.9	56.8	60.1	63.1	66.9	66.6	66.8	59.7	55.8	52.6
	5%	DB	70.3	67.6	67.2	67.9	67.8	69.9	73.4	73.4	75.0	76.1	72.4	67.0
		MCWB	52.3	53.6	55.4	56.3	59.0	62.1	65.6	65.4	65.7	60.5	55.0	52.4
	10%	DB	65.8	63.5	64.0	64.8	66.0	68.2	72.0	72.1	72.7	72.0	68.2	63.9
		MCWB	51.8	53.2	55.5	56.3	58.4	61.1	64.7	64.7	64.8	60.7	55.8	52.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.0	60.2	60.7	61.2	63.2	65.9	70.0	69.4	70.8	69.3	63.1	61.3
		MCDB	65.8	66.2	68.7	70.7	69.5	73.0	76.4	76.7	78.0	76.6	71.4	66.4
	2%	WB	58.5	58.4	59.2	59.4	61.7	64.1	68.2	67.6	68.8	66.1	61.4	59.0
		MCDB	64.1	64.3	65.8	67.2	67.3	69.8	74.3	74.1	75.2	73.0	68.1	63.6
	5%	WB	57.3	57.2	58.0	58.3	60.4	63.0	66.5	66.4	67.0	64.2	60.1	57.3
		MCDB	63.2	63.0	64.1	65.3	65.9	68.0	72.2	72.4	73.3	70.6	66.5	61.8
	10%	WB	55.8	55.8	56.9	57.2	59.3	62.0	65.5	65.3	65.6	62.7	58.8	55.7
		MCDB	61.6	61.4	62.5	63.5	64.8	66.9	70.8	70.9	71.7	68.7	65.0	60.7
(35) Mean Daily Temperature Range	5% DB	MDBR	17.2	15.9	14.8	14.4	12.2	10.5	10.7	11.3	12.8	15.5	17.3	16.9
		MCDBR	24.1	23.0	21.8	20.8	15.8	12.6	12.4	13.1	16.1	24.1	24.2	21.5
		MCWBR	11.8	12.1	11.7	11.0	8.4	6.8	6.0	6.7	9.0	12.8	13.4	12.6
	5% WB	MCDBR	16.1	16.3	15.7	15.9	13.2	11.4	11.6	12.6	13.7	16.8	17.6	15.6
		MCWBR	11.0	10.9	9.7	9.2	7.4	6.3	5.7	6.7	7.7	11.2	12.5	11.8
(40) Clear-Sky Solar Irradiance	taub		0.308	0.319	0.331	0.376	0.397	0.390	0.420	0.388	0.382	0.359	0.313	0.315
	taud		2.578	2.566	2.522	2.381	2.343	2.374	2.342	2.405	2.422	2.472	2.588	2.573
	Ebn at Noon		289	297	300	289	282	283	274	282	279	277	284	279
	Edh at Noon		25	28	31	38	40	39	40	37	35	30	24	24
(44) All-Sky Solar Radiation	RadAvg		986	1264	1694	2101	2295	2385	2348	2218	1891	1441	1111	897
	RadStd		73	130	109	120	163	121	110	81	75	110	65	70

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.46	N/A	-4.79	+3.26	+1.44	N/A	N/A	-414	+569	+169
(47) Regional (45 neighbors)		+1.15	N/A	-3.13	+1.21	N/A	N/A	N/A	-230	+421	+171

Nomenclature: See separate page