

PASO ROBLES, CA, USA

WMO: 723965

Lat: 35.670N

Lon: 120.628W

Elev: 810

StdP: 14.27

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93209

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	27.1	29.6	16.2	12.8	49.3	20.0	15.5	47.8	21.2	54.4	19.1	53.4	1.7	80	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.3	102.3	66.6	99.0	65.8	95.4	64.6	69.3	95.5	67.7	93.6	66.1	91.3	8.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.0	79.5	72.7	57.9	73.8	71.2	56.5	70.1	69.9	33.8	95.7	32.2	93.7	31.1	91.3	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.7	18.9	17.4	DB	22.5	108.8	3.6	2.8	19.9	110.8	17.8	112.5	15.8	114.0	13.3	116.1	(4)
(5)			WB	21.0	73.2	3.6	3.3	18.4	75.6	16.3	77.5	14.3	79.4	11.7	81.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.6	48.9	50.5	54.2	57.6	63.9	69.8	74.1	74.0	70.4	62.3	53.6	47.7		
	DBStd	10.92	4.91	5.07	5.33	6.11	6.14	6.00	5.57	5.13	5.70	5.75	5.78	5.12		
	HDD50	294	78	52	20	9	0	0	0	0	0	0	29	106		
	HDD65	2611	498	407	334	233	97	21	2	1	16	121	344	537		
	CDD50	4173	45	65	152	236	430	593	746	742	611	383	137	33		
	CDD65	1015	0	0	1	10	62	164	284	279	176	38	1	0		
	CDH74	16335	7	16	142	489	1368	2727	3898	3807	2694	1055	131	1		
	CDH80	8895	1	0	28	174	648	1521	2297	2265	1491	443	27	0		
(14) Wind	WSAvg	6.4	4.8	5.3	5.9	7.4	8.6	9.0	8.1	7.3	6.2	5.2	4.5	4.6		
(15) Precipitation	PrecAvg	12.4	2.6	2.7	2.2	0.9	0.1	0.0	0.0	0.0	0.2	0.4	1.4	1.9		
	PrecMax	24.4	12.2	8.8	9.0	4.5	1.7	0.1	0.3	0.9	1.3	2.4	5.2	6.8		
	PrecMin	4.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	4.8	2.4	2.6	1.9	1.0	0.3	0.0	0.1	0.2	0.3	0.6	1.3	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.4	76.6	83.7	91.5	98.9	104.2	106.4	106.4	103.1	95.9	83.7	71.4		
		MCWB	52.6	57.8	60.7	61.2	65.1	67.4	68.8	69.0	66.5	63.9	58.3	51.7		
	2%	DB	68.1	71.3	78.0	85.1	92.9	99.0	101.6	101.6	98.6	89.7	77.8	66.1		
		MCWB	52.8	56.0	58.6	60.1	63.0	65.3	67.0	66.2	65.1	61.1	57.0	51.9		
	5%	DB	63.6	66.0	73.0	79.7	87.4	94.4	97.5	97.5	94.2	84.9	72.3	62.6		
		MCWB	52.7	54.0	56.5	58.4	61.0	64.0	65.8	65.4	63.7	59.5	55.3	52.1		
	10%	DB	59.7	61.7	68.4	74.3	81.9	89.5	93.1	92.9	89.5	80.0	67.2	58.8		
		MCWB	51.6	52.5	55.1	56.3	59.5	62.7	64.6	64.2	63.0	58.4	53.8	51.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.6	60.9	63.5	64.9	67.6	70.8	71.5	71.6	70.6	66.8	61.3	59.5		
		MCDB	64.2	70.0	78.2	83.8	94.2	99.3	101.5	99.7	92.2	86.4	74.5	64.3		
	2%	WB	56.6	58.1	60.2	61.6	64.7	67.7	69.0	68.6	67.4	63.7	59.3	56.8		
		MCDB	62.1	66.1	74.1	80.3	89.1	93.7	95.8	96.2	90.2	83.4	71.8	60.9		
	5%	WB	54.7	55.9	58.0	59.4	62.4	65.5	67.2	66.8	65.4	61.5	57.5	54.5		
		MCDB	60.0	63.4	70.4	77.0	84.2	90.5	93.6	93.7	90.1	79.2	68.0	58.7		
	10%	WB	52.8	53.7	55.8	57.3	60.2	63.4	65.5	65.1	63.6	59.6	55.5	52.1		
		MCDB	58.2	60.3	66.2	72.5	79.2	86.7	90.8	90.2	87.1	76.4	64.9	56.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	24.3	23.6	27.0	30.5	32.7	36.5	37.3	38.2	37.4	34.3	28.9	24.4		
		MCDBR	32.2	32.8	36.2	40.6	43.1	44.8	44.2	45.1	45.1	43.2	37.9	31.0		
		MCWBR	19.1	18.7	18.8	18.6	17.5	16.8	15.6	16.1	17.6	19.1	19.3	18.6		
	5% WB	MCDBR	22.6	26.1	31.9	36.4	39.3	40.7	40.0	41.3	39.8	37.2	30.5	19.8		
		MCWBR	14.8	15.8	17.4	17.9	16.9	16.8	15.2	16.0	16.3	17.2	16.7	13.7		
(40) Clear-Sky Solar Irradiance	taub		0.301	0.314	0.320	0.337	0.354	0.340	0.362	0.339	0.345	0.335	0.308	0.305		
	taud		2.554	2.524	2.509	2.457	2.418	2.464	2.430	2.474	2.461	2.491	2.540	2.552		
	Ebn at Noon		288	296	302	300	294	297	290	296	289	283	282	279		
	Edh at Noon		25	29	31	35	37	35	36	34	33	29	25	23		
(44) All-Sky Solar Radiation	RadAvg		895	1178	1641	2068	2408	2608	2478	2273	1924	1427	1031	797		
	RadStd		81	129	125	148	121	89	75	59	58	78	54	82		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	-3.67	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	+0.90	N/A	-1.75	+0.97	N/A	N/A	-266	+319	+76

Nomenclature: See separate page