

ATLANTIC CITY INTL, NJ, USA

WMO: 724070

Lat: 39.452N

Lon: 74.567W

Elev: 60

StdP: 14.66

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93730

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.6	16.0	-3.4	4.6	15.6	1.0	5.8	19.9	29.7	33.4	26.8	34.4	8.2	290	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	92.4	75.3	89.5	74.0	86.8	73.0	78.3	87.5	77.0	85.2	75.8	82.9	10.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.7	134.9	82.5	74.5	129.5	81.1	73.4	124.7	79.9	41.6	87.7	40.4	85.3	39.2	83.1	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.1	21.7	19.0	DB	5.0	97.4	4.9	2.8	1.4	99.4	-1.4	101.1	-4.2	102.7	-7.8	104.8
			WB	4.0	80.7	4.7	1.4	0.6	81.7	-2.2	82.5	-4.8	83.3	-8.3	84.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.1	33.7	35.8	42.3	52.5	61.7	71.2	76.5	74.8	68.2	57.2	46.6	38.9	(6)
	DBStd	16.95	10.46	9.45	9.11	8.43	7.95	6.75	5.39	5.43	6.48	8.10	8.56	9.16	(7)
	HDD50	1814	514	408	274	65	3	0	0	0	0	22	164	364	(8)
	HDD65	4734	970	819	705	386	162	22	0	1	40	267	552	810	(9)
	CDD50	3664	9	9	35	140	367	637	822	769	547	246	63	20	(10)
	CDD65	1107	0	0	1	11	61	209	357	305	136	26	1	0	(11)
	CDH74	9424	0	0	14	130	521	1741	3332	2629	920	134	3	0	(12)
	CDH80	3194	0	0	2	41	156	593	1294	874	213	21	0	0	(13)
(14) Wind	WSAvg	8.6	9.6	9.9	10.5	10.3	8.7	7.8	7.2	6.7	7.4	7.8	8.4	8.8	(14)
(15) Precipitation	PrecAvg	42.8	3.4	3.1	4.1	3.4	3.3	3.1	4.1	4.3	3.2	3.4	3.4	3.8	(15)
	PrecMax	68.6	7.1	6.4	9.3	7.6	7.5	8.3	12.6	16.1	8.5	9.1	10.6	10.0	(16)
	PrecMin	25.3	0.6	0.7	0.4	0.8	0.6	0.7	0.5	0.4	0.4	0.1	0.7	0.6	(17)
	PrecStd	7.9	1.4	1.5	1.9	1.5	1.7	1.9	2.2	3.0	1.8	1.9	2.1	1.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.9	67.3	75.1	85.8	89.3	94.1	97.1	95.0	90.3	82.6	72.2	67.3	(19)
		MCWB	56.1	55.5	59.7	65.5	70.5	75.4	77.4	77.3	73.4	70.3	62.1	60.6	(20)
	2%	DB	58.1	59.6	66.7	77.0	84.5	89.9	93.0	90.8	85.2	77.7	67.2	61.5	(21)
		MCWB	54.4	52.3	55.2	61.3	69.2	73.9	75.6	75.3	72.4	67.8	59.4	57.3	(22)
	5%	DB	54.2	54.7	61.0	71.0	80.0	86.5	90.0	87.7	82.0	73.9	63.9	57.5	(23)
		MCWB	50.8	48.3	52.0	59.0	66.8	72.4	74.8	74.0	70.8	66.0	58.5	54.4	(24)
	10%	DB	49.8	50.4	56.6	66.1	75.5	83.2	87.0	84.8	79.2	70.7	61.0	53.9	(25)
		MCWB	45.6	44.9	49.6	56.0	64.4	70.6	73.9	72.9	69.7	64.1	56.4	50.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.8	59.2	62.0	67.3	73.3	77.7	80.2	79.9	78.0	73.9	65.7	62.2	(27)
		MCDB	61.4	63.7	72.2	79.3	84.2	89.0	91.1	90.1	83.6	78.0	68.9	64.9	(28)
	2%	WB	55.3	54.2	57.4	64.0	71.1	76.0	78.5	78.1	75.6	71.0	62.5	58.4	(29)
		MCDB	57.4	57.7	63.0	72.9	81.2	86.0	88.5	86.7	80.5	75.2	65.3	60.8	(30)
	5%	WB	51.3	49.7	54.1	61.4	69.0	74.5	77.3	76.8	74.1	68.2	60.0	55.0	(31)
		MCDB	53.6	53.4	58.6	69.2	77.2	83.3	86.1	84.1	78.9	72.4	62.9	57.5	(32)
	10%	WB	46.4	45.5	50.8	58.4	66.6	73.0	76.1	75.4	72.3	65.4	57.1	50.8	(33)
		MCDB	49.0	50.2	55.7	64.4	73.5	80.4	83.7	81.5	77.0	69.5	60.2	53.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.4	17.8	18.4	19.6	18.9	18.2	17.6	17.7	18.6	19.2	18.7	16.9	(35)
		MCDBR	20.4	22.8	24.5	25.7	23.8	21.4	20.5	19.5	20.1	21.1	20.7	18.7	(36)
		MCWBR	17.3	16.9	15.7	13.6	11.4	9.3	7.8	7.8	9.8	12.4	14.8	16.7	(37)
	5% WB	MCDBR	19.6	21.2	21.3	22.1	20.4	18.9	17.2	15.9	15.6	16.6	16.4	17.5	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.316	0.320	0.355	0.387	0.433	0.491	0.499	0.492	0.412	0.362	0.331	0.315	(40)
		taud	2.491	2.479	2.420	2.353	2.257	2.135	2.126	2.135	2.334	2.477	2.518	2.534	(41)
		Ebn at Noon	272	287	286	282	270	253	250	248	263	267	264	264	(42)
	Edh at Noon		25	29	34	38	43	49	49	47	36	29	24	22	(43)
(44) All-Sky Solar Radiation	RadAvg		635	923	1237	1588	1764	1933	1964	1725	1413	1016	726	563	(44)
	RadStd		56	102	101	123	209	161	95	115	130	100	66	54	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (62 neighbors)	+1.28	N/A	N/A	N/A	N/A	N/A	N/A	-277	+371	+203
		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+223	+130

Nomenclature: See separate page