

ATLANTIC CITY INTL, NJ, USA

WMO: 724070

Lat: 39.452N

Lon: 74.567W

Elev: 18

StdP: 101.11

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93730

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.3	-8.9	-19.7	0.7	-9.1	-17.2	0.8	-6.7	13.3	0.8	12.0	1.3	3.7	290	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	33.5	24.1	31.9	23.3	30.5	22.8	25.7	30.9	25.0	29.6	24.3	28.3	4.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.3	19.3	28.0	23.6	18.5	27.3	23.0	17.8	26.6	79.0	31.0	76.0	29.6	73.2	28.4	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.2	9.7	8.5	-15.0	36.3	2.7	1.6	-17.0	37.5	-18.6	38.4	-20.1	39.3	-22.1	40.4		
			-15.6	27.0	2.6	0.8	-17.5	27.6	-19.0	28.1	-20.5	28.5	-22.4	29.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.8	0.9	2.1	5.7	11.4	16.5	21.8	24.7	23.8	20.1	14.0	8.1	3.8	(6)
(7)		DBStd	9.42	5.81	5.25	5.06	4.68	4.41	3.75	3.00	3.01	3.60	4.50	4.75	5.09	(7)
(8)		HDD10.0	1008	286	227	152	36	2	0	0	0	12	91	202		(8)
(9)		HDD18.3	2630	539	455	392	214	90	12	0	1	22	148	307	450	(9)
(10)		CDD10.0	2036	5	5	19	78	204	354	457	427	304	137	35	11	(10)
(11)		CDD18.3	615	0	0	1	6	34	116	198	169	76	14	1	0	(11)
(12)		CDH23.3	5236	0	0	8	72	289	967	1851	1461	511	74	2	0	(12)
(13)		CDH26.7	1774	0	0	1	23	87	329	719	486	118	12	0	0	(13)
(14)	Wind	WSAvg	3.8	4.3	4.4	4.7	4.6	3.9	3.5	3.2	3.0	3.3	3.5	3.7	3.9	(14)
(15)	Precipitation	PrecAvg	1087	86	79	105	86	85	80	104	82	86	87	96		(15)
(16)		PrecMax	1742	181	163	235	193	191	212	321	408	217	230	269	254	(16)
(17)		PrecMin	642	14	17	9	21	14	18	13	11	10	2	17	16	(17)
(18)		PrecStd	200	36	37	48	38	43	49	57	77	45	49	53	49	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.7	19.6	24.0	29.9	31.8	34.5	36.2	35.0	32.4	28.1	22.4	19.6	(19)
(20)			MCWB	13.4	13.0	15.4	18.6	21.4	24.1	25.2	25.1	23.0	21.3	16.7	15.9	(20)
(21)		2%	DB	14.5	15.3	19.3	25.0	29.2	32.1	33.9	32.7	29.6	25.4	19.6	16.4	(21)
(22)			MCWB	12.4	11.3	12.9	16.3	20.7	23.3	24.2	24.1	22.4	19.9	15.2	14.0	(22)
(23)		5%	DB	12.3	12.6	16.1	21.7	26.6	30.3	32.2	30.9	27.8	23.3	17.7	14.1	(23)
(24)			MCWB	10.4	9.0	11.1	15.0	19.3	22.4	23.8	23.3	21.5	18.9	14.7	12.4	(24)
(25)		10%	DB	9.9	10.2	13.7	19.0	24.2	28.4	30.6	29.3	26.2	21.5	16.1	12.2	(25)
(26)			MCWB	7.6	7.2	9.8	13.3	18.0	21.4	23.3	22.7	20.9	17.8	13.6	10.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.9	15.1	16.7	19.6	23.0	25.4	26.8	26.6	25.5	23.3	18.7	16.8	(27)
(28)			MCDWB	16.3	17.6	22.3	26.3	29.0	31.7	32.8	32.3	28.7	25.5	20.5	18.3	(28)
(29)		2%	WB	13.0	12.3	14.1	17.8	21.7	24.4	25.8	25.6	24.2	21.7	17.0	14.7	(29)
(30)			MCDWB	14.1	14.3	17.2	22.7	27.4	30.0	31.4	30.4	26.9	24.0	18.5	16.0	(30)
(31)		5%	WB	10.7	9.9	12.3	16.3	20.6	23.6	25.2	24.9	23.4	20.1	15.5	12.8	(31)
(32)			MCDWB	12.0	11.9	14.8	20.7	25.1	28.5	30.0	28.9	26.1	22.4	17.1	14.2	(32)
(33)		10%	WB	8.0	7.5	10.5	14.6	19.2	22.8	24.5	24.1	22.4	18.6	13.9	10.5	(33)
(34)			MCDWB	9.4	10.1	13.2	18.0	23.0	26.9	28.7	27.5	25.0	20.8	15.7	11.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.1	9.9	10.2	10.9	10.5	10.1	9.8	9.8	10.3	10.7	10.4	9.4	(35)
(36)			MCDBR	11.3	12.7	13.6	14.3	13.2	11.9	11.4	10.9	11.2	11.7	11.5	10.4	(36)
(37)			MCWBR	9.6	9.4	8.7	7.5	6.3	5.2	4.3	4.3	5.5	6.9	8.2	9.3	(37)
(38)		5% WB	MCDWR	10.9	11.8	11.8	12.3	11.3	10.5	9.5	8.8	8.6	9.2	9.1	9.7	(38)
(39)			MCWBR	10.2	10.1	9.1	7.4	6.1	5.0	4.2	3.9	4.8	6.5	7.9	9.4	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.316	0.320	0.355	0.387	0.433	0.491	0.499	0.492	0.412	0.362	0.331	0.315	(40)
(41)		taud		2.491	2.479	2.420	2.353	2.257	2.135	2.126	2.135	2.334	2.477	2.518	2.534	(41)
(42)		Ebn at Noon		856	904	901	888	850	799	788	782	830	843	831	831	(42)
(43)		Edh at Noon		78	90	106	121	136	153	154	148	114	90	76	70	(43)
(44)	All-Sky Solar Radiation	RadAvg		2.00	2.91	3.90	5.01	5.56	6.09	6.19	5.44	4.45	3.20	2.29	1.77	(44)
(45)		RadStd		0.17	0.32	0.32	0.39	0.66	0.51	0.30	0.36	0.41	0.31	0.21	0.17	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.71	N/A	N/A	N/A	N/A	N/A	N/A	-154	+206	+113
(47)	Regional (62 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+124	+72

Nomenclature: See separate page