

LEXINGTON BLUE GRASS, KY, USA

WMO: 724220

Lat: 38.041N

Lon: 84.606W

Elev: 299

StdP: 97.79

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93820

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.5	-10.4	-18.7	0.7	-11.5	-16.1	1.0	-9.1	11.3	10.5	10.2	7.9	2.9	310	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	33.1	23.2	31.9	23.0	30.7	22.6	25.2	30.7	24.5	29.6	23.8	28.6	3.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.9	28.2	22.8	18.2	27.3	22.3	17.6	26.6	78.0	30.8	75.3	29.8	72.6	28.7	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.4	-17.6	35.1	3.8	1.9	-20.3	36.5	-22.5	37.6	-24.6	38.7	-27.4	40.1		
(5)			-18.0	26.3	3.7	0.7	-20.7	26.8	-22.8	27.2	-24.9	27.7	-27.6	28.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	0.6	2.9	7.5	13.5	18.4	22.9	24.5	24.2	20.7	14.3	7.8	3.1	(6)
(7)		DBStd	9.80	6.94	6.50	6.10	5.17	4.35	3.04	2.48	2.60	3.95	4.96	5.34	5.90	(7)
(8)		HDD10.0	1005	301	212	122	25	2	0	0	0	0	16	104	224	(8)
(9)		HDD18.3	2491	549	432	338	158	55	4	0	1	22	143	317	471	(9)
(10)		CDD10.0	2254	9	13	44	128	263	386	451	440	321	149	38	12	(10)
(11)		CDD18.3	701	0	0	2	12	58	141	193	183	93	18	1	0	(11)
(12)		CDH23.3	5867	0	1	12	89	430	1153	1677	1567	793	142	3	0	(12)
(13)		CDH26.7	2019	0	0	0	8	98	386	630	584	283	29	0	0	(13)
(14)	Wind	WSAvg	3.5	4.2	4.1	4.1	4.1	3.4	3.0	2.6	2.6	2.8	3.2	3.7	3.9	(14)
(15)	Precipitation	PrecAvg	1193	79	85	112	104	126	112	128	98	86	76	85	103	(15)
(16)		PrecMax	1832	162	258	351	323	277	297	261	284	265	187	195	258	(16)
(17)		PrecMin	810	9	17	25	29	30	16	32	4	9	8	11	16	(17)
(18)		PrecStd	229	38	50	60	58	61	58	50	54	58	48	40	51	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.7	21.3	25.0	27.9	30.8	33.3	34.7	34.8	34.2	29.5	23.3	19.3	(19)
(20)			MCWB	15.0	15.6	16.9	18.2	21.5	23.1	24.6	23.4	21.5	20.4	17.1	15.2	(20)
(21)		2%	DB	16.3	18.0	22.0	26.0	29.1	31.7	32.9	32.8	31.9	26.9	20.5	16.6	(21)
(22)			MCWB	13.8	13.0	15.0	17.6	20.6	23.0	24.0	23.2	21.4	19.1	15.0	13.9	(22)
(23)		5%	DB	14.1	15.5	19.4	23.9	27.7	30.5	31.6	31.4	30.0	24.6	18.3	14.4	(23)
(24)			MCWB	12.0	11.7	13.6	16.6	20.3	22.4	23.5	23.0	21.1	17.9	14.1	12.1	(24)
(25)		10%	DB	11.3	13.0	17.0	21.9	26.0	29.1	30.2	30.0	27.9	22.4	16.3	12.2	(25)
(26)			MCWB	8.7	9.4	12.2	15.5	19.7	22.0	23.0	22.6	20.2	17.2	12.4	10.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.0	16.7	17.9	20.5	23.1	25.3	26.3	25.8	24.1	22.6	18.4	16.5	(27)
(28)			MCDWB	17.7	20.1	23.3	25.8	28.0	30.6	31.7	31.4	30.0	27.3	21.8	18.6	(28)
(29)		2%	WB	14.3	14.5	16.2	18.9	22.0	24.4	25.4	24.9	23.1	20.8	16.8	14.3	(29)
(30)			MCDWB	16.0	17.0	20.5	23.8	27.4	29.5	31.0	30.3	28.6	24.4	19.6	15.8	(30)
(31)		5%	WB	12.3	12.3	14.7	17.6	21.2	23.7	24.7	24.1	22.3	19.3	14.9	12.5	(31)
(32)			MCDWB	14.0	14.8	18.3	22.1	26.0	28.7	29.8	29.3	27.3	23.0	17.4	14.1	(32)
(33)		10%	WB	9.0	9.7	12.9	16.4	20.3	22.9	23.9	23.5	21.5	17.9	13.0	10.1	(33)
(34)			MCDWB	11.0	12.7	16.6	20.7	24.6	27.7	28.5	28.1	26.0	21.5	15.7	12.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	9.2	10.3	11.2	10.3	10.0	10.5	11.1	10.8	9.7	8.1	(35)	
(36)			MCDBR	10.0	12.2	12.4	12.9	11.6	11.7	11.5	11.9	13.4	12.7	11.6	10.1	(36)
(37)			MCWBR	8.0	9.3	7.7	7.4	5.6	5.1	4.6	4.6	5.3	6.4	7.9	8.4	(37)
(38)		5% WB	MCDWB	9.2	11.4	10.7	10.7	10.0	10.2	10.0	9.7	10.5	10.4	10.0	9.4	(38)
(39)			MCWBR	7.9	9.7	7.3	7.1	5.5	5.0	4.7	4.4	4.9	6.3	8.0	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.307	0.320	0.349	0.390	0.436	0.447	0.472	0.466	0.408	0.353	0.320	0.299	(40)	
(41)		taud	2.464	2.408	2.388	2.273	2.189	2.196	2.139	2.144	2.278	2.428	2.476	2.492	(41)	
(42)		Ebn at Noon	877	908	911	888	850	837	813	807	837	859	853	861	(42)	
(43)		Edh at Noon	81	98	110	131	146	145	152	148	122	95	80	74	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.92	2.60	3.70	4.94	5.53	6.18	5.83	5.48	4.53	3.38	2.34	1.66	(44)	
(45)		RadStd	0.21	0.37	0.34	0.36	0.52	0.32	0.32	0.31	0.48	0.39	0.26	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+151	+92
(47) Regional (23 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+121	+75

Nomenclature: See separate page