

HUNTINGTON TRI-STATE, WV, USA

WMO: 724250

Lat: 38.365N

Lon: 82.555W

Elev: 824

StdP: 14.26

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03860

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.4	14.7	-1.4	5.3	14.2	3.4	6.7	17.6	19.6	41.6	18.0	41.1	5.4	250	0.413

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	91.4	74.0	89.1	73.3	86.9	72.4	77.3	86.6	76.0	84.6	74.7	82.9	6.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.7	133.7	81.7	73.3	127.5	80.3	72.1	122.6	79.0	41.2	86.7	39.9	85.1	38.6	82.8	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.8	14.5	12.4	DB	2.5	94.5	7.7	3.3	-3.1	96.9	-7.5	98.8	-11.8	100.6	-17.4	103.0	
			WB	1.9	79.8	7.6	1.8	-3.5	81.0	-8.0	82.1	-12.2	83.1	-17.7	84.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.2	34.2	38.0	46.0	57.1	64.9	72.6	75.6	74.7	68.4	57.1	46.3	38.4
	DBStd	17.01	12.35	11.31	11.07	9.32	7.59	5.35	4.47	4.61	6.69	8.62	9.44	9.99
	HDD50	1715	513	361	211	37	2	0	0	0	0	30	179	382
	HDD65	4383	956	758	595	266	101	8	0	1	41	270	562	825
	CDD50	3977	22	23	87	251	463	679	792	766	552	251	69	22
	CDD65	1171	0	0	6	30	97	237	328	302	143	26	2	0
	CDH74	9930	2	3	58	340	855	1967	2740	2479	1217	254	15	0
	CDH80	3371	0	0	7	65	228	663	1022	907	425	53	1	0
Wind	WSAvg	5.4	6.7	6.6	6.7	6.6	5.2	4.7	4.2	3.8	4.0	4.7	5.4	5.9
Precipitation	PrecAvg	43.3	3.0	3.1	3.9	3.7	4.5	3.8	4.9	3.9	3.1	2.8	3.2	3.4
	PrecMax	70.8	6.4	8.7	8.9	10.0	15.4	7.6	8.6	7.4	10.4	6.4	7.8	8.7
	PrecMin	30.0	0.6	0.6	1.1	0.7	0.9	0.4	1.4	0.7	0.1	0.0	0.6	0.3
	PrecStd	7.8	1.3	1.7	1.9	1.8	2.6	1.7	2.0	1.7	2.1	1.5	1.7	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.4	72.1	80.2	85.3	88.3	93.0	94.3	94.5	92.8	85.1	75.9	68.5
		MCWB	58.8	58.4	61.5	64.1	70.9	72.7	75.6	74.0	71.0	68.4	61.7	58.9
	2%	DB	63.3	65.7	74.5	81.8	85.3	89.1	90.8	90.7	88.7	80.4	70.9	63.3
		MCWB	55.7	54.1	58.1	62.1	69.0	73.6	75.2	74.1	70.7	65.9	58.3	55.7
	5%	DB	58.6	60.3	69.4	78.2	82.7	86.6	88.4	88.1	85.1	76.3	66.4	59.0
		MCWB	53.2	51.2	55.5	60.4	68.1	72.4	74.2	73.4	69.6	63.2	56.3	52.9
	10%	DB	53.2	55.8	64.0	74.1	79.4	84.0	85.9	85.3	81.3	72.0	62.2	54.8
		MCWB	47.5	49.1	53.1	58.9	66.8	71.2	73.4	72.3	68.2	62.0	53.7	49.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.2	60.9	63.1	67.8	74.0	78.0	79.5	78.9	75.6	71.9	64.3	60.6
		MCDB	66.4	69.2	77.1	80.6	83.9	86.7	88.1	87.7	85.5	80.6	72.7	66.3
	2%	WB	57.3	57.0	60.4	65.1	71.7	75.5	77.5	77.2	73.6	68.8	61.1	57.8
		MCDB	62.0	62.7	70.6	76.0	81.0	84.5	86.9	86.4	82.5	76.2	67.9	62.2
	5%	WB	53.7	53.5	58.2	62.9	70.0	74.3	76.3	75.5	71.9	66.1	58.1	54.2
		MCDB	58.2	58.6	66.5	73.0	78.9	83.3	84.9	83.8	79.8	73.4	64.1	58.0
	10%	WB	48.1	48.8	54.9	60.9	68.3	72.9	74.9	74.2	70.3	63.4	54.8	50.0
		MCDB	52.8	55.5	62.4	70.3	76.6	81.4	82.7	81.8	77.5	69.9	61.3	54.4
Mean Daily Temperature Range	5% DB	MDBR	15.8	17.1	19.5	22.0	20.5	19.4	18.5	19.3	20.7	21.0	19.0	15.4
		MCDBR	20.1	25.0	26.4	27.5	24.4	22.7	21.7	22.6	25.2	26.2	24.8	21.4
		MCWBR	14.4	17.1	14.3	13.3	10.8	9.2	8.5	8.9	9.8	12.6	15.1	15.8
	5% WB	MCDBR	18.4	21.8	21.5	21.8	20.5	19.3	18.6	18.5	19.8	20.9	19.7	18.7
		MCWBR	14.0	17.6	13.5	12.3	10.2	9.2	8.5	8.4	8.9	11.5	14.4	15.4
Clear-Sky Solar Irradiance	taub	0.308	0.324	0.347	0.400	0.447	0.470	0.495	0.494	0.411	0.360	0.331	0.301	
	taud	2.495	2.435	2.426	2.280	2.161	2.144	2.091	2.074	2.291	2.437	2.490	2.533	
	Ebn at Noon	278	287	290	279	266	259	251	248	265	270	266	272	
	Edh at Noon	25	30	34	41	48	48	50	50	38	30	25	23	
All-Sky Solar Radiation	RadAvg	587	804	1159	1550	1746	1931	1817	1707	1422	1036	729	512	
	RadStd	57	115	101	124	155	98	95	101	140	121	90	57	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (28 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+214	+117	

Nomenclature: See separate page