

HUNTINGTON TRI-STATE, WV, USA

WMO: 724250

Lat: 38.365N

Lon: 82.555W

Elev: 251

StdP: 98.34

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03860

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.6	-9.6	-18.6	0.8	-9.9	-15.9	1.0	-8.0	8.8	5.3	8.0	5.0	2.4	250	0.413

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	33.0	23.3	31.7	23.0	30.5	22.4	25.2	30.3	24.4	29.2	23.7	28.3	2.9	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.7	19.1	27.6	22.9	18.2	26.8	22.3	17.5	26.1	78.0	30.4	74.9	29.5	71.9	28.2	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.5	5.5	DB	-16.4	34.7	4.3	1.8	-19.5	36.0	-22.0	37.1	-24.4	38.1	-27.5	39.4	(4)
(5)			WB	-16.7	26.5	4.2	1.0	-19.7	27.2	-22.2	27.8	-24.6	28.4	-27.6	29.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	1.2	3.3	7.8	14.0	18.3	22.6	24.2	23.7	20.2	14.0	8.0	3.6	(6)	
	DBStd	9.45	6.86	6.28	6.15	5.18	4.22	2.97	2.48	2.56	3.72	4.79	5.25	5.55	(7)	
	HDD10.0	953	285	201	117	21	1	0	0	0	17	99	212		(8)	
	HDD18.3	2435	531	421	331	148	56	4	0	1	23	150	312	458	(9)	
	CDD10.0	2209	12	13	48	139	257	377	440	426	307	139	38	12	(10)	
	CDD18.3	651	0	0	3	17	54	132	182	168	79	14	1	0	(11)	
	CDH23.3	5517	1	2	32	189	475	1093	1522	1377	676	141	8	0	(12)	
	CDH26.7	1873	0	0	4	36	127	368	568	504	236	29	1	0	(13)	
(14) Wind	WSAvg	2.4	3.0	2.9	3.0	2.9	2.3	2.1	1.9	1.7	1.8	2.1	2.4	2.6	(14)	
(15) Precipitation	PrecAvg	1099	75	78	100	93	114	97	124	99	80	72	82	87	(15)	
	PrecMax	1798	162	220	226	253	391	194	218	187	264	162	198	221	(16)	
	PrecMin	762	16	14	28	19	24	10	35	17	3	0	16	8	(17)	
	PrecStd	197	34	43	49	46	67	44	50	44	53	37	42	40	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.8	22.3	26.8	29.6	31.3	33.9	34.6	34.7	33.8	29.5	24.4	20.3	(19)	
		MCWB	14.9	14.7	16.4	17.9	21.6	22.6	24.2	23.3	21.6	20.2	16.5	15.0	(20)	
	2%	DB	17.4	18.7	23.6	27.7	29.6	31.7	32.7	32.6	31.5	26.9	21.6	17.4	(21)	
		MCWB	13.2	12.3	14.5	16.7	20.6	23.1	24.0	23.4	21.5	18.8	14.6	13.2	(22)	
	5%	DB	14.8	15.7	20.8	25.6	28.1	30.3	31.4	31.2	29.5	24.6	19.1	15.0	(23)	
		MCWB	11.8	10.7	13.1	15.8	20.1	22.5	23.5	23.0	20.9	17.3	13.5	11.6	(24)	
	10%	DB	11.8	13.2	17.8	23.4	26.3	28.9	30.0	29.6	27.4	22.2	16.8	12.7	(25)	
		MCWB	8.6	9.5	11.7	15.0	19.3	21.8	23.0	22.4	20.1	16.6	12.0	9.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.2	16.0	17.3	19.9	23.3	25.6	26.4	26.0	24.2	22.2	17.9	15.9	(27)	
		MCDB	19.1	20.7	25.1	27.0	28.8	30.4	31.1	30.9	29.7	27.0	22.6	19.1	(28)	
	2%	WB	14.0	13.9	15.8	18.4	22.1	24.1	25.3	25.1	23.1	20.5	16.1	14.3	(29)	
		MCDB	16.6	17.1	21.4	24.4	27.2	29.2	30.5	30.2	28.0	24.5	19.9	16.8	(30)	
	5%	WB	12.0	11.9	14.5	17.2	21.1	23.5	24.6	24.2	22.2	19.0	14.5	12.3	(31)	
		MCDB	14.5	14.8	19.2	22.8	26.1	28.5	29.4	28.8	26.5	23.0	17.8	14.4	(32)	
	10%	WB	9.0	9.3	12.7	16.1	20.2	22.7	23.8	23.5	21.3	17.4	12.7	10.0	(33)	
		MCDB	11.5	13.1	16.9	21.3	24.8	27.5	28.2	27.7	25.3	21.0	16.3	12.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	9.5	10.8	12.2	11.4	10.8	10.3	10.7	11.5	11.7	10.5	8.6	(35)	
		MCDBR	11.2	13.9	14.7	15.3	13.6	12.6	12.1	12.6	14.0	14.6	13.8	11.9	(36)	
	5% WB	MCWBR	8.0	9.5	7.9	7.4	6.0	5.1	4.7	4.9	5.4	7.0	8.4	8.8	(37)	
		MCWBR	10.2	12.1	11.9	12.1	11.4	10.7	10.3	10.3	11.0	11.6	11.0	10.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.308	0.324	0.347	0.400	0.447	0.470	0.495	0.494	0.411	0.360	0.331	0.301	(40)	
		taud	2.495	2.435	2.426	2.280	2.161	2.144	2.091	2.074	2.291	2.437	2.490	2.533	(41)	
	Ebn at Noon		875	904	914	878	839	817	792	782	834	850	839	859	(42)	
		Edh at Noon	79	95	106	130	150	152	159	158	120	94	79	71	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.85	2.53	3.65	4.88	5.50	6.09	5.73	5.38	4.48	3.27	2.30	1.61	(44)	
	RadStd		0.18	0.36	0.32	0.39	0.49	0.31	0.30	0.32	0.44	0.38	0.28	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+96	N/A
(47) Regional (28 neighbors)		+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+119	+65

Nomenclature: See separate page