

HUNTINGBURG, IN, USA

WMO: 724365

Lat: 38.249N

Lon: 86.954W

Elev: 529

StdP: 14.42

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 53896

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.3	12.2	-1.3	5.2	10.5	3.0	6.5	14.2	26.1	40.9	23.7	41.1	6.6	290	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	92.4	76.0	90.4	75.6	88.3	74.8	79.3	88.7	77.8	87.0	76.4	85.1	8.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.7	142.0	85.1	75.0	133.9	83.2	73.3	126.3	81.0	43.1	89.0	41.6	86.5	40.1	85.5	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.8	(b) 19.0	(c) 16.9	(e) -1.3	(f) 95.0	(g) 5.8	(h) 2.3	(i) -5.5	(j) 96.6	(k) -8.8	(l) 97.9	(m) -12.1	(n) 99.2	(o) -16.3	(p) 100.9		
(4) 21.8	(5) 19.0	(6) 16.9	(7) -1.3	(8) 95.0	(9) 5.8	(10) 2.3	(11) -5.5	(12) 96.6	(13) -8.8	(14) 97.9	(15) -12.1	(16) 99.2	(17) -16.3	(18) 100.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.1	32.8	36.6	45.4	56.2	65.5	73.6	76.6	75.5	68.9	57.7	45.8	37.4
	DBStd	17.79	12.11	11.55	10.93	9.03	7.77	5.72	4.86	4.82	7.10	8.90	9.82	10.33
	HDD50	1834	549	394	221	41	2	0	0	0	27	193	407	
	HDD65	4524	999	794	612	284	93	7	0	1	40	262	577	855
	CDD50	4068	15	20	78	229	482	707	825	792	569	265	68	18
	CDD65	1282	0	0	5	21	108	264	360	328	159	35	2	0
	CDH74	11469	0	0	27	158	818	2355	3359	2944	1511	288	9	0
	CDH80	4212	0	0	2	13	200	876	1358	1130	571	62	0	0
(14) Wind	WSAvg	7.4	9.0	8.9	8.9	8.9	7.3	6.3	5.4	5.0	5.6	7.0	8.1	8.2
(15) Precipitation	PrecAvg	49.6	4.1	3.3	4.5	5.0	5.8	4.6	4.0	3.0	3.8	3.7	4.0	4.4
	PrecMax	61.7	6.7	6.3	10.8	10.4	11.9	7.3	6.9	6.4	10.2	7.5	6.8	8.5
	PrecMin	37.7	1.4	1.4	2.3	2.1	1.6	2.3	1.5	0.5	0.3	0.9	1.4	2.2
	PrecStd	6.8	1.5	1.4	2.2	1.9	2.9	1.5	1.5	1.7	2.7	1.9	1.5	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.4	69.6	78.8	81.8	88.0	93.0	97.2	95.1	93.3	85.7	74.8	66.3
		MCWB	59.2	60.5	64.1	66.1	72.8	74.7	78.4	77.5	72.8	72.0	62.9	60.7
	2%	DB	61.0	63.7	72.3	79.1	84.3	90.5	91.5	91.2	90.3	81.3	69.8	61.6
		MCWB	56.9	55.9	60.0	64.6	70.9	74.2	77.8	76.2	72.7	66.9	60.5	56.8
	5%	DB	56.4	59.4	66.5	75.0	82.0	88.3	90.1	89.7	86.4	76.9	64.8	56.7
		MCWB	52.9	53.3	57.0	62.5	69.4	73.7	77.6	75.8	71.2	64.4	57.8	52.1
	10%	DB	51.9	54.4	63.1	72.0	79.2	85.3	87.9	86.4	82.2	72.7	61.4	53.7
		MCWB	47.6	48.2	54.6	60.9	67.6	72.7	76.2	74.4	68.7	62.6	54.5	49.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.9	62.1	65.4	69.3	75.3	78.4	82.2	80.7	76.8	73.6	65.8	62.1
		MCDB	63.3	67.7	76.0	79.4	84.2	88.0	91.1	90.8	88.5	84.0	71.6	65.6
	2%	WB	57.6	58.4	62.1	66.6	73.0	76.7	80.2	78.6	74.9	70.1	62.3	58.0
		MCDB	60.8	62.6	69.7	75.3	81.8	86.4	88.9	88.3	86.0	77.0	67.4	61.6
	5%	WB	53.6	54.0	58.9	64.5	71.2	75.4	78.5	77.3	73.0	66.9	59.1	53.2
		MCDB	56.1	58.5	65.6	72.3	79.8	84.9	87.4	86.3	82.5	73.8	64.5	55.9
	10%	WB	47.3	48.3	55.3	62.2	69.1	74.0	77.2	75.8	71.1	64.2	55.3	48.8
		MCDB	50.5	53.8	62.2	69.7	77.0	82.8	85.7	83.7	78.9	70.7	60.5	52.7
(35) Mean Daily Temperature Range	5% DB	MDBR	15.1	16.4	18.3	20.4	18.8	19.2	18.6	19.8	22.0	20.8	17.4	14.3
		MCDBR	18.3	21.7	23.1	23.4	21.1	21.9	21.1	22.3	25.8	24.2	21.4	18.2
	5% WB	MCWBR	16.2	17.1	15.0	14.1	11.1	9.6	9.4	10.0	11.3	12.9	15.1	15.5
		MCWBR	17.3	20.1	20.0	19.1	18.2	18.6	18.4	19.0	21.6	19.5	18.7	16.8
(40) Clear-Sky Solar Irradiance	taub	0.312	0.324	0.360	0.406	0.437	0.451	0.470	0.477	0.417	0.359	0.327	0.308	
		taud	2.467	2.407	2.376	2.248	2.207	2.194	2.149	2.120	2.275	2.440	2.476	2.483
	Ebn at Noon	276	286	285	277	269	265	258	253	263	270	267	269	
		Edn at Noon	26	31	36	43	45	46	48	48	39	30	25	24
(44) All-Sky Solar Radiation	RadAvg	614	840	1179	1558	1739	2000	1914	1771	1463	1075	731	523	
	RadStd	66	101	110	96	156	125	121	102	117	115	80	50	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+203	+140

Nomenclature: See separate page