

TERRE HAUTE, IN, USA

WMO: 724373

Lat: 39.452N

Lon: 87.309W

Elev: 575

StdP: 14.39

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03868

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.4	(c) 7.7	(d) -6.6	(e) 3.9	(f) 3.5	(g) -1.3	(h) 5.2	(i) 9.0	(j) 24.4	(k) 32.9	(l) 22.3	(m) 29.9	(n) 6.4	(o) 310	(p) 0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	92.1	75.8	90.0	75.4	87.7	74.0	79.0	88.4	77.5	86.6	76.0	84.4	8.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.1	139.1	84.8	74.7	132.6	83.1	73.1	125.7	81.0	42.8	88.7	41.2	86.3	39.7	84.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	18.8	17.0	-6.2	95.3	7.3	3.5	-11.4	97.9	-15.7	99.9	-19.8	101.9	-25.1	104.5
			-6.8	81.7	7.1	2.1	-11.9	83.2	-16.1	84.4	-20.1	85.5	-25.3	87.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.9	28.8	33.0	42.9	54.3	64.3	73.0	75.4	73.9	67.2	55.7	43.5	33.6		
	DBStd	18.71	12.33	11.56	10.87	9.02	8.18	6.09	5.46	5.05	7.13	8.93	9.55	10.82		
	HDD50	2284	664	485	277	56	3	0	0	0	0	42	241	516		
	HDD65	5165	1122	896	689	336	117	10	1	3	58	314	647	972		
	CDD50	3711	7	9	56	185	446	690	789	740	517	218	45	9		
	CDD65	1114	0	0	3	15	95	250	325	278	124	24	0	0		
	CDH74	10438	0	0	23	135	855	2295	3145	2540	1218	224	3	0		
	CDH80	3741	0	0	2	12	234	859	1253	911	420	50	0	0		
(14) Wind	WSAvg	7.3	9.0	8.9	9.0	9.1	7.5	6.4	5.3	4.8	5.2	6.8	8.1	8.1		
(15) Precipitation	PrecAvg	39.8	2.1	2.2	3.6	3.9	4.3	3.6	4.7	3.5	3.3	2.3	3.4	2.9		
	PrecMax	54.8	5.9	5.5	7.1	7.0	11.8	7.7	10.9	10.0	7.8	4.6	11.6	8.1		
	PrecMin	26.5	0.3	0.4	0.9	0.7	1.4	0.3	0.7	0.6	0.2	0.4	0.5	0.4		
	PrecStd	7.6	1.5	1.3	1.8	1.7	2.6	1.7	2.6	2.5	2.0	1.0	2.3	1.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.7	66.6	77.6	81.6	89.1	94.1	97.7	93.5	92.3	85.5	72.8	64.2		
		MCWB	58.4	58.1	62.5	65.9	71.6	74.6	78.0	76.7	72.9	69.9	61.4	59.1		
	2%	DB	57.3	61.0	71.5	78.4	85.3	90.7	92.6	90.5	88.4	80.2	67.2	59.0		
		MCWB	53.9	54.4	59.7	63.6	69.8	74.3	77.4	76.5	72.8	66.3	59.3	54.8		
	5%	DB	52.3	55.4	65.8	74.1	82.4	88.3	89.9	88.0	85.0	75.3	63.3	54.2		
		MCWB	49.4	50.0	56.5	61.5	68.5	73.4	76.7	75.0	71.0	63.8	56.9	50.8		
	10%	DB	46.1	50.3	61.1	70.3	79.2	85.3	86.8	85.2	81.4	71.7	59.2	48.9		
		MCWB	42.4	45.0	53.0	59.4	67.1	71.5	74.6	73.4	68.6	62.3	52.8	44.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.0	60.7	64.6	69.0	74.8	78.7	81.5	80.5	76.8	72.2	64.8	60.1		
		MCDB	62.0	65.2	76.1	78.9	83.9	89.4	90.7	89.3	87.0	81.8	69.4	63.9		
	2%	WB	54.8	55.8	61.0	66.0	72.5	77.0	79.8	78.4	74.9	69.1	61.2	55.4		
		MCDB	57.4	59.6	68.8	74.0	82.2	87.5	89.3	87.3	84.9	76.1	65.2	57.9		
	5%	WB	50.0	50.7	58.2	63.6	70.6	75.3	78.0	76.8	72.8	66.3	57.8	51.1		
		MCDB	51.9	55.2	64.6	70.9	79.6	84.8	86.9	85.2	81.4	73.1	62.8	53.9		
	10%	WB	42.7	45.0	54.1	61.2	68.7	73.8	76.4	75.2	70.9	63.2	53.6	45.7		
		MCDB	45.8	49.9	60.3	68.6	76.5	82.5	84.6	82.5	78.4	69.5	58.2	48.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.3	16.6	18.8	21.1	20.2	19.5	19.7	20.8	23.3	21.7	18.0	14.5		
		MCDBR	19.2	23.4	24.6	25.1	23.5	22.5	22.0	22.6	26.5	26.0	22.7	19.5		
		MCWBR	16.9	18.4	15.7	14.4	11.4	9.6	9.8	10.5	12.1	14.1	16.5	16.9		
	5% WB	MCDBR	18.5	21.7	21.5	20.5	20.1	19.0	19.4	19.5	22.0	21.2	20.2	18.0		
		MCWBR	17.5	18.7	15.0	13.6	11.1	9.2	10.0	10.1	11.2	12.7	16.5	16.6		
(40) Clear-Sky Solar Irradiance	taub		0.305	0.319	0.355	0.407	0.438	0.447	0.464	0.473	0.430	0.362	0.321	0.301		
	taud		2.450	2.396	2.368	2.227	2.191	2.202	2.151	2.114	2.217	2.412	2.475	2.479		
	Ebn at Noon		275	286	285	276	268	265	259	253	257	266	266	268		
	Edh at Noon		25	31	35	43	46	45	48	48	41	30	25	23		
(44) All-Sky Solar Radiation	RadAvg		568	831	1166	1511	1724	1976	1918	1752	1461	1030	688	484		
	RadStd		65	93	99	105	155	118	117	109	106	103	73	55		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+189	N/A

Nomenclature: See separate page