

KANSAS CITY WHEELER, MO, USA

WMO: 724463

Lat: 39.121N

Lon: 94.597W

Elev: 742

StdP: 14.31

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13988

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.8	10.1	-5.2	4.3	9.2	-1.2	5.3	12.4	24.1	43.9	21.0	39.4	7.6	320	0.509

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.8	97.2	76.4	94.0	76.0	91.4	75.4	79.6	92.1	78.2	90.2	77.1	88.5	10.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.8	138.7	87.0	74.7	133.7	86.1	73.2	126.9	84.6	43.7	92.3	42.3	90.2	40.9	88.4	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.8	19.2	17.7	-0.1	101.4	5.3	3.3	-4.0	103.8	-7.1	105.7	-10.1	107.6	-14.0	109.9		
			-1.3	81.5	5.0	1.7	-4.9	82.7	-7.8	83.7	-10.6	84.6	-14.2	85.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	57.4	31.6	36.0	46.6	57.1	67.0	76.4	80.9	79.4	71.4	58.9	46.4	35.5	(6)
(7)		DBStd	19.48	11.65	11.95	11.54	9.45	8.05	6.10	5.76	5.88	7.79	9.29	9.97	10.63	(7)
(8)		HDD50	1898	576	413	201	39	2	0	0	0	26	180	461		(8)
(9)		HDD65	4510	1035	812	577	269	77	4	0	1	27	233	560	915	(9)
(10)		CDD50	4591	6	21	96	251	527	792	958	911	642	303	73	11	(10)
(11)		CDD65	1726	0	0	6	31	137	346	493	447	219	45	2	0	(11)
(12)		CDH74	18080	0	3	52	252	1149	3535	5849	4849	2029	351	11	0	(12)
(13)		CDH80	7784	0	0	5	44	324	1444	2852	2266	763	86	0	0	(13)
(14)	Wind	WSAvg	8.3	8.4	8.7	9.4	9.9	8.5	8.5	7.7	7.3	7.3	7.8	8.3	8.0	(14)
(15)	Precipitation	PrecAvg	40.2	1.2	1.8	2.4	4.0	5.5	6.0	4.5	4.1	4.3	3.3	2.1	1.6	(15)
(16)		PrecMax	52.0	3.1	4.4	5.0	7.4	11.3	11.1	12.5	10.0	10.0	7.6	6.8	4.1	(16)
(17)		PrecMin	28.1	0.2	0.0	0.8	0.7	1.5	1.9	0.2	1.1	0.7	0.6	0.1	0.0	(17)
(18)		PrecStd	6.8	0.7	1.1	1.2	1.6	2.8	2.5	3.0	2.4	2.6	1.8	1.6	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.6	72.3	79.5	84.7	90.3	96.4	101.5	101.1	95.5	87.1	75.2	66.4	(19)
(20)		MCWB	54.5	55.4	62.3	65.7	72.9	75.6	76.0	75.2	74.3	71.5	61.6	58.7		(20)
(21)		2%	DB	59.7	65.4	74.5	80.4	86.6	92.8	97.7	96.8	90.9	82.0	70.9	61.1	(21)
(22)		MCWB	49.8	54.2	60.0	63.9	70.7	75.6	76.9	76.0	74.0	67.5	58.9	53.5		(22)
(23)		5%	DB	53.8	59.9	70.2	76.7	83.7	90.5	94.7	93.4	87.9	77.7	66.1	55.6	(23)
(24)		MCWB	45.2	49.7	57.5	61.8	69.3	74.9	76.8	75.5	72.9	65.1	56.0	47.3		(24)
(25)		10%	DB	47.9	54.4	65.3	73.0	80.8	88.0	91.6	90.6	84.2	73.5	62.1	51.2	(25)
(26)		MCWB	41.1	45.9	54.4	60.4	68.2	73.9	76.0	75.0	71.1	63.4	53.8	44.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.9	60.2	65.7	69.4	76.1	79.6	81.8	80.8	78.0	73.3	65.1	60.8	(27)
(28)		MADB	63.3	67.6	76.0	80.0	86.3	91.1	93.5	92.9	89.2	83.4	71.3	65.5		(28)
(29)		2%	WB	50.2	55.0	62.4	67.0	73.5	78.0	80.1	79.0	75.8	70.9	60.8	54.7	(29)
(30)		MADB	57.1	63.0	71.5	76.3	83.6	89.6	92.7	91.3	87.1	78.8	67.9	59.5		(30)
(31)		5%	WB	45.5	50.4	59.5	64.6	71.4	76.4	78.7	77.6	74.3	67.9	58.2	48.4	(31)
(32)		MADB	53.0	59.4	68.2	73.8	81.1	87.6	91.0	89.5	85.2	75.4	64.2	54.3		(32)
(33)		10%	WB	41.2	45.7	55.0	61.7	69.3	75.0	77.6	76.3	72.7	64.6	54.4	44.3	(33)
(34)		MADB	47.8	54.2	64.2	71.6	78.5	85.5	89.0	87.6	82.8	71.7	61.3	50.4		(34)
(35)	Mean Daily Temperature Range	MDBR	16.8	17.5	19.5	19.1	17.8	17.1	16.8	17.4	18.4	18.5	17.4	16.0		(35)
(36)		5% DB	MCDBR	25.2	25.2	25.8	23.5	20.3	18.7	19.0	20.5	19.9	22.1	23.1	23.2	(36)
(37)		MCWBR	17.0	16.4	14.6	13.2	9.9	8.1	7.2	7.7	8.4	11.4	14.5	16.3		(37)
(38)		5% WB	MCDBR	23.6	23.2	22.1	20.4	18.0	17.4	16.9	18.3	18.0	17.9	19.7	20.7	(38)
(39)		MCWBR	16.9	16.7	14.4	13.6	10.6	8.9	8.0	8.4	8.7	11.3	14.7	16.6		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.296	0.308	0.339	0.391	0.431	0.434	0.442	0.441	0.391	0.347	0.305	0.291		(40)
(41)		taud	2.464	2.436	2.408	2.281	2.227	2.254	2.250	2.258	2.352	2.464	2.523	2.502		(41)
(42)		Ebn at Noon	280	292	292	281	270	269	266	263	270	273	275	273		(42)
(43)		Edh at Noon	25	30	34	41	44	43	43	42	36	29	24	23		(43)
(44)	All-Sky Solar Radiation	RadAvg	694	943	1226	1563	1805	2043	2037	1802	1517	1076	758	601		(44)
(45)		RadStd	71	100	106	100	159	155	129	93	102	122	73	56		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page