

DODGE CITY, KS, USA

WMO: 724510

Lat: 37.7614N

Lon: 99.9686W

Elev: 790

StdP: 92.19

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13985

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.1	-12.3	-19.8	0.7	-12.5	-17.5	0.9	-9.4	14.8	3.4	13.1	2.2	5.3	340	0.679

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	38.0	20.9	36.4	20.9	34.8	20.9	23.5	31.9	22.8	31.6	22.3	31.0	7.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.3	17.5	26.2	20.5	16.7	25.8	19.8	16.0	25.2	74.1	32.0	71.5	31.6	69.1	30.9	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.8	12.1	11.1	-19.4	40.4	2.4	1.5	-21.2	41.4	-22.6	42.3	-24.0	43.1	-25.7	44.2
			-19.9	24.6	2.3	0.9	-21.5	25.3	-22.9	25.8	-24.2	26.4	-25.9	27.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.3	0.5	2.1	7.2	12.2	18.0	23.9	26.6	25.5	21.1	13.8	6.7	1.0	(6)
(7)		DBStd	10.65	5.96	6.59	6.24	5.48	4.89	3.82	3.18	3.22	4.68	5.34	5.44	5.66	(7)
(8)		HDD10.0	1124	297	229	125	38	3	0	0	0	1	24	126	281	(8)
(9)		HDD18.3	2686	553	454	344	192	67	4	1	1	26	158	348	537	(9)
(10)		CDD10.0	2325	2	8	40	106	252	417	514	481	334	142	28	2	(10)
(11)		CDD18.3	846	0	0	1	10	58	171	256	223	109	17	0	0	(11)
(12)		CDH23.3	9973	1	7	44	196	714	1983	3093	2474	1203	242	15	0	(12)
(13)		CDH26.7	5106	0	2	7	63	298	1012	1751	1332	559	81	2	0	(13)
(14)	Wind	WSAvg	5.7	5.4	5.7	6.2	6.5	5.9	5.2	4.9	5.6	5.7	5.5	5.4	(14)	
(15)	Precipitation	PrecAvg	551	14	16	37	52	75	81	78	71	42	42	20	21	(15)
(16)		PrecMax	823	65	72	224	205	262	231	232	189	173	164	95	108	(16)
(17)		PrecMin	265	0	0	0	2	6	4	6	17	0	0	0	0	(17)
(18)		PrecStd	116	14	16	38	42	46	48	52	45	34	38	21	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.5	23.9	27.4	31.6	36.0	39.6	40.0	39.3	37.2	32.2	25.4	19.2	(19)
(20)		MCWB	8.8	10.5	12.5	14.9	18.0	19.2	21.1	20.8	19.5	17.5	12.1	9.3	(20)	
(21)		2%	DB	16.2	19.7	24.3	28.4	32.7	36.3	38.3	37.3	34.6	28.9	22.1	15.5	(21)
(22)		MCWB	6.9	9.0	12.5	14.7	18.3	20.4	21.2	21.3	19.6	16.3	11.4	7.5	(22)	
(23)		5%	DB	12.8	16.0	20.9	25.4	30.1	34.3	36.8	35.6	32.3	26.0	19.1	12.5	(23)
(24)		MCWB	5.4	7.7	10.9	13.9	17.8	20.7	21.3	21.3	19.9	15.3	10.2	6.0	(24)	
(25)		10%	DB	9.5	12.2	17.9	22.3	27.4	32.4	34.9	33.5	30.0	23.0	15.7	9.8	(25)
(26)		MCWB	3.8	5.8	10.0	13.0	17.3	20.7	21.5	21.2	19.0	14.3	9.0	4.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	12.2	16.4	18.0	21.6	23.9	24.5	24.1	22.8	20.2	14.7	11.2	(27)
(28)		MCDWB	18.4	19.0	22.6	24.3	29.3	32.2	32.7	31.8	31.0	27.1	19.7	15.8	(28)	
(29)		2%	WB	7.4	10.0	14.4	16.5	20.3	22.9	23.6	23.2	21.8	18.6	12.9	8.3	(29)
(30)		MCDWB	15.2	18.4	19.6	23.3	27.9	31.5	32.1	31.6	30.0	23.7	18.2	14.2	(30)	
(31)		5%	WB	5.7	8.1	12.5	15.1	19.4	22.1	22.9	22.6	20.9	17.2	11.2	6.3	(31)
(32)		MCDWB	12.2	15.3	18.8	22.5	26.6	30.6	31.9	31.1	28.6	22.5	17.5	12.4	(32)	
(33)		10%	WB	4.2	6.2	10.5	13.8	18.4	21.4	22.4	21.9	20.1	15.6	9.6	4.6	(33)
(34)		MCDWB	9.2	12.3	17.7	21.4	25.5	29.5	31.4	30.5	27.4	21.5	16.2	9.4	(34)	
(35)	Mean Daily Temperature Range	MDBR	13.1	13.6	14.6	14.5	14.0	14.0	14.1	13.7	14.0	14.2	14.1	12.4	(35)	
(36)		5% DB	MCDBR	18.1	19.7	19.2	19.1	17.4	16.4	16.5	16.3	18.0	18.3	16.8	(36)	
(37)		MCWBR	10.7	10.9	9.8	8.7	6.7	5.4	4.5	5.0	5.5	8.0	9.7	10.1	(37)	
(38)		5% WB	MCDBR	17.2	18.1	16.4	15.9	14.7	14.2	14.1	14.0	14.1	14.3	16.2	16.1	(38)
(39)		MCWBR	10.5	10.4	9.2	8.5	6.9	5.7	5.0	5.2	5.6	7.5	9.1	10.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.264	0.273	0.306	0.333	0.352	0.383	0.394	0.381	0.348	0.310	0.277	0.264	(40)	
(41)		taud	2.552	2.539	2.451	2.404	2.425	2.372	2.369	2.373	2.439	2.528	2.554	2.549	(41)	
(42)		Ebn at Noon	941	973	960	946	928	895	881	887	902	914	915	915	(42)	
(43)		Edh at Noon	74	85	103	115	115	121	121	118	104	86	73	69	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.66	3.47	4.65	5.73	6.62	7.28	7.12	6.26	5.26	3.87	2.90	2.34	(44)	
(45)		RadStd	0.23	0.37	0.38	0.32	0.42	0.41	0.30	0.34	0.31	0.45	0.27	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page