

GREAT BEND, KS, USA

WMO: 724517

Lat: 38.350N

Lon: 98.867W

Elev: 573

StdP: 94.63

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13940

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.0	-12.8	-21.1	0.6	-14.1	-17.9	0.8	-11.3	14.4	2.9	12.8	2.3	4.1	0	0.649

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	37.8	22.3	36.3	22.3	34.1	21.9	24.6	32.7	23.9	32.0	23.2	31.5	7.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	18.3	28.6	21.4	17.2	27.6	21.0	16.8	27.2	77.3	32.6	74.5	32.1	71.8	31.9	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 13.6	12.0	11.0	DB	-19.3	40.4	2.5	1.6	-21.1	41.6	-22.5	42.5	-23.9	43.4	-25.7	44.6	(4)
(5)			WB	-20.1	25.8	2.6	0.7	-21.9	26.3	-23.4	26.7	-24.9	27.1	-26.7	27.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	-0.4	1.4	6.7	11.9	18.0	24.0	26.6	25.5	21.0	13.7	6.3	0.5
	DBStd	10.91	5.93	6.57	6.25	5.45	4.96	3.87	3.35	3.20	4.72	5.27	5.38	5.56
	HDD10.0	1207	324	248	137	41	3	0	0	0	1	24	134	297
	HDD18.3	2796	582	475	362	201	68	4	1	1	27	161	361	553
	CDD10.0	2301	1	7	34	99	252	421	514	481	331	137	23	2
	CDD18.3	846	0	0	1	9	59	176	257	222	107	16	0	0
	CDH23.3	9676	0	4	29	157	657	1998	3062	2409	1146	203	11	0
	CDH26.7	4817	0	1	3	47	259	995	1689	1243	517	62	1	0
Wind	WSAvg	5.2	4.8	5.2	5.8	6.2	5.5	5.5	4.9	4.5	5.1	5.2	5.1	4.8
Precipitation	PrecAvg	672	17	24	41	59	112	95	89	94	48	46	27	21
	PrecMax	966	50	71	138	95	347	204	290	230	142	150	78	90
	PrecMin	424	0	0	0	7	25	29	0	7	7	2	3	0
	PrecStd	136	13	20	32	24	73	37	60	46	33	40	24	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.0	22.7	27.0	31.3	35.9	39.1	41.0	39.0	37.3	32.2	25.0	18.1
		MCWB	8.8	10.8	14.2	16.2	19.6	22.0	22.4	21.9	20.9	19.1	13.3	10.4
	2%	DB	15.0	18.7	23.0	27.5	32.3	36.3	38.6	37.3	34.0	27.9	21.4	14.9
		MCWB	6.8	9.7	13.4	16.1	19.7	22.3	22.4	22.3	21.0	16.8	12.1	7.9
	5%	DB	12.0	14.9	20.2	24.2	29.1	33.9	37.1	35.1	32.2	25.8	17.9	12.3
		MCWB	5.8	7.9	11.6	14.7	19.2	21.8	22.7	22.4	20.8	16.2	10.8	6.7
	10%	DB	8.0	12.0	17.4	22.0	27.3	32.4	34.2	32.9	29.5	22.6	15.9	8.9
		MCWB	3.7	6.4	10.9	14.1	18.5	21.4	22.6	22.0	19.7	15.2	10.1	4.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	13.0	17.6	19.3	22.6	25.0	25.6	25.4	23.6	21.2	15.2	12.4
		MCDB	16.8	18.2	21.8	26.0	29.5	33.4	34.2	32.8	31.2	27.1	20.7	15.5
	2%	WB	7.5	10.5	15.2	17.8	21.5	24.0	24.7	24.3	22.6	19.2	13.7	9.1
		MCDB	13.9	17.0	18.8	23.6	28.8	32.3	33.0	32.1	30.6	24.9	18.5	13.8
	5%	WB	5.8	8.4	13.3	16.2	20.4	23.0	24.0	23.6	21.6	17.7	11.9	6.8
		MCDB	11.2	14.9	19.1	22.7	27.3	31.2	32.3	31.6	29.5	22.4	17.0	12.0
	10%	WB	4.1	6.4	11.0	14.6	19.4	22.2	23.4	22.8	20.7	16.0	10.2	4.8
		MCDB	8.4	12.0	17.4	21.3	25.5	30.1	31.9	30.9	27.8	21.7	15.7	9.0
Mean Daily Temperature Range	5% DB	MDBR	12.5	13.0	13.8	13.7	12.7	13.1	13.2	12.9	13.3	13.8	13.7	12.1
		MCDBR	18.3	19.1	18.9	18.0	16.3	15.5	16.4	15.9	15.6	17.5	18.0	17.1
		MCWBR	11.7	11.6	10.7	9.6	7.0	5.6	5.1	5.4	6.0	8.8	10.5	11.2
	5% WB	MCDBR	17.1	17.8	15.4	15.3	13.4	13.7	13.4	13.3	13.4	13.6	15.7	15.9
		MCWBR	11.3	11.2	9.6	9.3	6.8	5.9	5.4	5.5	5.8	7.9	9.8	10.9
Clear-Sky Solar Irradiance	taub	0.274	0.284	0.318	0.342	0.369	0.391	0.411	0.397	0.363	0.322	0.282	0.271	
	taud	2.527	2.502	2.425	2.391	2.398	2.363	2.337	2.366	2.408	2.500	2.542	2.528	
	Ebn at Noon	922	955	945	935	911	887	866	871	884	895	903	899	
	Edh at Noon	75	88	106	116	118	122	125	118	107	88	74	70	
All-Sky Solar Radiation	RadAvg	2.53	3.32	4.43	5.51	6.36	7.09	6.92	6.16	5.10	3.73	2.79	2.21	
	RadStd	0.22	0.37	0.35	0.31	0.43	0.40	0.33	0.36	0.31	0.40	0.26	0.18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	+0.65	+0.57	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page