

LA JUNTA, CO, USA

WMO: 724635

Lat: 38.049N

Lon: 103.512W

Elev: 4194

StdP: 12.60

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23067

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	3.4	8.8	-4.9	4.9	18.3	-0.5	6.3	23.9	32.2	40.6	27.7	40.9	7.8	270	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.5	100.2	63.7	97.7	63.6	95.0	63.6	68.8	86.6	67.8	86.2	66.7	85.0	10.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.3	105.4	71.6	63.2	101.5	71.3	61.8	96.6	71.8	35.4	86.5	34.5	85.7	33.6	84.9	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.0	25.4	21.3	-4.7	104.9	7.1	2.9	-9.8	106.9	-14.0	108.6	-18.0	110.2	-23.1	112.3		
			-5.4	71.1	6.9	1.1	-10.4	71.9	-14.5	72.6	-18.3	73.2	-23.4	74.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	55.0	32.5	35.9	45.4	53.1	63.1	74.1	79.0	76.8	68.7	54.8	42.6	32.4
	DBStd	18.78	10.56	11.16	9.96	9.18	8.23	6.79	4.96	5.04	7.87	9.35	9.47	10.39
	HDD50	2098	545	406	203	72	9	0	0	0	3	57	254	549
	HDD65	5006	1008	815	608	365	133	10	0	1	52	331	671	1012
	CDD50	3911	2	11	61	165	414	722	900	831	564	206	33	2
	CDD65	1344	0	0	1	8	73	282	436	367	162	15	0	0
	CDH74	17958	0	9	89	338	1317	3780	5468	4265	2230	434	28	0
	CDH80	9386	0	1	12	79	550	2055	3175	2304	1071	137	2	0
(14) Wind	WSAvg	9.9	8.8	9.7	10.8	12.3	11.2	10.9	9.4	9.1	9.2	9.4	9.1	9.0
(15) Precipitation	PrecAvg	11.2	0.3	0.3	0.7	1.2	1.5	1.3	2.3	1.3	0.7	0.7	0.5	0.3
	PrecMax	17.4	0.9	1.4	3.5	4.6	4.2	3.3	5.6	4.3	2.0	2.3	1.8	0.9
	PrecMin	6.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0
	PrecStd	3.0	0.3	0.4	0.7	1.0	1.0	0.9	1.3	1.0	0.5	0.6	0.5	0.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.9	73.5	81.6	86.8	95.4	103.4	103.2	101.8	98.2	88.9	77.6	67.7
		MCWB	45.8	47.6	51.0	53.5	59.2	61.3	64.7	64.1	62.4	56.8	50.4	45.7
	2%	DB	62.5	67.3	76.0	82.1	90.4	99.2	100.5	98.2	94.0	84.1	72.5	61.2
		MCWB	43.0	45.2	48.8	52.2	57.9	61.7	64.6	64.1	61.6	55.3	48.5	42.7
	5%	DB	55.7	62.0	71.5	78.1	86.3	95.4	98.2	95.4	90.7	79.2	66.6	55.5
		MCWB	40.3	42.8	47.5	51.4	57.1	61.6	64.6	64.2	60.9	54.3	46.4	40.2
	10%	DB	49.7	55.0	65.5	73.1	82.0	91.6	95.4	92.2	86.9	73.4	60.7	49.8
		MCWB	37.4	39.8	45.5	50.0	56.2	61.8	65.0	64.6	60.1	52.3	44.0	37.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.7	48.7	52.7	57.3	64.3	68.7	70.4	70.2	66.7	61.4	52.2	46.6
		MCDB	66.6	71.9	74.0	75.9	83.1	87.1	88.2	85.8	83.6	76.7	72.3	66.5
	2%	WB	43.5	45.8	50.3	54.9	61.8	66.8	69.0	68.8	65.0	58.4	49.6	43.4
		MCDB	60.4	65.7	72.2	74.3	80.1	85.5	87.1	86.0	81.8	75.8	69.5	60.3
	5%	WB	40.7	43.2	48.3	53.0	60.0	65.4	68.1	67.7	63.6	55.9	47.3	40.6
		MCDB	55.1	61.0	68.6	72.6	78.3	84.5	86.6	85.8	82.0	73.6	65.3	54.9
	10%	WB	37.9	40.3	46.2	51.0	58.4	64.0	67.1	66.5	62.3	53.8	44.7	37.5
		MCDB	48.8	54.2	64.2	71.1	76.4	83.4	85.8	84.1	80.9	71.3	60.0	49.2
(35) Mean Daily Temperature Range	5% DB	MDBR	26.9	27.4	30.1	29.0	29.0	30.1	29.5	28.2	29.6	29.8	28.8	26.2
		MCDBR	37.0	38.0	38.7	37.6	36.0	35.2	33.5	32.8	34.8	38.0	38.3	35.4
	5% WB	MCWBR	21.1	19.9	17.7	15.3	12.7	10.7	9.4	8.8	11.3	16.1	19.2	20.2
		MCWBR	35.3	36.4	36.4	34.1	31.2	30.7	28.2	28.0	29.9	32.6	36.0	34.0
(40) Clear-Sky Solar Irradiance	taub	taub	0.245	0.253	0.278	0.308	0.328	0.345	0.372	0.355	0.319	0.278	0.256	0.246
		taud	2.601	2.598	2.519	2.430	2.435	2.410	2.395	2.421	2.492	2.597	2.578	2.588
	Ebn at Noon	Ebn at Noon	307	317	315	308	302	295	286	289	296	302	299	299
		Edh at Noon	22	25	30	36	36	37	37	36	31	25	23	21
(44) All-Sky Solar Radiation	RadAvg	RadAvg	879	1150	1576	1941	2224	2425	2375	2122	1772	1331	974	768
	RadStd	RadStd	59	91	115	105	122	101	77	69	84	90	67	51

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144	+88

Nomenclature: See separate page