

LEADVILLE LAKE COUNTY AP, CO, USA

WMO: 724673

Lat: 39.229N

Lon: 106.317W

Elev: 9932

StdP: 10.13

Time Zone: -7.00 (NAM)

Period: 98-19

WBAN: 93009

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-7.8	-3.0	-17.1	3.1	1.9	-13.2	3.9	6.1	24.4	21.5	20.9	20.4	6.7	50	0.751

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.1	74.2	47.8	72.2	47.4	70.1	46.9	52.3	64.3	51.2	63.5	50.1	62.3	10.9	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
48.7	74.1	53.3	47.4	70.5	52.7	45.8	66.3	52.1	25.2	64.2	24.5	63.3	23.7	61.6	60.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.8	18.7	16.8	DB	-16.8	78.8	4.7	1.3	-20.1	79.8	-22.9	80.6	-25.5	81.3	-29.0	82.3	(4)
(5)			WB	-17.3	55.3	4.5	1.7	-20.6	56.5	-23.2	57.5	-25.7	58.5	-29.0	59.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.3	17.8	18.2	24.9	31.7	40.8	51.1	56.2	53.5	47.6	37.0	26.0	17.5	
	DBStd	15.61	8.28	8.43	8.11	7.33	7.10	5.01	2.91	3.22	5.06	7.47	9.30	8.92	
	HDD50	5792	997	891	779	550	290	46	1	8	98	404	720	1008	
	HDD65	10846	1462	1311	1244	1000	749	416	274	355	523	869	1170	1473	
	CDD50	421	0	0	0	0	6	80	192	118	25	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	61	0	0	0	0	0	16	39	5	1	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	7.3	7.8	8.0	7.8	8.1	7.7	7.4	5.9	5.7	6.3	7.3	7.3	7.8	
Precipitation	PrecAvg	16.5	1.2	1.2	1.5	1.8	1.4	0.9	1.9	2.0	1.4	1.1	1.1	1.1	
	PrecMax	21.6	3.1	2.9	2.6	3.1	3.7	1.6	3.5	3.3	3.3	2.9	2.0	2.7	
	PrecMin	12.1	0.5	0.6	0.6	0.8	0.3	0.3	0.4	0.7	0.3	0.3	0.4	0.4	
	PrecStd	2.0	0.6	0.6	0.5	0.7	0.7	0.4	0.7	0.7	0.6	0.5	0.4	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.8	44.6	51.6	57.4	69.8	76.2	77.4	74.5	71.9	63.1	54.4	43.8	
		MCWB	30.4	30.2	34.7	37.2	44.7	47.2	49.2	47.9	46.2	40.7	34.9	29.6	
	2%	DB	38.2	39.4	46.9	53.0	63.8	73.1	74.9	72.1	68.1	59.1	49.6	38.9	
		MCWB	27.2	27.7	32.2	35.3	41.7	46.4	48.4	47.7	45.3	39.0	33.5	27.4	
	5%	DB	35.0	35.7	43.2	49.7	60.7	70.7	72.9	69.9	65.3	55.6	45.6	35.0	
		MCWB	26.1	26.5	30.3	34.1	40.1	45.4	48.1	47.4	44.0	37.7	31.4	25.7	
	10%	DB	31.3	32.0	39.3	46.3	57.1	68.1	70.8	67.2	63.0	52.2	41.2	31.2	
		MCWB	24.3	24.5	28.4	32.6	38.9	44.3	48.1	47.3	43.2	36.4	29.3	24.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.4	31.5	35.2	38.9	46.1	51.4	55.1	53.4	50.5	44.1	36.4	30.8
			MCDB	39.3	40.2	48.9	54.1	64.0	68.4	65.8	63.2	62.8	55.1	50.3	40.7
2%		WB	29.0	28.8	32.9	36.5	43.3	49.1	52.9	51.8	48.3	41.2	34.1	28.5	
		MCDB	36.0	37.3	45.1	49.5	59.3	65.6	64.9	63.0	59.9	54.2	47.4	36.1	
5%		WB	26.9	26.9	31.1	34.8	41.4	47.5	51.7	50.7	46.7	39.2	32.1	26.8	
		MCDB	33.3	34.5	41.5	47.1	56.9	63.9	64.2	62.0	58.5	52.6	43.8	33.6	
10%		WB	24.9	24.9	29.2	33.2	39.8	46.0	50.7	49.7	45.3	37.3	30.1	24.7	
		MCDB	31.1	31.3	38.3	44.5	54.8	63.5	63.2	60.8	57.7	49.2	40.2	31.0	
Mean Daily Temperature Range		5% DB	MDBR	21.1	20.4	21.4	21.3	24.6	30.0	29.1	27.4	27.4	23.4	22.3	20.5
			MCDBR	25.8	23.9	25.5	27.3	31.2	34.4	33.1	32.0	32.7	30.0	27.5	24.2
	MCWBR		17.6	15.9	14.7	13.7	13.6	14.0	12.3	12.5	14.1	14.8	15.3	16.1	
	5% WB	MCDBR	22.4	21.0	23.5	24.5	28.4	30.8	26.7	25.2	26.8	26.5	25.1	21.7	
		MCWBR	15.8	14.3	13.8	12.9	12.9	13.1	11.1	10.8	12.5	13.5	14.3	15.0	
Clear-Sky Solar Irradiance	taub	0.203	0.212	0.234	0.263	0.274	0.279	0.305	0.302	0.266	0.245	0.217	0.205		
	taud	2.461	2.424	2.398	2.452	2.562	2.566	2.566	2.543	2.519	2.640	2.655	2.618	2.501	
	Ebn at Noon	322	330	329	323	318	315	306	305	314	314	315	314		
	Edh at Noon	24	29	34	34	32	31	32	32	26	23	21	22		
All-Sky Solar Radiation	RadAvg	865	1172	1616	1848	1982	2312	2046	1813	1642	1226	881	718		
	RadStd	42	63	119	123	153	141	111	90	109	95	70	53		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+119	+38

Nomenclature: See separate page