

MEEKER, CO, USA

WMO: 724674

Lat: 40.044N

Lon: 107.889W

Elev: 1940

StdP: 80.09

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 94050

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.2	-19.8	-26.1	0.4	-22.8	-22.6	0.6	-19.4	9.9	3.0	8.6	3.2	0.8	50	0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	32.6	14.0	31.3	13.7	29.8	13.4	16.3	26.4	15.7	25.9	15.1	25.4	4.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.6	12.4	17.9	12.6	11.5	17.8	11.5	10.7	17.9	52.6	26.3	50.5	26.0	48.4	25.1	19.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.5	7.4	DB	-29.8	34.7	3.5	1.1	-32.4	35.5	-34.4	36.1	-36.4	36.7	-39.0	37.5	(4)
(5)			WB	-29.8	17.9	3.5	0.9	-32.3	18.5	-34.4	19.0	-36.3	19.5	-38.8	20.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-6.4	-3.2	2.3	6.4	11.1	16.7	20.5	19.1	14.5	7.5	1.0	-5.5	(6)	
	DBStd	10.14	5.97	5.48	4.82	4.03	3.96	3.23	1.96	2.05	3.34	4.41	5.52	5.96	(7)	
	HDD10.0	2131	509	370	241	116	36	2	0	0	7	98	272	481	(8)	
	HDD18.3	4252	768	603	498	357	226	66	4	15	119	336	522	739	(9)	
	CDD10.0	1052	0	0	1	9	69	202	327	282	141	20	1	0	(10)	
	CDD18.3	133	0	0	0	0	1	17	73	39	4	0	0	0	(11)	
	CDH23.3	3502	0	0	0	3	97	773	1413	906	297	12	0	0	(12)	
	CDH26.7	1292	0	0	0	0	16	270	623	322	60	1	0	0	(13)	
(14) Wind	WSAvg	2.4	1.5	2.0	2.5	3.1	3.0	3.0	2.5	2.5	2.6	2.3	2.0	1.6	(14)	
(15) Precipitation	PrecAvg	381	22	26	33	38	35	33	33	37	36	35	26	29	(15)	
	PrecMax	538	54	80	55	82	75	106	74	91	152	103	52	72	(16)	
	PrecMin	251	5	2	10	14	1	0	3	5	9	2	3	3	(17)	
	PrecStd	84	12	21	14	18	21	27	20	21	30	25	12	19	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	12.4	20.9	23.2	28.7	33.3	34.6	33.0	30.5	25.0	18.8	11.1	(19)	
		MCWB	2.8	4.6	7.3	8.7	11.9	13.5	15.0	14.3	12.9	10.2	7.1	3.3	(20)	
	2%	DB	6.7	9.5	17.3	21.0	26.0	31.4	33.0	31.5	28.3	22.2	16.1	7.9	(21)	
		MCWB	1.6	3.0	6.0	7.5	10.6	13.1	14.3	13.7	12.1	9.3	6.0	2.3	(22)	
	5%	DB	4.7	7.4	14.1	18.9	23.8	29.8	32.0	30.1	26.9	20.0	13.4	5.7	(23)	
		MCWB	0.6	1.8	4.8	6.6	9.8	12.5	14.2	13.3	11.5	8.5	4.9	1.1	(24)	
	10%	DB	2.8	5.5	11.7	16.9	22.1	27.9	30.5	28.5	24.9	17.7	10.7	3.1	(25)	
		MCWB	-0.3	1.1	3.7	6.1	9.3	12.1	14.1	13.4	11.2	7.6	3.8	-0.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	5.4	7.9	9.5	13.0	15.7	17.6	16.9	15.2	11.8	8.0	4.1	(27)	
		MCDB	7.1	10.9	19.1	21.2	25.8	27.6	26.2	25.9	25.4	19.5	16.6	9.0	(28)	
	2%	WB	2.3	3.5	6.5	8.2	11.6	14.6	16.6	16.1	14.0	10.5	6.3	2.8	(29)	
		MCDB	5.6	8.4	16.3	18.3	22.7	27.0	26.7	25.4	22.8	19.5	14.8	7.1	(30)	
	5%	WB	1.1	2.3	5.2	7.3	10.7	13.7	16.0	15.4	13.2	9.4	5.3	1.4	(31)	
		MCDB	3.9	6.6	13.4	17.1	21.2	26.2	26.5	24.7	21.6	18.1	12.8	5.1	(32)	
	10%	WB	0.0	1.3	4.0	6.5	9.9	12.8	15.4	14.9	12.3	8.3	4.0	0.1	(33)	
		MCDB	2.8	5.0	10.8	15.7	20.0	25.3	26.1	24.1	21.0	16.3	9.8	3.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.6	13.0	14.2	15.2	16.7	19.8	19.2	18.3	18.4	16.4	14.7	12.9	(35)	
		MCDBR	13.6	13.7	18.3	20.7	21.1	23.1	22.3	21.8	22.2	21.1	19.1	14.0	(36)	
	5% WB	MCWBR	9.5	8.5	9.2	9.5	8.8	9.0	8.1	8.2	9.2	10.3	10.5	9.1	(37)	
		MCWBR	11.6	12.4	17.3	18.0	18.7	20.0	17.2	16.3	16.8	17.9	17.9	12.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.237	0.247	0.269	0.296	0.304	0.307	0.339	0.337	0.294	0.271	0.248	0.240	(40)	
		taud	2.537	2.524	2.522	2.485	2.523	2.515	2.464	2.464	2.588	2.623	2.609	2.534	(41)	
	Ebn at Noon		961	993	997	980	972	965	930	925	955	952	942	929	(42)	
		Edh at Noon	71	83	94	105	103	104	109	106	87	75	66	66	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.33	3.15	4.53	5.62	6.51	7.74	7.10	6.20	5.30	3.76	2.57	1.96	(44)	
	RadStd		0.15	0.23	0.39	0.37	0.45	0.46	0.33	0.27	0.31	0.30	0.24	0.17	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page