

BLANDING, UT, USA

WMO: 724723

Lat: 37.583N

Lon: 109.483W

Elev: 5869

StdP: 11.84

Time Zone: -7.00 (NAM)

Period: 83-19

WBAN: 93025

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 10.7	(c) 14.8	(d) -2.2	(e) 6.1	(f) 33.2	(g) 1.3	(h) 7.3	(i) 31.9	(j) 20.9	(k) 30.7	(l) 18.4	(m) 33.0	(n) 5.4	(o) 350	(p) 0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.8	92.9	58.2	90.9	57.8	88.7	57.5	63.1	80.5	62.0	80.0	60.9	78.9	8.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.8	92.4	65.8	56.9	86.0	65.9	55.0	80.3	67.0	31.5	80.2	30.6	80.0	29.9	78.5	69.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 22.4	(b) 18.5	(c) 15.9	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 22.4	(b) 18.5	(c) 15.9	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	29.7	35.7	43.6	50.2	57.9	71.5	74.4	73.5	64.5	53.0	40.7	31.8
	DBStd	16.95	6.93	7.99	7.46	6.97	7.44	5.83	4.38	3.88	7.23	6.87	7.37	6.51
	HDD50	2255	628	400	225	83	21	0	0	0	3	45	285	565
	HDD65	5499	1093	819	665	443	235	16	1	1	95	373	728	1030
	CDD50	3097	0	1	26	90	267	645	757	729	437	138	7	0
	CDD65	868	0	0	0	0	16	211	294	266	79	2	0	0
	CDH74	9872	0	0	0	10	294	2755	3335	2600	839	39	0	0
	CDH80	4122	0	0	0	0	52	1216	1557	1055	240	2	0	0
Wind	WSAvg	6.6	5.0	6.2	7.5	8.2	8.1	7.6	6.3	6.4	6.8	6.2	6.0	4.7
Precipitation	PrecAvg	13.7	1.5	1.2	1.1	0.9	0.7	0.4	1.3	1.5	1.4	1.5	1.1	1.2
	PrecMax	21.9	5.3	3.7	3.6	2.9	2.3	1.9	3.5	5.4	4.1	7.2	3.0	4.8
	PrecMin	6.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.5	1.4	1.0	0.9	0.7	0.6	0.5	0.9	1.2	1.0	1.3	0.7	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.9	60.1	71.2	75.7	85.4	95.7	95.5	93.4	90.4	78.3	64.4	52.5
		MCWB	39.1	43.5	47.2	49.2	52.2	57.9	59.5	57.8	57.4	52.4	46.2	39.5
	2%	DB	47.1	55.4	65.9	72.2	80.9	92.3	93.2	91.1	86.0	73.2	61.3	48.4
		MCWB	36.8	41.2	44.9	47.9	51.4	56.9	59.3	57.9	56.0	50.5	44.8	37.5
	5%	DB	43.4	51.4	61.9	68.7	77.5	90.1	91.2	89.2	82.1	69.9	57.2	45.2
		MCWB	35.0	39.3	42.7	46.2	50.4	56.2	58.7	57.8	55.5	48.9	42.3	36.4
	10%	DB	40.0	47.5	57.8	65.1	73.7	87.1	88.8	86.3	79.0	66.2	53.6	42.1
		MCWB	33.4	37.5	41.2	44.4	49.4	55.4	58.7	57.6	54.8	47.6	40.7	35.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.0	45.4	48.0	52.2	56.6	62.7	65.2	64.2	60.5	56.2	48.2	42.9
		MCDB	48.9	56.1	67.3	70.6	70.9	83.0	77.1	78.4	74.0	64.0	60.0	47.6
	2%	WB	38.4	42.5	45.8	49.3	54.2	60.1	63.4	62.7	59.2	53.7	46.0	40.4
		MCDB	44.2	52.2	63.5	67.4	71.1	83.4	82.2	78.3	75.0	68.1	58.4	45.9
	5%	WB	36.2	40.4	43.8	47.4	52.5	58.5	62.4	61.7	58.0	51.4	43.6	38.1
		MCDB	41.3	49.0	59.2	65.5	71.3	82.2	81.1	78.5	75.0	64.2	55.8	42.9
	10%	WB	34.2	38.5	41.9	45.7	50.7	57.1	61.4	60.4	56.8	49.8	41.3	35.8
		MCDB	38.9	46.4	55.7	61.7	70.5	81.2	80.0	77.4	74.1	62.2	52.3	41.1
Mean Daily Temperature Range	5% DB	MDBR	16.0	18.4	21.5	24.0	25.0	28.6	26.8	25.2	23.9	23.3	20.6	16.4
		MCDBR	18.6	22.9	26.5	28.0	29.3	31.4	30.0	28.7	27.5	27.0	23.9	19.5
		MCWBR	11.4	12.2	13.0	12.7	12.1	12.2	10.1	10.6	11.0	12.3	12.9	12.2
	5% WB	MCDBR	15.7	20.7	24.4	26.5	25.8	27.4	24.9	23.0	23.8	22.4	22.9	16.2
		MCWBR	10.7	11.6	12.6	12.4	11.3	11.1	8.2	7.9	9.8	10.8	12.9	10.9
Clear-Sky Solar Irradiance	taub	0.244	0.257	0.267	0.288	0.299	0.303	0.344	0.343	0.300	0.282	0.251	0.246	
	taud	2.597	2.565	2.552	2.485	2.494	2.470	2.412	2.418	2.544	2.554	2.604	2.593	
	Ebn at Noon	308	315	319	315	311	308	294	293	303	301	303	300	
	Edh at Noon	22	26	30	34	34	35	37	36	30	26	22	21	
All-Sky Solar Radiation	RadAvg	881	1160	1667	2089	2392	2651	2387	2106	1829	1375	1010	754	
	RadStd	78	92	123	106	142	115	104	80	67	96	63	57	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page