

HANKSVILLE, UT, USAWMO: **724733**Lat: **38.417N**Lon: **110.700W**Elev: **4446**StdP: **12.48**Time Zone: **-7.00 (NAM)**Period: **98-19**WBAN: **23170****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	8.7	11.9	-1.9	5.9	25.4	1.3	6.9	27.8	24.6	51.2	19.0	45.2	0.2	140	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.6	102.2	62.1	99.7	61.2	97.3	60.7	67.2	86.0	65.6	86.3	64.2	85.7	6.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.6	100.3	72.6	60.5	93.1	72.3	57.1	82.2	72.4	34.2	85.4	32.9	85.9	31.8	85.4	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.0	19.6	17.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.5	30.9	37.3	47.3	54.4	63.1	76.4	82.1	77.9	69.4	54.7	41.1	29.7
	DBStd	18.97	6.75	7.45	7.01	6.53	7.08	6.42	4.53	4.26	6.76	7.37	7.82	7.22
	HDD50	2066	592	359	135	31	3	0	0	0	0	35	283	628
	HDD65	4998	1057	776	548	321	121	4	0	0	35	327	716	1093
	CDD50	4056	0	2	51	163	408	791	996	865	583	180	17	0
	CDD65	1516	0	0	0	3	61	345	531	400	168	8	0	0
	CDH74	22411	0	0	34	166	1270	5739	7507	5059	2452	182	2	0
	CDH80	12361	0	0	2	21	451	3417	4551	2757	1130	32	0	0
Wind	WSAvg	4.5	2.6	4.4	5.4	7.0	6.0	6.3	4.5	4.2	4.5	3.7	3.4	2.3
Precipitation	PrecAvg	5.7	0.4	0.3	0.5	0.5	0.5	0.3	0.5	0.7	0.8	0.7	0.4	0.3
	PrecMax	9.7	1.8	0.9	1.9	1.6	3.1	1.3	1.9	2.4	2.7	3.6	2.7	1.5
	PrecMin	2.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.7	0.5	0.2	0.4	0.5	0.5	0.4	0.4	0.6	0.7	0.7	0.5	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.4	64.3	79.3	83.8	95.0	104.4	107.3	102.0	97.2	83.7	70.5	55.5
		MCWB	42.9	45.3	50.7	53.0	58.6	60.9	64.7	62.5	60.6	55.9	49.3	45.4
	2%	DB	51.8	60.8	73.0	79.2	89.5	101.3	103.9	99.1	93.0	79.1	65.5	51.9
		MCWB	41.6	43.8	48.4	50.7	55.7	60.2	63.7	61.3	59.3	53.2	46.9	42.2
	5%	DB	47.9	55.3	69.0	75.3	85.7	99.2	100.4	96.3	90.3	74.7	62.6	46.2
		MCWB	38.6	42.0	46.9	49.5	54.5	59.7	62.5	61.0	58.3	51.7	45.2	37.6
	10%	DB	44.7	52.1	64.0	72.2	81.7	96.7	98.6	93.0	87.4	71.5	57.1	43.1
		MCWB	36.3	40.7	44.9	48.2	53.1	58.6	62.1	60.5	57.6	51.0	42.9	35.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.7	48.8	52.5	54.8	60.9	64.2	70.5	69.0	65.0	59.3	51.3	47.3
		MCDB	53.6	59.8	72.6	75.5	85.8	94.8	92.0	86.2	78.7	74.4	65.5	55.3
	2%	WB	42.3	45.5	50.1	52.4	57.9	62.1	68.1	66.5	63.1	56.8	48.3	42.8
		MCDB	50.3	57.1	69.6	74.7	82.2	94.3	88.1	83.9	79.3	70.0	62.5	50.6
	5%	WB	39.4	43.7	48.0	50.8	55.5	60.7	66.4	65.1	61.3	54.6	46.2	38.9
		MCDB	46.4	54.4	65.8	72.3	81.1	93.2	87.7	83.0	79.7	67.2	59.0	45.7
	10%	WB	36.9	41.4	46.1	49.3	53.9	59.5	65.1	63.8	59.7	52.7	44.0	35.4
		MCDB	43.0	51.0	62.2	69.0	78.4	90.9	88.2	81.9	80.0	66.6	55.6	42.2
Mean Daily Temperature Range	5% DB	MDBR	23.4	24.6	28.6	28.5	29.6	33.8	30.6	30.1	31.4	28.5	27.0	22.7
		MCDBR	29.8	30.6	37.4	35.4	38.6	39.6	35.7	35.0	37.4	34.6	31.9	26.1
		MCWBR	19.7	17.5	18.3	16.5	15.7	15.8	11.5	12.2	14.4	16.0	18.0	17.8
	5% WB	MCDBR	24.8	27.8	32.0	32.4	34.3	35.2	26.4	26.2	27.7	26.5	26.6	24.3
		MCWBR	17.6	17.1	17.6	15.7	14.3	14.0	9.0	9.3	11.1	12.7	15.5	17.4
Clear-Sky Solar Irradiance	taub		0.254	0.267	0.278	0.317	0.320	0.321	0.369	0.363	0.320	0.293	0.261	0.256
	taud		2.535	2.505	2.486	2.355	2.399	2.400	2.322	2.347	2.453	2.497	2.544	2.541
	Ebn at Noon		301	310	314	305	304	302	287	286	295	295	295	292
	Edh at Noon		23	28	31	38	37	37	40	38	32	28	23	22
All-Sky Solar Radiation	RadAvg		845	1151	1635	2041	2320	2594	2305	2039	1807	1352	977	740
	RadStd		68	93	95	95	128	137	108	99	85	93	63	53

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+218	N/A

Nomenclature: See separate page