

INVERNESS, FL, USA

WMO: 724737

Lat: 28.804N

Lon: 82.318W

Elev: 15

StdP: 101.14

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00377

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.2	1.9	-7.3	2.0	5.7	-3.7	2.8	7.1	7.9	14.4	7.2	16.8	0.6	0	0.307

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	35.3	25.6	34.1	25.2	32.9	24.8	28.0	31.3	27.5	30.6	27.1	30.3	2.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.4	23.3	29.1	27.1	22.8	28.9	26.2	21.7	28.5	89.7	31.5	86.8	31.2	84.9	30.7	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.0	5.2	4.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB													
			WB	-3.3	28.0	2.2	1.6	-4.9	29.2	-6.1	30.2	-7.4	31.1	-9.0	32.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.8	13.3	16.2	17.7	21.4	24.4	27.0	27.8	28.0	27.0	22.9	18.7	16.5
	DBStd	6.02	5.01	4.88	4.17	2.64	2.45	1.58	1.69	1.70	1.65	3.48	3.95	4.67
	HDD10.0	44	26	8	2	0	0	0	0	0	0	0	1	7
	HDD18.3	469	166	89	63	6	1	0	0	0	0	9	44	90
	CDD10.0	4338	129	182	241	341	447	509	551	558	511	402	261	207
	CDD18.3	1721	12	29	43	97	189	259	293	300	261	152	54	32
	CDH23.3	16074	104	237	407	1002	1888	2470	2838	2917	2333	1245	409	225
	CDH26.7	6567	8	38	77	323	825	1117	1316	1316	1009	427	84	28
(14) Wind	WSAvg	1.4	1.6	1.5	1.6	1.7	1.5	1.2	0.9	1.1	1.2	1.5	1.6	1.5
(15) Precipitation	PrecAvg	1360	84	83	106	56	81	201	198	210	162	64	51	65
	PrecMax	2217	243	168	406	150	304	555	374	411	413	230	196	266
	PrecMin	906	7	12	0	0	5	43	94	45	19	0	0	3
	PrecStd	236	46	44	82	40	63	102	68	83	99	50	44	53
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.6	29.9	30.1	32.8	34.9	37.2	37.2	37.0	35.2	32.9	31.1	28.7
		MCWB	20.4	21.4	19.1	22.0	22.9	24.9	26.0	26.6	25.1	24.5	23.9	22.1
	2%	DB	26.2	27.7	28.7	31.3	32.9	34.9	35.2	35.0	34.0	32.0	28.8	27.4
		MCWB	19.7	20.7	19.4	21.3	22.4	24.9	26.1	26.7	25.0	23.6	21.9	21.6
	5%	DB	24.1	26.3	27.4	30.1	32.3	32.8	33.9	33.0	32.8	30.9	27.4	26.2
		MCWB	18.9	19.9	19.2	20.7	22.2	24.6	25.9	25.8	24.7	22.8	20.7	20.7
	10%	DB	22.2	24.8	26.1	28.0	31.1	32.2	32.5	32.5	32.2	29.1	26.0	24.0
		MCWB	17.9	18.8	18.5	19.8	21.9	24.6	25.7	25.8	24.5	22.1	20.0	19.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.4	23.3	22.9	24.4	26.1	27.9	28.5	29.1	27.9	26.6	25.1	23.9
		MCDB	25.9	26.9	26.0	28.7	28.8	30.5	31.8	32.5	30.8	29.4	28.5	27.3
	2%	WB	20.9	22.2	21.9	23.4	25.2	27.2	27.8	28.3	27.2	25.5	23.8	22.9
		MCDB	23.8	25.8	25.4	28.0	28.8	30.0	31.0	32.0	30.4	28.9	27.2	25.7
	5%	WB	19.8	21.2	20.9	22.6	24.4	26.6	27.3	27.7	26.5	24.8	22.5	22.1
		MCDB	22.7	24.6	24.5	27.1	28.7	30.0	30.6	31.0	29.8	28.4	25.4	24.7
	10%	WB	18.6	20.2	19.9	21.5	23.7	26.0	26.9	27.2	25.8	23.9	21.3	21.0
		MCDB	22.1	23.3	23.6	25.8	28.0	29.6	30.3	30.3	29.2	27.5	24.0	23.3
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	13.2	13.9	13.9	12.8	10.3	10.0	9.5	9.9	11.9	12.8	12.8
		MCDBR	14.4	13.7	14.7	15.4	14.5	11.8	11.3	10.3	11.0	12.1	13.0	13.2
		MCWBR	8.3	7.3	6.7	6.0	4.9	4.2	3.8	3.8	3.7	4.8	6.5	7.5
	5% WB	MCDBR	12.3	11.8	12.1	12.8	10.9	9.9	9.8	9.2	9.3	9.5	10.4	11.8
		MCWBR	8.1	6.8	6.6	6.4	4.8	4.6	4.5	4.2	4.0	4.3	6.2	7.9
(40) Clear-Sky Solar Irradiance	taub		0.340	0.352	0.367	0.389	0.426	0.457	0.486	0.467	0.421	0.391	0.353	0.340
	taud		2.511	2.483	2.434	2.351	2.300	2.288	2.208	2.275	2.385	2.440	2.492	2.533
	Ebn at Noon		901	918	922	907	869	837	812	826	857	864	877	883
	Edh at Noon		90	101	112	126	133	134	145	134	117	104	92	85
(44) All-Sky Solar Radiation	RadAvg		3.41	4.07	5.21	6.25	6.61	5.91	5.62	5.43	4.95	4.53	3.71	3.13
	RadStd		0.24	0.31	0.44	0.36	0.41	0.46	0.37	0.35	0.34	0.31	0.20	0.26

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	-6	-52	+159	+115

Nomenclature: See separate page