

ST GEORGE, UT, USA

WMO: 724754

Lat: 37.091N

Lon: 113.593W

Elev: 2936

StdP: 13.20

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 23186

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	25.3	27.8	2.6	7.0	37.5	6.8	8.7	42.2	26.3	48.3	21.0	45.4	2.6	70	0.488

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.4	106.2	66.1	103.6	65.2	100.9	64.5	69.5	92.9	68.4	92.4	67.4	91.9	13.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.4	97.6	75.9	61.3	90.4	78.0	58.6	81.8	80.5	35.2	92.5	34.2	92.3	33.4	91.6	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.5	22.9	19.1	DB	19.9	110.5	4.5	2.1	16.6	112.0	14.0	113.3	11.4	114.5	8.1	116.0	(4)
(5)			WB	16.5	71.2	3.9	1.4	13.7	72.2	11.4	73.0	9.2	73.8	6.3	74.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.4	42.7	47.1	55.4	62.1	72.2	82.8	88.7	86.4	78.4	64.4	50.8	41.2
	DBStd	17.63	5.29	5.85	6.83	7.45	7.77	6.60	4.51	4.27	5.84	7.18	6.64	5.75
	HDD50	726	232	113	27	5	0	0	0	0	0	3	69	277
	HDD65	2931	693	500	303	141	27	2	0	0	2	97	427	739
	CDD50	5994	4	33	195	367	688	984	1200	1128	851	449	92	3
	CDD65	2724	0	0	6	53	250	536	735	663	403	78	0	0
	CDH74	37547	0	0	128	730	3135	7785	11041	9275	4621	822	10	0
	CDH80	22123	0	0	21	220	1533	4832	7166	5688	2416	247	0	0
Wind	WSAvg	6.1	3.6	4.6	6.1	7.9	8.4	8.4	8.0	7.3	6.4	5.2	3.8	3.5
Precipitation	PrecAvg	8.3	1.1	1.1	1.0	0.6	0.4	0.2	0.5	0.7	0.6	0.6	0.8	0.7
	PrecMax	15.8	4.7	3.1	4.4	2.9	2.0	1.3	1.5	2.3	2.7	2.4	2.4	2.5
	PrecMin	4.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.8	1.2	0.9	1.0	0.6	0.4	0.3	0.5	0.6	0.7	0.7	0.7	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.0	71.5	82.3	90.3	100.2	108.2	110.6	106.5	100.5	90.8	75.0	61.4
		MCWB	46.7	49.9	54.2	57.3	62.6	65.6	67.6	66.0	64.6	59.2	52.1	45.7
	2%	DB	58.7	66.0	77.4	85.8	96.8	104.2	107.8	104.2	98.7	86.0	71.7	57.1
		MCWB	43.9	47.3	51.8	55.7	60.0	64.0	66.9	65.7	63.2	57.7	51.1	44.1
	5%	DB	55.3	63.1	73.2	81.8	92.5	101.7	104.7	101.7	95.3	82.0	67.2	54.4
		MCWB	42.5	46.0	50.1	53.7	58.6	63.3	66.0	65.4	62.2	55.7	48.8	42.7
	10%	DB	53.7	59.2	70.2	78.7	89.5	99.3	101.8	99.4	92.2	79.0	63.5	51.9
		MCWB	41.9	44.3	48.9	52.1	57.8	62.1	65.2	64.9	61.4	54.2	46.9	41.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.6	51.4	55.1	58.2	63.1	66.9	71.5	70.4	68.8	62.4	54.9	49.3
		MCDB	56.4	64.4	79.9	87.5	99.1	103.5	95.5	93.1	88.5	81.5	69.7	57.0
	2%	WB	47.1	49.2	52.9	56.0	60.8	65.1	70.1	69.2	66.9	59.5	51.9	46.4
		MCDB	55.0	61.5	74.9	83.1	94.2	101.4	93.8	92.8	87.1	82.2	67.1	54.4
	5%	WB	44.8	47.5	51.0	54.3	59.2	63.5	69.0	68.2	65.4	57.4	49.9	44.2
		MCDB	52.7	60.4	71.1	79.9	90.6	98.7	92.9	92.2	85.7	77.8	65.4	51.9
	10%	WB	42.9	45.5	49.4	52.7	57.6	62.5	68.0	67.1	63.7	55.6	47.9	42.0
		MCDB	51.0	57.4	67.7	76.4	86.8	96.7	92.6	91.4	84.9	74.2	62.4	49.7
Mean Daily Temperature Range	5% DB	MDBR	19.3	20.6	24.1	24.8	25.5	27.4	25.4	25.2	25.6	24.3	21.9	18.1
		MCDBR	23.2	26.4	29.1	30.2	29.9	30.4	28.5	28.2	28.6	28.4	26.8	21.5
		MCWBR	13.2	13.8	13.5	13.1	12.6	13.3	10.6	10.1	11.0	12.7	13.7	12.5
	5% WB	MCDBR	18.7	23.2	27.6	28.8	28.7	29.1	23.4	23.7	23.0	24.9	24.0	18.4
		MCWBR	11.1	12.5	12.8	12.5	11.7	12.5	7.3	7.9	8.4	10.9	12.6	11.2
Clear-Sky Solar Irradiance	taub	0.268	0.277	0.291	0.319	0.337	0.331	0.381	0.375	0.326	0.307	0.275	0.269	
	taud	2.570	2.553	2.512	2.419	2.405	2.421	2.370	2.377	2.502	2.518	2.570	2.575	
	Ebn at Noon	298	308	311	305	299	299	284	284	295	292	293	291	
	Edh at Noon	23	27	31	36	37	37	38	37	31	28	23	22	
All-Sky Solar Radiation	RadAvg	908	1182	1667	2103	2409	2677	2337	2156	1890	1404	1031	790	
	RadStd	83	117	111	113	159	136	121	115	87	105	53	66	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		N/A	N/A	-1.76	N/A	N/A	N/A	N/A	N/A	+178	+76

Nomenclature: See separate page