

BRYCE CANYON, UT, USA

WMO: 724756

Lat: 37.706N

Lon: 112.146W

Elev: 7586

StdP: 11.09

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 23159

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.6	-2.9	-13.7	3.5	-4.8	-8.5	4.6	2.5	25.5	27.4	23.1	27.0	6.2	250	0.697

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.6	84.8	53.7	82.4	53.3	80.6	52.9	59.1	72.9	57.9	72.4	56.7	71.6	11.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.0	85.7	62.0	53.4	80.7	61.0	51.6	75.5	60.7	29.1	72.3	28.2	71.9	27.3	71.5	63.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.7	20.9	18.7	DB	-18.1	89.1	5.3	2.1	-21.9	90.6	-25.0	91.9	-28.0	93.0	-31.8	94.5	(4)
(5)			WB	-18.5	61.5	5.2	1.0	-22.2	62.2	-25.3	62.9	-28.2	63.4	-31.9	64.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.3	21.0	23.5	31.8	39.3	47.3	57.2	64.1	61.4	54.0	42.8	31.8	20.8		
	DBStd	16.62	9.03	9.11	8.21	6.68	6.69	5.51	3.66	3.46	5.49	6.38	8.25	9.24		
	HDD50	4378	900	742	564	322	130	10	0	0	26	233	545	906		
	HDD65	8673	1365	1162	1029	770	549	236	61	117	330	688	995	1371		
	CDD50	1221	0	0	0	2	46	227	436	353	147	10	0	0		
	CDD65	39	0	0	0	0	0	3	31	5	0	0	0	0		
	CDH74	2799	0	0	0	0	39	759	1192	673	135	1	0	0		
	CDH80	547	0	0	0	0	4	146	293	96	8	0	0	0		
	WSAvg	8.5	7.9	8.5	9.0	10.3	9.5	9.3	7.6	7.5	8.0	8.2	8.0	7.6		
	PrecAvg	13.2	1.2	1.2	1.0	0.7	0.7	0.5	1.3	1.7	1.6	1.7	0.7	0.9		
(15) Precipitation	PrecMax	18.8	4.8	4.2	2.9	1.8	2.6	2.0	2.7	3.4	5.2	5.1	3.4	2.8		
	PrecMin	7.1	0.2	0.1	0.1	0.0	0.0	0.0	0.1	0.1	0.1	0.0	0.1	0.2		
	PrecStd	3.4	1.2	0.9	0.7	0.5	0.6	0.5	0.7	0.8	1.5	1.5	0.7	0.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.6	53.7	63.6	69.3	78.3	86.7	89.0	85.3	80.9	72.1	62.6	51.0		
		MCWB	35.8	38.1	42.7	44.9	50.4	53.0	55.9	53.5	51.6	47.7	42.6	35.6		
	2%	DB	44.8	48.4	58.1	65.2	73.6	83.8	85.9	82.4	77.7	67.2	57.9	45.5		
		MCWB	34.3	34.9	40.3	43.3	47.8	52.4	54.4	53.3	50.6	45.5	40.2	34.1		
	5%	DB	39.7	43.4	54.0	61.7	71.0	81.5	83.4	80.7	75.0	63.9	53.8	41.1		
		MCWB	31.7	33.3	38.2	41.4	46.6	51.2	54.5	53.5	50.1	44.2	38.6	32.8		
	10%	DB	36.1	39.0	48.4	57.5	67.3	78.9	80.9	78.3	72.6	60.8	49.2	36.8		
		MCWB	29.8	31.4	35.8	39.9	45.2	50.2	54.1	53.4	49.7	43.1	36.6	30.7		
	0.4%	WB	38.0	39.1	43.6	46.8	52.6	56.8	61.0	60.2	57.4	51.4	44.6	38.6		
		MCDB	46.7	49.9	61.0	65.5	74.5	79.6	74.2	72.3	69.0	64.9	58.4	45.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.0	36.3	41.2	44.3	49.6	54.5	59.5	58.7	55.4	48.5	41.8	35.9		
		MCDB	41.9	45.8	56.9	61.8	70.3	77.8	73.6	72.0	68.9	61.0	55.2	42.3		
	5%	WB	32.9	34.2	38.9	42.4	47.9	52.9	58.4	57.4	53.6	46.5	39.3	33.4		
		MCDB	38.4	41.7	52.0	58.7	67.6	76.5	73.2	71.2	67.3	59.5	51.7	39.7		
	10%	WB	30.6	32.1	36.4	40.8	46.1	51.3	57.3	56.4	51.9	44.5	37.2	31.1		
		MCDB	35.5	38.5	47.4	56.4	64.9	75.1	72.7	70.1	65.4	57.5	48.0	37.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	27.1	26.1	26.7	28.5	31.4	37.6	32.6	32.0	32.9	30.3	28.9	26.7		
		MCDBR	29.8	28.8	33.7	37.1	38.5	42.1	37.5	37.0	38.0	36.9	35.7	29.9		
		MCWBR	21.0	18.0	18.1	18.7	17.8	19.1	15.0	15.1	17.1	19.2	20.6	20.3		
		MCDBR	26.2	25.9	31.2	33.5	34.8	37.4	28.3	27.8	28.3	29.8	32.1	26.7		
	5% WB	MCWBR	18.9	16.9	17.2	17.4	16.5	17.3	11.4	12.0	13.7	16.6	19.4	18.8		
(40) Clear-Sky Solar Irradiance	taub		0.232	0.238	0.249	0.276	0.281	0.281	0.321	0.325	0.278	0.270	0.240	0.234		
	taud		2.594	2.594	2.602	2.507	2.556	2.561	2.483	2.455	2.620	2.588	2.629	2.598		
	Ebn at Noon		313	323	326	319	317	315	302	299	311	306	308	305		
	Edh at Noon		22	25	28	33	32	32	34	34	27	25	21	21		
(44) All-Sky Solar Radiation	RadAvg		887	1151	1618	2030	2297	2606	2201	1997	1791	1353	989	766		
	RadStd		72	100	102	112	179	167	132	125	99	116	62	61		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page