

BRYCE CANYON, UT, USA

WMO: 724756

Lat: 37.706N

Lon: 112.146W

Elev: 2312

StdP: 76.46

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 23159

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.6	-19.4	-25.4	0.5	-20.5	-22.5	0.7	-16.4	11.4	-2.6	10.3	-2.8	2.8	250	0.697

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	29.3	12.0	28.0	11.8	27.0	11.6	15.1	22.7	14.4	22.4	13.7	22.0	5.0	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.8	12.2	16.7	11.9	11.5	16.1	10.9	10.8	15.9	49.8	22.4	47.7	22.2	45.6	21.9	17.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.4	8.4	-27.8	31.7	2.9	1.2	-30.0	32.6	-31.7	33.3	-33.3	33.9	-35.4	34.7		
(5)			-28.1	16.4	2.9	0.6	-30.1	16.8	-31.8	17.1	-33.4	17.5	-35.5	17.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.2	-6.1	-4.7	-0.1	4.1	8.5	14.0	17.8	16.3	12.2	6.0	-0.1	-6.2
	DBStd	9.23	5.02	5.06	4.56	3.71	3.72	3.06	2.03	1.92	3.05	3.55	4.58	5.14
	HDD10.0	2432	500	412	313	179	72	6	0	0	14	129	303	503
	HDD18.3	4818	758	646	572	428	305	131	34	65	183	382	553	762
	CDD10.0	678	0	0	0	1	26	126	242	196	82	6	0	0
	CDD18.3	22	0	0	0	0	0	2	17	3	0	0	0	0
	CDH23.3	1555	0	0	0	0	22	422	662	374	75	1	0	0
	CDH26.7	304	0	0	0	0	2	81	163	53	4	0	0	0
Wind	WSAvg	3.8	3.5	3.8	4.0	4.6	4.3	4.1	3.4	3.4	3.6	3.7	3.6	3.4
Precipitation	PrecAvg	335	30	31	25	19	18	12	32	44	41	42	18	23
	PrecMax	478	121	106	73	45	65	52	68	86	132	129	87	72
	PrecMin	180	4	2	2	1	1	0	2	3	2	0	3	6
	PrecStd	86	31	22	19	13	15	13	18	21	38	38	17	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	12.1	17.5	20.7	25.7	30.4	31.7	29.6	27.2	22.3	17.0	10.5
		MCWB	2.1	3.4	5.9	7.1	10.2	11.7	13.3	12.0	10.9	8.7	5.9	2.0
	2%	DB	7.1	9.1	14.5	18.4	23.1	28.8	29.9	28.0	25.4	19.6	14.4	7.5
		MCWB	1.3	1.6	4.6	6.3	8.8	11.3	12.5	11.8	10.3	7.5	4.6	1.2
	5%	DB	4.3	6.3	12.2	16.5	21.7	27.5	28.5	27.0	23.9	17.7	12.1	5.0
		MCWB	-0.2	0.7	3.5	5.2	8.1	10.7	12.5	12.0	10.1	6.8	3.7	0.4
	10%	DB	2.3	3.9	9.1	14.2	19.6	26.1	27.2	25.7	22.5	16.0	9.5	2.7
		MCWB	-1.2	-0.3	2.1	4.4	7.3	10.1	12.3	11.9	9.8	6.1	2.5	-0.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.3	3.9	6.5	8.2	11.4	13.8	16.1	15.7	14.1	10.8	7.0	3.7
		MCDB	8.2	10.0	16.1	18.6	23.6	26.4	23.4	22.4	20.6	18.3	14.7	7.7
	2%	WB	1.7	2.4	5.1	6.9	9.8	12.5	15.3	14.8	13.0	9.2	5.4	2.2
		MCDB	5.5	7.7	13.8	16.6	21.3	25.4	23.1	22.2	20.5	16.1	12.9	5.7
	5%	WB	0.5	1.2	3.8	5.8	8.8	11.6	14.7	14.1	12.0	8.0	4.1	0.8
		MCDB	3.5	5.4	11.1	14.9	19.8	24.7	22.9	21.8	19.6	15.3	11.0	4.3
	10%	WB	-0.8	0.1	2.5	4.9	7.8	10.7	14.1	13.5	11.1	6.9	2.9	-0.5
		MCDB	1.9	3.6	8.6	13.5	18.3	24.0	22.6	21.2	18.6	14.2	8.9	2.9
Mean Daily Temperature Range	5% DB	MDBR	15.1	14.5	14.8	15.9	17.4	20.9	18.1	17.8	18.3	16.9	16.0	14.9
		MCDBR	16.6	16.0	18.7	20.6	21.4	23.4	20.8	20.6	21.1	20.5	19.8	16.6
		MCWBR	11.7	10.0	10.1	10.4	9.9	10.6	8.4	8.4	9.5	10.7	11.4	11.3
	5% WB	MCDBR	14.6	14.4	17.3	18.6	19.3	20.8	15.7	15.4	15.7	16.6	17.8	14.8
		MCWBR	10.5	9.4	9.5	9.7	9.1	9.6	6.3	6.6	7.6	9.2	10.8	10.5
Clear-Sky Solar Irradiance	taub	0.232	0.238	0.249	0.276	0.281	0.281	0.321	0.325	0.278	0.270	0.240	0.234	
	taud	2.594	2.594	2.602	2.507	2.556	2.561	2.483	2.455	2.620	2.588	2.629	2.598	
	Ebn at Noon	988	1019	1029	1006	999	994	951	942	981	964	971	963	
	Edh at Noon	70	80	88	104	101	100	108	108	86	80	67	65	
All-Sky Solar Radiation	RadAvg	2.80	3.63	5.10	6.40	7.24	8.21	6.94	6.29	5.65	4.26	3.12	2.42	
	RadStd	0.23	0.31	0.32	0.35	0.56	0.53	0.42	0.39	0.31	0.37	0.19	0.19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page