

CORTEZ, CO, USA

WMO: 724767

Lat: 37.307N

Lon: 108.626W

Elev: 5910

StdP: 11.82

Time Zone: -7.00 (NAM)

Period: 96-19

WBAN: 93069

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.1	6.5	-6.3	4.9	13.0	-2.1	6.1	18.0	22.8	39.2	19.3	38.1	5.6	70	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.2	93.4	59.3	91.3	58.7	89.6	58.3	64.8	81.5	63.1	81.2	61.9	80.4	10.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.9	99.7	67.5	58.1	90.1	66.8	55.9	83.1	67.4	32.9	81.6	31.5	80.2	30.5	80.3	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.0	19.1	16.9	-6.1	97.9	5.4	1.9	-10.0	99.3	-13.1	100.4	-16.1	101.5	-20.0	102.9		
			-7.1	67.6	5.1	3.9	-10.8	70.4	-13.7	72.7	-16.6	74.9	-20.2	77.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.3	28.2	32.8	40.6	47.0	56.0	66.0	72.8	69.9	61.9	49.2	37.9	28.7
	DBStd	16.61	8.25	7.15	6.63	6.46	6.77	5.38	3.62	3.46	5.73	6.70	6.89	7.66
	HDD50	2729	677	481	297	129	24	1	0	0	3	93	364	660
	HDD65	6232	1142	901	758	540	288	49	1	5	121	489	813	1125
	CDD50	2490	0	0	4	39	209	481	707	617	362	69	2	0
	CDD65	517	0	0	0	0	7	80	244	157	29	0	0	0
	CDH74	10771	0	0	1	31	608	2773	3713	2568	1018	59	0	0
	CDH80	4708	0	0	0	2	145	1287	1882	1107	281	4	0	0
Wind	WSAvg	6.7	5.6	6.2	7.3	8.4	8.0	7.7	6.3	5.9	6.2	6.6	6.1	5.7
Precipitation	PrecAvg	15.3	1.3	1.4	1.2	1.1	1.0	0.5	1.3	1.8	1.7	1.5	1.3	1.1
	PrecMax	20.5	4.0	4.4	4.1	2.6	4.6	2.2	2.2	3.7	3.8	3.7	2.8	3.2
	PrecMin	9.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	0.4	0.0	0.0	0.1
	PrecStd	2.8	1.0	0.9	0.8	0.7	1.0	0.5	0.6	0.8	0.9	0.9	0.6	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	60.4	72.1	78.2	88.4	95.5	97.5	93.4	89.3	79.4	67.7	55.3
		MCWB	41.2	42.6	47.3	50.1	58.1	57.9	59.8	60.0	58.4	53.1	47.0	40.1
	2%	DB	50.0	56.5	67.8	73.3	83.7	92.6	94.6	91.3	86.2	75.0	63.4	50.5
		MCWB	38.3	40.6	45.0	47.3	53.8	56.8	59.9	59.2	57.6	51.3	45.5	38.6
	5%	DB	46.2	52.0	63.7	70.9	80.8	90.3	92.1	89.6	83.2	72.0	60.1	46.6
		MCWB	36.0	38.8	43.5	46.6	52.8	55.9	59.8	59.2	56.1	49.8	43.0	36.7
	10%	DB	43.0	47.8	59.9	67.2	77.2	87.9	90.1	86.6	80.7	68.2	55.0	43.3
		MCWB	34.6	37.2	41.3	45.1	50.7	55.2	59.6	59.1	55.2	48.3	40.9	35.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.9	45.6	48.8	52.1	62.9	66.3	72.3	66.7	62.2	56.8	50.0	43.7
		MCDB	52.1	55.3	67.7	72.9	81.5	82.1	82.3	82.5	80.3	71.2	64.6	50.9
	2%	WB	40.0	42.1	46.1	49.4	56.3	61.0	65.0	64.4	60.3	54.3	46.2	40.6
		MCDB	46.8	52.8	65.2	69.3	78.1	85.1	82.0	80.4	77.3	69.1	59.9	47.8
	5%	WB	37.5	39.8	44.1	47.5	53.9	58.9	63.4	62.9	59.0	52.0	44.1	37.9
		MCDB	43.5	49.7	62.0	67.5	75.8	82.8	82.4	79.3	75.7	66.5	57.3	45.1
	10%	WB	35.4	37.7	42.1	45.8	52.0	57.0	62.3	61.6	57.5	50.1	41.8	35.5
		MCDB	41.6	46.0	57.7	65.0	73.5	82.1	81.7	78.2	74.6	64.7	53.8	42.7
Mean Daily Temperature Range	5% DB	MDBR	25.8	26.1	31.4	32.6	35.1	39.7	34.2	32.9	34.3	32.6	30.1	25.6
		MCDBR	29.5	32.9	39.5	40.8	41.9	44.2	38.9	38.9	39.3	39.3	37.8	28.7
		MCWBR	19.3	19.5	20.7	20.0	18.8	17.2	13.8	14.3	15.8	19.4	22.2	18.8
	5% WB	MCDBR	24.8	27.8	36.0	36.5	37.7	38.4	30.6	28.9	30.9	32.4	33.3	25.9
		MCWBR	17.1	17.4	19.6	18.6	18.3	17.1	11.1	11.0	13.1	16.8	20.4	17.7
Clear-Sky Solar Irradiance	taub	0.242	0.250	0.271	0.296	0.307	0.314	0.353	0.353	0.310	0.286	0.253	0.243	
	taud	2.589	2.573	2.531	2.472	2.481	2.446	2.411	2.392	2.517	2.554	2.595	2.588	
	Ebn at Noon	310	319	318	313	308	305	292	290	300	300	302	302	
	Edh at Noon	23	26	30	34	35	36	37	37	30	27	22	21	
All-Sky Solar Radiation	RadAvg	902	1175	1644	2048	2350	2625	2312	2056	1798	1373	1016	779	
	RadStd	81	99	126	109	167	131	114	77	73	104	70	63	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page