

CORTEZ, CO, USA

WMO: 724767

Lat: 37.307N

Lon: 108.626W

Elev: 1801

StdP: 81.48

Time Zone: -7.00 (NAM)

Period: 96-19

WBAN: 93069

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.2	-14.2	-21.3	0.7	-10.6	-18.9	0.9	-7.8	10.2	4.0	8.6	3.4	2.5	70	0.592

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	34.1	15.2	32.9	14.8	32.0	14.6	18.2	27.5	17.3	27.3	16.6	26.9	4.6	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.1	14.2	19.7	14.5	12.9	19.3	13.3	11.9	19.7	58.6	27.5	55.4	26.8	53.1	26.8	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.3	8.5	7.5	-21.2	36.6	3.0	1.1	-23.3	37.4	-25.1	38.0	-26.7	38.6	-28.9	39.4		
			-21.7	19.8	2.8	2.2	-23.8	21.4	-25.4	22.6	-27.0	23.8	-29.0	25.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	-2.1	0.5	4.8	8.3	13.3	18.9	22.7	21.1	16.6	9.6	3.3	-1.8
	DBStd	9.23	4.59	3.97	3.69	3.59	3.76	2.99	2.01	1.92	3.18	3.72	3.83	4.26
	HDD10.0	1516	376	267	165	72	13	1	0	0	2	52	202	367
	HDD18.3	3462	634	501	421	300	160	27	1	3	67	272	452	625
	CDD10.0	1383	0	0	2	22	116	267	393	343	201	38	1	0
	CDD18.3	287	0	0	0	0	4	44	136	87	16	0	0	0
	CDH23.3	5984	0	0	1	17	338	1541	2063	1427	566	33	0	0
	CDH26.7	2616	0	0	0	1	81	715	1046	615	156	2	0	0
Wind	WSAvg	3.0	2.5	2.8	3.3	3.8	3.6	3.4	2.8	2.6	2.8	3.0	2.7	2.5
Precipitation	PrecAvg	389	34	35	31	27	26	12	33	46	44	39	32	29
	PrecMax	520	101	111	105	67	118	55	56	93	97	95	70	81
	PrecMin	245	0	1	0	0	1	0	0	13	9	0	1	3
	PrecStd	72	26	23	21	18	25	13	16	21	24	24	16	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	15.8	22.3	25.7	31.4	35.3	36.4	34.1	31.8	26.3	19.8	12.9
		MCWB	5.1	5.9	8.5	10.0	14.5	14.4	15.4	15.5	14.7	11.7	8.3	4.5
	2%	DB	10.0	13.6	19.9	23.0	28.7	33.7	34.8	32.9	30.1	23.9	17.4	10.3
		MCWB	3.5	4.8	7.2	8.5	12.1	13.8	15.5	15.1	14.2	10.7	7.5	3.7
	5%	DB	7.9	11.1	17.6	21.6	27.1	32.4	33.4	32.0	28.5	22.2	15.6	8.1
		MCWB	2.2	3.8	6.4	8.1	11.6	13.3	15.5	15.1	13.4	9.9	6.1	2.6
	10%	DB	6.1	8.8	15.5	19.5	25.1	31.0	32.3	30.4	27.1	20.1	12.8	6.3
		MCWB	1.5	2.9	5.2	7.3	10.4	12.9	15.3	15.1	12.9	9.0	4.9	1.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	7.6	9.3	11.2	17.1	19.1	22.4	19.3	16.8	13.8	10.0	6.5
		MCDB	11.2	12.9	19.8	22.7	27.5	27.8	27.9	28.1	26.8	21.8	18.1	10.5
	2%	WB	4.4	5.6	7.9	9.7	13.5	16.1	18.3	18.0	15.7	12.4	7.9	4.8
		MCDB	8.2	11.5	18.5	20.7	25.6	29.5	27.8	26.9	25.2	20.6	15.5	8.8
	5%	WB	3.1	4.4	6.7	8.6	12.2	14.9	17.4	17.2	15.0	11.1	6.7	3.3
		MCDB	6.4	9.8	16.7	19.7	24.3	28.2	28.0	26.3	24.3	19.2	14.1	7.3
	10%	WB	1.9	3.1	5.6	7.7	11.1	13.9	16.8	16.4	14.2	10.0	5.5	1.9
		MCDB	5.3	7.8	14.3	18.3	23.1	27.8	27.6	25.7	23.7	18.2	12.1	5.9
Mean Daily Temperature Range	5% DB	MDBR	14.4	14.5	17.5	18.1	19.5	22.0	19.0	18.3	19.1	18.1	16.7	14.2
		MCDBR	16.4	18.3	21.9	22.7	23.3	24.6	21.6	21.6	21.8	21.8	21.0	16.0
		MCWBR	10.7	10.8	11.5	11.1	10.4	9.6	7.7	7.9	8.8	10.8	12.3	10.4
	5% WB	MCDBR	13.8	15.4	20.0	20.3	21.0	21.3	17.0	16.1	17.2	18.0	18.5	14.4
		MCWBR	9.5	9.7	10.9	10.3	10.2	9.5	6.2	6.1	7.3	9.3	11.3	9.9
Clear-Sky Solar Irradiance	taub		0.242	0.250	0.271	0.296	0.307	0.314	0.353	0.353	0.310	0.286	0.253	0.243
	taud		2.589	2.573	2.531	2.472	2.481	2.446	2.411	2.392	2.517	2.554	2.595	2.588
	Ebn at Noon		977	1005	1004	986	972	960	920	915	945	945	953	952
	Edh at Noon		71	83	95	108	109	113	116	116	96	84	70	67
All-Sky Solar Radiation	RadAvg		2.84	3.70	5.18	6.46	7.41	8.27	7.29	6.48	5.67	4.33	3.20	2.46
	RadStd		0.25	0.31	0.40	0.34	0.53	0.41	0.36	0.24	0.23	0.33	0.22	0.20

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page