

EUREKA AP, NV, USA

WMO: 724770

Lat: 39.601N

Lon: 116.006W

Elev: 5936

StdP: 11.81

Time Zone: -8.00 (NAP)

Period: 96-19

WBAN: 03170

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.5	(c) 1.1	(d) -10.5	(e) 3.9	(f) 6.5	(g) -6.1	(h) 5.0	(i) 13.2	(j) 25.1	(k) 35.2	(l) 21.8	(m) 35.4	(n) 5.3	(o) 220	(p) 0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 36.8	(c) 93.5	(d) 56.2	(e) 91.3	(f) 55.7	(g) 89.7	(h) 55.2	(i) 60.3	(j) 81.5	(k) 59.1	(l) 81.4	(m) 57.9	(n) 80.4	(o) 10.9	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.2	78.1	65.1	51.7	71.1	64.9	48.4	62.8	65.6	29.2	81.6	28.3	80.6	27.4	79.7	65.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	20.2	17.7	DB	-13.3	98.8	5.9	1.9	-17.6	100.2	-21.0	101.3	-24.4	102.3	-28.7	103.7
			WB	-13.8	63.5	5.8	1.2	-18.0	64.4	-21.4	65.1	-24.6	65.7	-28.8	66.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	26.0	29.7	38.3	44.0	51.8	63.0	71.7	69.3	60.3	47.5	37.0	26.2
	DBStd	17.58	10.23	9.90	8.59	7.36	7.40	7.54	4.05	4.22	7.40	8.07	8.99	10.02
	HDD50	3249	744	569	368	205	68	7	0	0	16	139	394	739
	HDD65	6959	1209	989	826	630	409	119	5	15	168	544	841	1204
	CDD50	2214	0	0	7	26	125	397	674	598	324	60	3	0
	CDD65	448	0	0	0	0	2	59	213	148	25	1	0	0
	CDH74	10181	0	0	0	17	248	1891	3863	3045	1060	57	0	0
	CDH80	4608	0	0	0	2	46	805	2002	1429	318	6	0	0
	WSAvg	6.8	5.5	6.3	7.4	8.1	7.5	7.4	7.3	7.2	6.8	6.6	6.0	5.7
	PrecAvg	9.2	0.7	0.8	0.9	1.1	1.1	0.6	0.5	0.6	0.6	0.7	0.6	0.7
(15) Precipitation	PrecMax	13.0	1.8	1.7	2.9	2.4	2.9	2.3	1.7	1.7	1.7	2.6	1.7	1.5
	PrecMin	5.7	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.9	0.6	0.4	0.7	0.7	0.9	0.7	0.4	0.5	0.4	0.7	0.4	0.4
	PrecStd	1.9	0.6	0.4	0.7	0.7	0.9	0.7	0.4	0.5	0.4	0.7	0.4	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.2	60.1	70.6	76.0	85.0	95.1	97.9	94.5	89.6	79.6	68.7	54.5
		MCWB	40.5	41.6	45.7	48.1	52.0	56.5	57.5	56.4	54.2	51.1	46.2	39.8
	2%	DB	49.6	54.5	64.9	71.4	80.7	91.3	95.0	91.6	86.2	74.8	63.9	49.9
		MCWB	38.6	40.0	43.5	46.6	50.9	54.8	56.8	55.5	53.5	48.7	44.1	38.5
	5%	DB	45.1	49.9	60.6	66.9	76.2	88.4	92.7	90.2	83.8	70.7	59.1	45.9
		MCWB	36.1	37.9	42.0	45.2	49.6	54.0	56.3	55.0	52.9	46.9	42.0	36.4
	10%	DB	40.7	45.3	55.5	62.9	72.0	84.8	90.6	88.2	81.1	66.3	54.2	42.0
		MCWB	34.0	36.3	40.2	43.1	48.3	52.9	56.1	54.7	52.0	45.3	39.6	34.4
	0.4%	WB	42.5	43.9	46.7	50.3	54.3	59.4	62.3	61.3	60.5	53.0	48.2	43.0
		MCDB	50.6	55.5	66.9	69.8	74.6	87.3	81.6	77.6	78.2	73.0	64.2	50.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	39.2	41.1	44.5	48.0	52.5	57.3	60.7	59.5	57.7	50.6	45.0	39.9
		MCDB	47.8	52.2	62.8	67.5	74.3	83.6	82.3	80.3	75.4	68.7	61.8	47.6
	5%	WB	36.9	38.8	42.6	46.0	51.1	55.4	59.6	58.3	55.5	48.6	42.6	37.2
		MCDB	43.6	48.4	58.9	64.0	72.3	83.0	82.2	79.8	75.1	65.6	57.0	44.6
	10%	WB	34.8	36.7	40.6	44.1	49.5	54.0	58.7	56.9	53.3	46.8	40.4	34.5
		MCDB	40.6	44.7	54.9	60.4	69.0	80.9	81.5	79.7	76.5	63.6	52.7	41.1
(35) Mean Daily Temperature Range	5% DB	MDBR	24.8	24.5	26.4	28.6	31.0	37.0	36.8	36.9	36.1	32.9	29.5	24.6
		MCDBR	27.4	29.0	33.7	36.7	39.1	41.6	40.8	39.9	39.8	38.3	35.5	28.0
		MCWBR	17.9	16.9	16.9	17.8	16.7	16.3	15.5	15.8	17.0	18.8	19.5	18.0
	5% WB	MCDBR	24.0	25.5	31.7	32.4	34.6	38.2	32.3	32.4	32.3	32.2	32.3	23.3
		MCWBR	16.2	15.6	16.7	16.1	15.5	15.2	11.6	12.2	13.6	16.1	18.2	15.2
(40) Clear-Sky Solar Irradiance	taub		0.236	0.245	0.256	0.284	0.293	0.294	0.314	0.307	0.278	0.260	0.242	0.236
	taud		2.619	2.612	2.602	2.507	2.527	2.555	2.524	2.518	2.605	2.637	2.646	2.621
	Ebn at Noon		308	318	322	315	312	311	303	304	309	307	303	300
	Edh at Noon		21	24	28	33	33	32	33	32	27	23	20	19
(44) All-Sky Solar Radiation	RadAvg		734	1026	1461	1845	2136	2511	2292	2131	1807	1297	869	625
	RadStd		90	116	98	121	220	186	149	145	92	92	46	86

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	+0.72	N/A	N/A	+0.94	N/A	N/A	N/A	N/A	+225	+110

Nomenclature: See separate page