

SACRAMENTO MATHER, CA, USA

WMO: 724833

Lat: 38.567N

Lon: 121.300W

Elev: 30

StdP: 100.96

Time Zone: -8.00 (NAP)

Period: 86-19

WBAN: 23206

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.1	-0.6	-7.9	1.9	7.2	-5.4	2.4	7.4	13.3	11.2	11.9	10.5	1.1	110	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	38.4	20.4	36.8	19.7	34.9	19.2	21.6	35.9	20.7	34.2	20.0	33.0	2.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.3	11.6	24.3	15.5	11.1	24.4	14.8	10.5	23.7	62.5	36.0	59.6	34.4	57.0	32.9	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	7.6	6.2	DB	-4.3	42.1	2.4	1.5	-6.0	43.2	-7.4	44.1	-8.7	44.9	-10.5	46.1	(4)
(5)			WB	-5.2	23.6	2.1	0.8	-6.7	24.2	-8.0	24.7	-9.1	25.1	-10.7	25.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	7.4	10.2	12.5	14.5	17.9	21.5	24.7	23.7	21.8	17.9	11.4	7.4	(6)	
	DBStd	6.75	2.73	3.02	2.83	3.45	4.09	3.55	2.89	2.90	3.16	3.41	2.92	3.11	(7)	
	HDD10.0	249	88	33	9	5	2	0	0	0	0	1	19	92	(8)	
	HDD18.3	1541	338	228	183	122	57	11	0	1	7	47	209	340	(9)	
	CDD10.0	2414	9	38	86	141	247	346	454	424	353	247	60	9	(10)	
	CDD18.3	665	0	0	0	7	43	107	196	166	111	35	0	0	(11)	
	CDH23.3	9490	0	1	27	207	799	1603	2615	2177	1484	570	7	0	(12)	
	CDH26.7	5054	0	0	2	64	351	832	1563	1244	778	219	0	0	(13)	
(14) Wind	WSAvg	2.4	1.9	2.3	2.7	2.6	2.6	2.8	2.7	2.5	2.1	1.9	1.9	2.4	(14)	
(15) Precipitation	PrecAvg	420	85	74	64	27	10	4	1	2	7	23	58	62	(15)	
	PrecMax	850	232	218	181	107	53	32	20	16	71	174	188	159	(16)	
	PrecMin	159	4	5	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	159	64	58	47	28	12	6	4	4	14	31	52	43	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.7	22.0	26.2	31.3	35.2	38.8	41.6	40.2	38.2	34.9	24.3	17.7	(19)	
		MCWB	11.8	13.6	16.5	17.8	19.2	20.0	21.9	20.5	20.2	18.3	15.0	11.8	(20)	
	2%	DB	15.4	20.1	23.5	28.6	32.9	36.3	38.7	37.8	35.9	31.8	21.9	15.9	(21)	
		MCWB	10.6	13.3	15.3	16.4	18.7	19.5	21.0	19.7	18.6	16.9	14.0	10.8	(22)	
	5%	DB	13.8	18.0	21.3	25.6	31.0	34.0	37.0	35.9	33.7	28.9	19.9	14.0	(23)	
		MCWB	10.6	12.3	14.2	15.1	17.9	18.7	20.2	19.3	18.0	16.1	12.7	10.4	(24)	
	10%	DB	12.4	16.1	19.0	22.8	28.0	31.8	34.7	33.4	31.7	26.6	17.8	12.6	(25)	
		MCWB	9.7	11.3	13.5	14.2	16.5	18.2	19.6	18.8	17.5	15.5	12.1	9.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.8	15.6	17.8	19.8	20.8	21.9	22.9	22.1	21.5	19.0	16.8	14.1	(27)	
		MCDB	15.6	19.8	24.2	29.0	32.0	35.9	38.5	37.3	35.7	31.5	22.3	16.2	(28)	
	2%	WB	12.5	14.1	16.0	17.4	19.9	20.8	21.8	20.9	20.0	17.9	15.1	12.4	(29)	
		MCDB	14.0	18.0	21.8	26.0	31.2	33.4	36.7	35.1	32.8	29.3	18.9	13.6	(30)	
	5%	WB	11.2	13.0	15.1	16.1	18.6	19.8	20.8	20.1	18.7	17.0	14.0	11.4	(31)	
		MCDB	13.2	16.5	20.3	23.8	29.0	32.0	35.0	33.7	31.2	27.1	17.7	13.1	(32)	
	10%	WB	10.1	12.2	14.0	14.9	17.2	18.8	20.0	19.3	17.9	16.2	13.0	10.2	(33)	
		MCDB	12.3	15.3	18.2	21.7	26.3	30.3	33.5	32.0	29.9	24.8	16.3	12.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	11.1	12.2	14.9	17.4	18.7	19.6	19.1	17.9	15.6	12.1	9.1	(35)	
		MCDBR	11.3	13.6	16.9	19.7	21.2	22.7	21.5	21.8	21.0	19.7	15.5	11.6	(36)	
	5% WB	MCWBR	7.7	7.9	9.5	9.4	8.8	9.2	7.7	7.5	7.9	8.2	8.3	7.3	(37)	
		MCWBR	9.6	11.4	14.1	17.6	19.7	20.8	20.6	20.1	19.4	17.4	12.7	8.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.324	0.326	0.347	0.356	0.369	0.364	0.364	0.348	0.355	0.351	0.333	0.336	(40)	
		taud	2.501	2.504	2.430	2.402	2.384	2.409	2.410	2.445	2.431	2.443	2.477	2.454	(41)	
	Ebn at Noon		854	903	913	921	910	911	908	918	892	859	833	806	(42)	
		Edh at Noon	79	89	105	115	120	117	116	109	104	93	80	77	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.19	3.21	4.57	6.05	7.36	8.27	8.22	7.38	5.97	4.22	2.71	1.95	(44)	
	RadStd		0.40	0.42	0.49	0.53	0.47	0.34	0.25	0.23	0.21	0.28	0.20	0.33	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (47 neighbors)		+0.40	N/A	-1.08	N/A	N/A	N/A	N/A	-116	+138	+42

Nomenclature: See separate page