

SACRAMENTO MCCLELLAN, CA, USA

WMO: 724836

Lat: 38.667N

Lon: 121.400W

Elev: 77

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23208

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	31.7	34.1	18.7	14.1	51.7	23.3	17.6	54.7	27.6	56.0	24.9	54.2	2.6	320	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.6	101.8	69.2	99.2	67.8	95.3	66.4	71.4	96.8	69.8	93.8	68.4	91.6	6.9	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.0	86.5	77.7	61.0	80.4	76.2	59.2	75.3	73.5	35.0	97.0	33.7	94.0	32.6	91.5	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.4	17.9	15.4	DB	26.7	106.2	3.8	2.1	24.0	107.7	21.8	108.9	19.7	110.1	16.9	111.6	
			WB	26.4	73.9	3.8	2.7	23.7	75.8	21.5	77.4	19.4	78.9	16.7	80.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.8	48.7	51.7	55.7	60.7	66.9	74.3	78.2	77.6	73.5	64.3	54.2	47.0
	DBStd	12.15	4.80	4.49	4.98	6.03	6.02	6.32	5.03	5.15	5.32	5.09	5.61	5.23
	HDD50	264	78	30	9	2	0	0	0	0	0	0	22	123
	HDD65	2331	504	373	288	156	47	5	0	0	4	73	323	558
	CDD50	4933	39	77	187	321	523	729	874	856	705	442	150	30
	CDD65	1526	0	0	1	25	105	284	409	391	260	50	1	0
	CDH74	19393	0	0	46	445	1419	3713	5160	4775	3030	770	35	0
	CDH80	10346	0	0	3	109	604	2048	3051	2758	1541	230	2	0
Wind	WSAvg	7.1	6.5	7.2	7.1	7.6	8.2	8.2	8.2	7.8	6.8	6.2	5.6	6.3
Precipitation	PrecAvg	16.5	3.3	2.9	2.5	1.1	0.4	0.2	0.0	0.1	0.3	0.9	2.3	2.4
	PrecMax	33.5	9.1	8.6	7.1	4.2	2.1	1.3	0.8	0.6	2.8	6.9	7.4	6.3
	PrecMin	6.3	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	6.3	2.5	2.3	1.9	1.1	0.5	0.2	0.2	0.2	0.6	1.2	2.0	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.2	70.4	79.3	87.4	96.8	103.8	104.5	106.0	101.1	91.3	78.7	64.4
		MCWB	53.6	57.8	60.0	62.9	66.9	70.6	70.2	70.5	69.0	64.1	59.0	55.4
	2%	DB	63.1	67.4	74.5	82.4	91.1	100.0	101.3	100.5	95.8	85.7	73.3	61.4
		MCWB	54.1	56.7	58.3	60.7	64.2	68.4	69.1	68.2	65.8	62.6	57.5	54.0
	5%	DB	59.3	63.9	71.9	79.7	87.6	95.4	98.9	97.5	92.6	81.7	69.6	59.0
		MCWB	53.0	54.0	57.4	60.3	63.8	66.6	67.7	67.0	64.8	59.2	56.6	52.3
	10%	DB	57.0	61.3	67.7	75.1	82.0	91.2	94.9	93.4	89.9	78.5	64.4	56.8
		MCWB	52.0	54.1	55.9	58.6	61.1	65.1	66.7	66.0	64.1	58.0	54.7	51.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.0	61.4	63.6	66.8	69.5	73.2	73.5	72.6	72.1	66.3	62.3	59.9
		MCDB	63.2	65.3	73.3	80.3	88.5	98.9	98.9	99.9	93.8	87.4	71.0	62.8
	2%	WB	57.1	59.1	60.8	63.8	66.8	70.7	71.2	70.5	69.0	63.8	60.4	57.2
		MCDB	59.6	63.1	70.3	76.8	85.8	95.3	96.9	96.4	91.0	81.3	68.4	59.4
	5%	WB	54.9	57.1	58.9	61.7	64.7	68.8	69.5	68.8	67.2	61.9	58.6	55.0
		MCDB	57.5	62.0	67.9	75.6	83.6	91.6	93.9	93.2	88.8	76.7	65.7	57.6
	10%	WB	53.3	55.0	57.0	59.8	62.6	66.8	68.0	67.3	65.4	60.2	56.8	52.7
		MCDB	55.6	59.7	65.1	72.7	79.1	88.2	91.7	90.8	85.3	73.4	62.7	55.4
Mean Daily Temperature Range	5% DB	MDBR	15.7	18.0	20.5	23.7	25.4	29.6	31.6	30.9	28.8	26.4	20.1	16.9
		MCDBR	20.3	22.8	27.7	30.8	32.6	34.5	34.7	34.6	33.5	31.7	27.2	19.2
		MCWBR	12.7	13.1	14.0	13.0	11.7	11.9	12.0	11.7	11.5	12.2	12.8	11.8
	5% WB	MCDBR	13.0	18.4	23.3	27.2	30.0	32.9	33.1	32.4	30.4	26.5	20.3	11.7
		MCWBR	9.7	11.9	12.8	12.7	12.4	12.1	12.7	11.5	11.1	10.8	11.3	8.7
Clear-Sky Solar Irradiance	taub	0.323	0.326	0.346	0.356	0.370	0.364	0.364	0.347	0.355	0.349	0.331	0.336	
	taud	2.507	2.507	2.436	2.402	2.384	2.410	2.406	2.443	2.431	2.449	2.486	2.457	
	Ebn at Noon	271	286	290	292	289	289	288	291	283	273	265	256	
	Edh at Noon	25	28	33	36	38	37	37	35	33	29	25	24	
All-Sky Solar Radiation	RadAvg	687	1013	1446	1919	2337	2618	2608	2336	1891	1332	850	613	
	RadStd	127	132	155	168	145	107	77	75	66	89	63	103	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (46 neighbors)	+0.72	N/A	-1.94	N/A	N/A	N/A	N/A	-209	+248	+76

Nomenclature: See separate page