

YUBA COUNTY AP, CA, USA

WMO: 724838

Lat: 39.102N

Lon: 121.568W

Elev: 62

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 93205

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.2	33.3	19.1	14.4	51.5	22.9	17.3	50.1	27.8	51.2	24.4	52.8	1.7	340	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.3	101.8	69.6	99.1	69.1	96.5	68.0	72.5	96.0	70.9	94.1	69.4	92.3	6.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.7	88.6	83.4	62.3	84.0	81.5	60.7	79.5	79.7	36.1	96.1	34.6	94.3	33.5	92.6	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.4	18.9	16.7	DB	25.8	107.4	3.1	2.0	23.5	108.9	21.7	110.1	20.0	111.2	17.8	112.7	(4)
			WB	24.6	75.7	3.1	2.8	22.4	77.7	20.6	79.4	18.8	80.9	16.6	83.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.4	47.3	50.8	55.5	59.4	67.4	74.6	78.8	76.9	72.8	63.9	53.3	47.1
	DBStd	12.42	4.63	4.64	5.42	6.28	6.21	6.23	4.85	4.22	5.36	5.43	5.68	5.09
	HDD50	316	109	42	12	3	0	0	0	0	0	0	31	119
	HDD65	2481	550	397	297	189	44	6	0	0	6	84	353	555
	CDD50	4838	24	66	182	286	539	739	894	834	683	432	130	29
	CDD65	1525	0	0	3	22	117	295	429	369	238	51	1	0
	CDH74	20920	0	1	86	440	1790	4058	5812	4764	3079	862	28	0
	CDH80	11378	0	0	6	136	789	2269	3512	2756	1629	280	1	0
Wind	WSAvg	6.6	5.6	7.0	7.4	7.5	7.8	7.5	6.8	6.3	5.8	5.8	5.3	6.3
Precipitation	PrecAvg	21.2	4.3	3.5	3.2	1.6	0.7	0.2	0.0	0.1	0.3	1.3	3.1	3.7
	PrecMax	46.3	12.0	9.5	11.2	4.7	3.8	1.7	1.7	1.0	1.9	9.3	7.4	14.1
	PrecMin	7.4	0.5	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	7.2	2.8	2.7	2.4	1.3	0.9	0.4	0.2	0.2	0.4	1.6	2.0	2.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.1	72.4	80.9	89.2	97.5	105.1	106.2	104.0	100.9	92.7	77.4	64.0
		MCWB	50.8	57.1	61.0	64.2	68.2	70.9	71.6	68.7	67.0	64.1	59.4	53.7
	2%	DB	62.8	68.2	76.3	83.9	92.6	100.2	102.0	99.7	97.2	86.6	73.1	61.1
		MCWB	51.5	55.5	59.3	62.1	66.2	69.3	70.4	69.2	66.5	61.9	57.5	52.9
	5%	DB	59.0	64.2	72.4	79.3	88.8	96.6	99.1	96.9	93.4	82.4	68.7	58.7
		MCWB	51.3	52.9	57.4	60.3	63.7	67.5	69.8	68.3	65.9	60.3	55.2	52.1
	10%	DB	55.9	61.2	68.1	73.8	84.0	92.3	96.0	93.3	90.1	79.0	64.2	56.2
		MCWB	50.3	52.2	55.5	58.2	62.5	66.1	68.8	67.3	64.9	59.2	54.2	50.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.1	59.8	63.3	67.0	71.0	74.1	75.4	72.9	71.2	66.8	62.1	58.8
		MCDB	61.2	67.2	77.0	84.3	90.7	97.0	99.2	96.8	93.2	85.4	72.6	61.8
	2%	WB	54.4	57.4	60.9	63.9	68.1	71.4	73.1	71.1	68.9	64.4	59.7	56.2
		MCDB	57.9	64.6	73.1	80.3	88.8	94.3	97.2	94.8	91.8	82.1	68.3	58.8
	5%	WB	53.0	55.4	59.0	61.7	65.9	69.4	71.3	69.5	67.3	62.5	57.7	54.1
		MCDB	56.4	62.1	69.4	76.3	84.8	92.0	95.0	92.9	89.7	78.2	64.8	56.4
	10%	WB	51.2	53.5	56.9	59.4	63.8	67.7	69.7	68.3	65.7	60.6	56.0	52.4
		MCDB	55.3	58.8	65.8	71.9	81.2	89.2	92.8	90.8	87.1	74.4	62.3	54.7
Mean Daily Temperature Range	5% DB	MDBR	17.0	19.3	21.3	24.2	28.0	31.2	33.3	33.3	31.9	27.5	21.2	16.4
		MCDBR	24.4	26.1	29.3	33.0	34.9	36.1	35.9	36.7	37.5	34.4	28.0	20.0
		MCWBR	14.8	14.9	15.0	14.6	13.0	12.1	12.7	13.5	13.9	14.1	14.2	12.3
	5% WB	MCDBR	16.6	21.4	25.7	30.3	33.0	34.0	33.9	34.0	34.4	29.5	22.6	11.2
		MCWBR	11.3	13.1	14.0	14.3	13.4	12.7	13.5	13.4	13.6	12.7	12.8	8.2
Clear-Sky Solar Irradiance	taub	0.322	0.325	0.342	0.355	0.365	0.359	0.358	0.342	0.348	0.340	0.322	0.330	
	taud	2.511	2.510	2.456	2.409	2.410	2.431	2.416	2.457	2.449	2.476	2.517	2.480	
	Ebn at Noon	271	286	291	292	290	291	290	293	285	276	268	257	
	Edh at Noon	24	28	32	36	37	36	36	34	32	28	24	24	
All-Sky Solar Radiation	RadAvg	677	989	1412	1891	2319	2609	2613	2332	1879	1307	822	595	
	RadStd	124	134	162	176	150	112	78	77	69	95	68	103	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (43 neighbors)		+0.74	N/A	-2.03	N/A	N/A	N/A	N/A	-198	+250	+81

Nomenclature: See separate page