

YUBA COUNTY AP, CA, USA

WMO: 724838

Lat: 39.102N

Lon: 121.568W

Elev: 19

StdP: 101.10

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 93205

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.0	0.7	-7.2	2.1	10.8	-5.0	2.5	10.1	12.4	10.7	10.9	11.5	0.7	340	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	38.8	20.9	37.3	20.6	35.8	20.0	22.5	35.6	21.6	34.5	20.8	33.5	3.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	12.7	28.5	16.8	12.0	27.5	15.9	11.4	26.5	66.1	35.6	62.7	34.6	60.0	33.7	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	8.5	7.5	-3.5	41.9	1.7	1.1	-4.7	42.7	-5.7	43.4	-6.7	44.0	-7.9	44.8
			-4.1	24.3	1.7	1.6	-5.4	25.4	-6.4	26.3	-7.3	27.2	-8.6	28.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	8.5	10.5	13.0	15.2	19.7	23.7	26.0	24.9	22.6	17.7	11.8	8.4
	DBStd	6.90	2.57	2.58	3.01	3.49	3.45	3.46	2.70	2.34	2.98	3.02	3.15	2.83
	HDD10.0	176	61	23	7	2	0	0	0	0	0	0	17	66
	HDD18.3	1378	306	221	165	105	24	3	0	0	3	47	196	308
	CDD10.0	2688	13	37	101	159	299	411	497	463	379	240	72	16
	CDD18.3	847	0	0	2	12	65	164	238	205	132	28	1	0
	CDH23.3	11622	0	1	48	244	994	2254	3229	2647	1711	479	16	0
	CDH26.7	6321	0	0	3	76	438	1261	1951	1531	905	156	1	0
Wind	WSAvg	2.9	2.5	3.1	3.3	3.3	3.5	3.4	3.1	2.8	2.6	2.6	2.4	2.8
Precipitation	PrecAvg	539	108	89	81	40	17	6	1	2	7	34	78	93
	PrecMax	1175	304	241	284	120	97	44	43	25	47	236	188	357
	PrecMin	188	12	4	4	1	0	0	0	0	0	0	0	0
	PrecStd	184	72	69	60	34	23	9	6	5	11	41	52	68
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.0	22.5	27.1	31.8	36.4	40.6	41.2	40.0	38.3	33.7	25.2	17.8
		MCWB	10.4	14.0	16.1	17.9	20.1	21.6	22.0	20.4	19.4	17.8	15.2	12.0
	2%	DB	17.1	20.1	24.6	28.8	33.7	37.9	38.9	37.6	36.2	30.3	22.8	16.2
		MCWB	10.8	13.0	15.2	16.7	19.0	20.7	21.3	20.7	19.2	16.6	14.1	11.6
	5%	DB	15.0	17.9	22.4	26.3	31.5	35.9	37.3	36.0	34.1	28.0	20.4	14.8
		MCWB	10.7	11.6	14.1	15.7	17.6	19.7	21.0	20.2	18.8	15.7	12.9	11.2
	10%	DB	13.3	16.2	20.0	23.2	28.9	33.5	35.6	34.0	32.3	26.1	17.9	13.4
		MCWB	10.2	11.2	13.0	14.5	16.9	18.9	20.4	19.6	18.3	15.1	12.3	10.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	15.4	17.4	19.5	21.7	23.4	24.1	22.7	21.8	19.3	16.7	14.9
		MCDB	16.2	19.5	25.0	29.1	32.6	36.1	37.4	36.0	34.0	29.7	22.6	16.5
	2%	WB	12.4	14.1	16.0	17.7	20.0	21.9	22.9	21.7	20.5	18.0	15.4	13.4
		MCDB	14.4	18.1	22.8	26.8	31.5	34.6	36.2	34.9	33.2	27.8	20.1	14.9
	5%	WB	11.7	13.0	15.0	16.5	18.8	20.8	21.9	20.9	19.6	16.9	14.3	12.3
		MCDB	13.5	16.7	20.8	24.6	29.3	33.3	35.0	33.8	32.1	25.6	18.2	13.5
	10%	WB	10.7	12.0	13.9	15.2	17.6	19.8	21.0	20.2	18.7	15.9	13.3	11.3
		MCDB	12.9	14.9	18.8	22.2	27.3	31.8	33.8	32.7	30.6	23.6	16.8	12.6
Mean Daily Temperature Range	5% DB	MDBR	9.5	10.7	11.8	13.5	15.6	17.3	18.5	18.5	17.7	15.3	11.8	9.1
		MCDBR	13.6	14.5	16.3	18.3	19.4	20.0	19.9	20.4	20.8	19.1	15.6	11.1
		MCWBR	8.2	8.3	8.3	8.1	7.2	6.7	7.1	7.5	7.7	7.8	7.9	6.9
	5% WB	MCDBR	9.2	11.9	14.3	16.8	18.3	18.9	18.8	18.9	19.1	16.4	12.5	6.2
		MCWBR	6.3	7.3	7.8	8.0	7.4	7.0	7.5	7.5	7.6	7.1	7.1	4.6
Clear-Sky Solar Irradiance	taub	0.322	0.325	0.342	0.355	0.365	0.359	0.358	0.342	0.348	0.340	0.322	0.330	
	taud	2.511	2.510	2.456	2.409	2.410	2.431	2.416	2.457	2.449	2.476	2.517	2.480	
	Ebn at Noon	853	902	918	921	913	916	913	923	898	869	844	811	
	Edh at Noon	77	88	102	114	116	114	115	107	102	89	76	75	
All-Sky Solar Radiation	RadAvg	2.13	3.12	4.45	5.96	7.31	8.22	8.24	7.35	5.92	4.12	2.59	1.88	
	RadStd	0.39	0.42	0.51	0.56	0.47	0.35	0.25	0.24	0.22	0.30	0.21	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (43 neighbors)	+0.41	N/A	-1.13	N/A	N/A	N/A	N/A	-110	+139	+45

Nomenclature: See separate page