

NORTH LAS VEGAS, NV, USA

WMO: 724846

Lat: 36.212N

Lon: 115.196W

Elev: 2203

StdP: 13.56

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 53123

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	32.1	34.9	-3.1	5.1	60.8	0.7	6.2	58.3	28.9	51.5	26.1	49.2	4.7	320	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	108.5	67.1	106.3	66.3	104.1	64.9	73.4	98.3	71.5	94.9	70.1	93.7	10.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	103.4	83.2	63.5	95.1	87.4	61.2	87.6	87.5	38.3	98.9	36.6	95.4	35.3	92.9	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.6	22.3	19.3	DB	27.6	112.2	2.7	2.0	25.6	113.6	24.0	114.8	22.5	115.9	20.5	117.4	(4)
(5)			WB	21.9	74.5	2.5	3.1	20.1	76.7	18.7	78.6	17.3	80.3	15.5	82.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.4	49.0	52.5	60.7	67.1	76.3	87.2	92.5	89.8	82.6	69.4	57.0	47.5	(6)	
	DBStd	16.75	5.67	6.36	6.97	6.86	7.63	5.82	4.38	4.19	5.87	6.70	6.96	5.40	(7)	
	HDD50	264	85	43	5	0	0	0	0	0	0	0	19	112	(8)	
	HDD65	1910	497	350	171	57	8	0	0	0	0	34	250	543	(9)	
	CDD50	7340	53	114	335	512	816	1115	1317	1235	978	601	229	35	(10)	
	CDD65	3510	0	1	36	119	359	665	852	770	529	169	10	0	(11)	
	CDH74	52388	0	12	360	1308	4643	10592	14399	12332	7075	1574	93	0	(12)	
	CDH80	32690	0	0	71	448	2429	6918	10075	8172	4039	532	6	0	(13)	
(14) Wind	WSAvg	7.6	6.3	7.3	8.3	9.6	9.0	8.7	7.7	7.4	7.0	6.9	6.3	6.3	(14)	
(15) Precipitation	PrecAvg	4.9	0.6	1.1	0.4	0.3	0.0	0.1	0.4	0.4	0.4	0.5	0.3	0.6	(15)	
	PrecMax	11.4	3.0	3.4	4.5	1.8	0.3	0.9	1.9	1.9	2.2	1.6	2.0	2.1	(16)	
	PrecMin	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	2.3	0.8	1.0	0.9	0.4	0.1	0.2	0.4	0.4	0.5	0.5	0.4	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.7	75.9	86.1	93.3	102.1	110.5	112.2	108.8	103.2	93.0	80.6	67.2	(19)	
		MCWB	49.9	51.0	54.9	58.3	64.1	64.3	69.0	69.2	64.7	61.9	54.8	49.3	(20)	
	2%	DB	65.2	71.9	81.6	89.0	98.9	106.8	109.4	106.5	100.3	89.6	76.8	63.7	(21)	
		MCWB	47.4	49.3	55.0	57.0	63.1	64.3	67.4	67.4	64.4	60.3	52.7	47.5	(22)	
	5%	DB	62.8	68.2	78.3	85.1	95.5	104.4	107.4	104.4	98.6	85.8	73.3	61.0	(23)	
		MCWB	46.1	48.0	52.3	54.9	58.9	63.1	67.0	65.7	64.1	57.7	51.5	46.0	(24)	
	10%	DB	59.7	64.4	74.5	81.5	91.9	101.9	105.1	102.1	96.4	82.4	69.9	57.5	(25)	
		MCWB	44.5	46.7	50.8	53.8	58.3	62.7	66.3	65.3	62.8	56.7	50.3	43.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.6	54.5	58.1	61.9	70.3	74.9	75.7	76.0	71.9	66.1	58.1	53.3	(27)	
		MCDB	59.6	65.9	81.2	89.2	100.4	102.4	105.1	101.6	91.6	84.9	72.4	62.3	(28)	
	2%	WB	51.3	51.7	55.4	58.2	65.3	70.4	73.3	73.3	69.2	63.1	54.8	50.8	(29)	
		MCDB	59.3	63.1	76.5	84.5	95.5	100.9	98.5	96.9	90.6	82.6	72.9	59.3	(30)	
	5%	WB	49.0	50.2	53.5	56.1	61.2	66.8	71.5	71.4	67.7	60.7	52.7	48.3	(31)	
		MCDB	58.8	62.5	74.8	81.3	90.2	98.7	95.5	93.2	90.2	80.0	69.9	57.3	(32)	
	10%	WB	46.6	48.5	51.9	54.4	59.0	64.4	70.3	69.9	66.0	58.9	51.0	46.0	(33)	
		MCDB	56.8	61.9	72.0	78.6	89.4	97.1	94.4	91.9	88.7	77.8	67.3	55.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	18.1	18.7	20.6	21.8	22.2	24.4	22.6	22.8	22.4	20.8	19.8	16.9	(35)	
		MCDBR	21.8	23.6	25.2	26.8	26.9	27.1	25.1	25.2	25.1	24.2	23.7	20.3	(36)	
	5% WB	MCWBR	11.3	10.8	10.9	11.3	10.8	10.1	9.0	9.0	9.7	10.2	10.6	10.6	(37)	
		MCWBR	17.8	19.5	23.7	24.4	25.9	26.0	21.1	21.1	21.7	21.3	21.1	16.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.264	0.269	0.283	0.305	0.323	0.319	0.359	0.348	0.314	0.290	0.267	0.264	(40)	
		taud	2.621	2.622	2.561	2.478	2.450	2.475	2.445	2.466	2.542	2.595	2.627	2.629	(41)	
	Ebn at Noon		303	313	315	310	304	304	291	292	300	300	299	296	(42)	
		Edh at Noon	23	25	30	34	36	35	36	34	30	26	22	21	(43)	
(44) All-Sky Solar Radiation	RadAvg		969	1273	1752	2197	2489	2705	2384	2217	1957	1468	1094	858	(44)	
	RadStd		77	112	82	94	125	113	125	112	82	88	44	63	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-4.79	N/A	-1.80	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)		+0.88	N/A	-2.83	N/A	N/A	N/A	N/A	-211	+340	+146

Nomenclature: See separate page