

NORTH LAS VEGAS, NV, USA

WMO: 724846

Lat: 36.212N

Lon: 115.196W

Elev: 672

StdP: 93.51

Time Zone: -8.00 (NAP)

Period: 00-19

WBAN: 53123

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	0.0	1.6	-19.5	0.7	16.0	-17.4	0.9	14.6	12.9	10.8	11.7	9.6	2.1	320	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	42.5	19.5	41.3	19.1	40.1	18.3	23.0	36.9	21.9	35.0	21.2	34.3	4.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	14.8	28.5	17.5	13.6	30.8	16.2	12.5	30.9	71.3	37.2	67.3	35.2	64.2	33.8	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	10.0	8.6	-2.5	44.6	1.5	1.1	-3.5	45.4	-4.4	46.0	-5.3	46.6	-6.4	47.4		
(5)			-5.6	23.6	1.4	1.7	-6.6	24.9	-7.4	25.9	-8.2	26.9	-9.2	28.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	9.4	11.4	15.9	19.5	24.6	30.7	33.6	32.1	28.1	20.8	13.9	8.6		
	DBStd	9.30	3.15	3.53	3.87	3.81	4.24	3.24	2.43	2.33	3.26	3.72	3.87	3.00		
	HDD10.0	147	47	24	3	0	0	0	0	0	0	0	11	62		
	HDD18.3	1061	276	194	95	32	4	0	0	0	0	19	139	302		
	CDD10.0	4078	29	63	186	284	453	619	732	686	543	334	127	19		
	CDD18.3	1950	0	1	20	66	199	369	473	428	294	94	6	0		
	CDH23.3	29104	0	7	200	727	2579	5884	7999	6851	3931	874	52	0		
(13)	CDH26.7	18161	0	0	39	249	1349	3843	5597	4540	2244	296	3	0		
(14)	Wind	WSAvg	3.4	2.8	3.2	3.7	4.3	4.0	3.9	3.4	3.3	3.1	2.8	2.8		
(15) Precipitation	PrecAvg	125	16	27	11	7	1	3	10	9	9	12	7	14		
	PrecMax	289	77	86	114	45	8	23	47	49	56	40	50	53		
	PrecMin	31	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	58	21	25	22	10	2	5	10	11	12	13	11	15		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.9	24.4	30.0	34.0	39.0	43.6	44.5	42.6	39.6	33.9	27.0	19.6		
		MCWB	9.9	10.5	12.7	14.6	17.9	17.9	20.6	20.7	18.2	16.6	12.7	9.6		
	2%	DB	18.5	22.2	27.5	31.7	37.1	41.6	43.0	41.4	37.9	32.0	24.9	17.6		
		MCWB	8.6	9.6	12.8	13.9	17.3	17.9	19.7	19.7	18.0	15.7	11.5	8.6		
	5%	DB	17.1	20.1	25.7	29.5	35.3	40.2	41.9	40.2	37.0	29.9	22.9	16.1		
		MCWB	7.8	8.9	11.3	12.7	14.9	17.3	19.5	18.7	17.8	14.3	10.8	7.8		
	10%	DB	15.4	18.0	23.6	27.5	33.3	38.8	40.6	39.0	35.8	28.0	21.0	14.2		
		MCWB	6.9	8.2	10.5	12.1	14.6	17.1	19.1	18.5	17.1	13.7	10.2	6.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.0	12.5	14.5	16.6	21.3	23.8	24.3	24.5	22.2	18.9	14.5	11.8		
		MCDB	15.4	18.8	27.3	31.8	38.0	39.1	40.6	38.7	33.1	29.4	22.5	16.8		
	2%	WB	10.7	11.0	13.0	14.5	18.5	21.3	22.9	22.9	20.7	17.3	12.7	10.5		
		MCDB	15.2	17.3	24.7	29.2	35.3	38.3	36.9	36.1	32.6	28.1	22.7	15.2		
	5%	WB	9.4	10.1	11.9	13.4	16.2	19.3	21.9	21.9	19.8	15.9	11.5	9.1		
		MCDB	14.9	16.9	23.8	27.4	32.3	37.1	35.3	34.0	32.3	26.6	21.1	14.1		
	10%	WB	8.1	9.2	11.0	12.5	15.0	18.0	21.3	21.0	18.9	14.9	10.6	7.8		
		MCDB	13.8	16.6	22.2	25.9	31.9	36.2	34.7	33.3	31.5	25.4	19.6	13.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.0	10.4	11.4	12.1	12.3	13.6	12.6	12.7	12.4	11.5	11.0	9.4		
		MCDBR	12.1	13.1	14.0	14.9	14.9	15.1	13.9	14.0	13.9	13.4	13.2	11.3		
	5% WB	MCWBR	6.3	6.0	6.0	6.3	6.0	5.6	5.0	5.0	5.4	5.7	5.9	5.9		
		MCWBR	9.9	10.8	13.2	13.6	14.4	14.5	11.7	11.7	12.1	11.8	11.7	9.4		
(40) Clear-Sky Solar Irradiance	taub		0.264	0.269	0.283	0.305	0.323	0.319	0.359	0.348	0.314	0.290	0.267	0.264		
	taud		2.621	2.622	2.561	2.478	2.450	2.475	2.445	2.466	2.542	2.595	2.627	2.629		
	Ebn at Noon		956	987	993	978	958	957	916	922	945	946	943	934		
	Edh at Noon		71	80	94	108	113	110	112	108	95	82	70	67		
(44) All-Sky Solar Radiation	RadAvg		3.06	4.01	5.52	6.93	7.85	8.53	7.51	6.99	6.17	4.63	3.45	2.71		
	RadStd		0.24	0.35	0.26	0.30	0.40	0.36	0.39	0.35	0.26	0.28	0.14	0.20		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-2.66	N/A	-1.00	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	+0.49	N/A	-1.57	N/A	N/A	N/A	N/A	-117	+189	+81

Nomenclature: See separate page