

RENO-TAHOE, NV, USA

WMO: 724880

Lat: 39.484N

Lon: 119.771W

Elev: 1344

StdP: 86.19

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23185

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-8.9	-7.0	-16.3	1.1	4.4	-14.3	1.3	4.1	15.0	11.1	12.8	10.4	0.9	290	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	36.1	16.3	34.7	15.8	33.3	15.1	17.8	32.2	16.9	31.3	16.1	30.5	4.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.6	10.7	21.9	10.9	9.6	22.3	9.6	8.7	22.2	54.7	32.3	52.1	31.3	49.6	30.6	20.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	9.8	8.4	-13.2	38.6	2.9	1.4	-15.3	39.6	-17.0	40.4	-18.6	41.2	-20.6	42.2		
(5)			-13.9	19.0	2.7	1.1	-15.8	19.8	-17.4	20.4	-18.9	21.0	-20.8	21.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.5	2.6	4.3	7.8	10.4	15.3	20.5	24.9	23.6	19.0	12.4	6.3	2.1		
	DBStd	8.70	3.82	3.73	3.86	4.22	4.30	4.14	2.81	2.60	3.68	3.96	4.10	4.31		
	HDD10.0	924	230	161	89	46	7	1	0	0	1	22	121	247		
	HDD18.3	2676	487	393	327	238	114	27	1	2	36	188	360	504		
	CDD10.0	1829	1	2	20	59	170	315	463	423	271	95	11	2		
	CDD18.3	541	0	0	0	1	19	91	205	166	56	3	0	0		
	CDH23.3	7819	0	0	3	44	348	1313	2782	2262	957	111	0	0		
	CDH26.7	3786	0	0	0	4	103	597	1516	1161	384	21	0	0		
(14) Wind	WSAvg	2.7	1.9	2.5	3.2	3.6	3.4	3.4	3.1	2.8	2.3	2.1	2.1	2.1		
(15) Precipitation	PrecAvg	189	29	25	20	10	16	12	6	8	9	9	20	28		
	PrecMax	336	105	123	73	34	73	39	27	42	59	42	78	99		
	PrecMin	109	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	62	25	25	16	9	18	12	8	10	13	11	18	25		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.3	19.2	23.4	27.2	32.1	36.2	38.6	36.8	34.2	29.2	21.8	16.0		
		MCWB	7.4	7.8	9.8	11.7	14.2	15.7	17.3	16.8	15.2	13.3	9.8	7.3		
	2%	DB	13.7	16.2	20.7	24.4	29.5	33.9	36.7	35.4	32.3	26.3	19.2	13.5		
		MCWB	6.3	6.7	8.4	10.5	13.1	15.1	16.5	16.2	14.2	12.0	8.5	6.4		
	5%	DB	11.5	14.0	18.5	22.1	27.3	32.2	35.3	34.1	30.8	24.0	16.7	11.4		
		MCWB	5.0	5.7	7.5	9.4	12.4	14.4	16.1	15.4	13.9	10.7	7.4	5.6		
	10%	DB	9.5	11.6	16.2	19.7	24.9	30.4	33.8	32.6	29.1	21.7	14.2	9.5		
		MCWB	4.2	4.9	6.8	8.3	11.2	13.8	15.6	14.8	13.3	9.7	6.4	4.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	9.1	10.5	12.5	15.4	17.4	19.1	18.6	17.5	14.0	10.7	9.2		
		MCDB	14.6	16.6	21.5	25.2	29.8	33.2	34.1	34.4	29.1	26.8	20.2	14.1		
	2%	WB	7.0	7.6	9.2	11.0	13.9	16.1	18.0	17.4	15.9	12.8	9.2	7.4		
		MCDB	11.8	14.8	19.1	22.7	27.0	31.3	32.3	32.0	28.7	24.1	17.5	11.9		
	5%	WB	5.7	6.3	8.1	10.0	12.9	15.2	17.3	16.4	14.8	11.5	8.0	6.0		
		MCDB	10.3	12.7	17.2	20.9	25.6	30.0	31.9	30.9	27.9	22.3	15.5	10.6		
	10%	WB	4.6	5.2	7.1	8.9	11.9	14.3	16.5	15.6	13.8	10.3	6.9	4.7		
		MCDB	8.9	10.9	15.4	18.7	23.4	28.7	31.0	30.0	27.2	20.2	13.5	9.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	12.0	13.5	13.7	14.4	16.3	17.6	17.9	17.6	16.1	13.5	10.9		
		MCDBR	14.9	16.5	18.0	18.2	18.1	18.7	18.5	19.2	19.9	20.0	17.6	13.5		
	5% WB	MCWBR	8.5	8.6	8.4	7.8	6.9	6.5	6.0	6.6	7.3	8.6	9.0	7.6		
		MCWBR	12.9	14.6	16.4	16.9	17.1	18.2	17.4	18.1	18.6	18.2	16.3	11.9		
(40) Clear-Sky Solar Irradiance	taub		0.267	0.282	0.291	0.305	0.320	0.322	0.324	0.321	0.305	0.293	0.269	0.265		
		taud	2.548	2.514	2.512	2.478	2.467	2.476	2.497	2.478	2.533	2.562	2.590	2.555		
	Ebn at Noon		924	951	973	972	957	950	945	943	944	925	915	899		
		Edh at Noon	72	86	96	106	110	109	106	105	93	81	68	66		
(44) All-Sky Solar Radiation	RadAvg		2.34	3.25	4.66	6.09	7.19	8.24	8.07	7.29	5.95	4.20	2.73	1.99		
	RadStd		0.32	0.37	0.38	0.47	0.58	0.45	0.38	0.32	0.23	0.29	0.18	0.28		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.67	N/A	N/A	+0.64	N/A	N/A	N/A	-135	+205	+123
(47) Regional (17 neighbors)		+0.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+94	+43

Nomenclature: See separate page