

FALLON NAS, NV, USA

WMO: 724885

Lat: 39.417N

Lon: 118.717W

Elev: 3934

StdP: 12.72

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 93102

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	9.9	14.5	-0.5	6.2	30.9	3.1	7.4	32.0	26.6	51.9	23.2	48.7	3.0	160	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.6	99.3	61.0	97.0	60.1	94.6	59.3	63.6	90.1	62.4	89.4	61.2	88.7	7.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.3	75.3	69.5	52.5	67.8	68.7	49.7	61.1	69.3	30.7	89.8	29.7	89.0	28.9	88.2	68.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	20.2	16.9	2.0	103.3	5.7	2.4	-2.1	105.1	-5.5	106.5	-8.7	107.9	-12.9	109.6
			1.0	66.0	5.7	1.3	-3.1	66.9	-6.5	67.7	-9.7	68.4	-13.9	69.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	54.2	34.9	39.7	46.4	51.6	59.9	69.3	77.6	75.3	66.5	53.2	42.1	33.2	(6)
(7)		DBStd	16.49	7.99	7.14	6.90	7.39	7.26	7.19	4.71	4.53	7.09	7.77	7.64	8.96	(7)
(8)		HDD50	1829	469	294	153	69	9	1	0	0	2	54	254	524	(8)
(9)		HDD65	4970	933	708	576	404	191	41	1	2	68	372	688	986	(9)
(10)		CDD50	3370	2	6	42	117	315	579	855	783	498	154	16	3	(10)
(11)		CDD65	1035	0	0	0	2	32	170	391	320	113	7	0	0	(11)
(12)		CDH74	17721	0	0	14	154	828	3067	6198	5092	2144	223	1	0	(12)
(13)		CDH80	9478	0	0	0	26	275	1573	3685	2885	977	57	0	0	(13)
(14)	Wind	WSAvg	6.1	5.0	6.4	7.2	7.7	7.3	6.9	6.2	5.8	5.5	5.2	5.2	5.3	(14)
(15)	Precipitation	PrecAvg	5.0	0.5	0.5	0.4	0.5	0.6	0.6	0.2	0.3	0.2	0.3	0.5	0.4	(15)
(16)		PrecMax	7.6	1.7	2.4	1.5	2.7	1.7	3.0	1.3	1.7	0.9	2.2	1.6	1.3	(16)
(17)		PrecMin	2.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.4	0.4	0.5	0.4	0.5	0.6	0.7	0.3	0.4	0.3	0.5	0.4	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.9	67.2	75.8	83.4	90.9	100.2	103.4	100.5	95.4	86.5	71.5	62.4	(19)
(20)			MCWB	46.3	46.7	49.2	53.8	56.1	60.5	61.9	60.9	59.6	56.5	49.5	46.1	(20)
(21)		2%	DB	56.1	63.1	71.2	78.5	86.7	96.0	100.2	97.9	92.1	79.8	67.1	57.2	(21)
(22)			MCWB	43.1	45.6	47.2	51.4	55.3	59.2	61.1	60.5	58.0	53.5	47.9	44.1	(22)
(23)		5%	DB	52.3	59.1	67.3	74.2	82.9	92.7	98.1	95.7	89.5	75.2	62.9	52.4	(23)
(24)			MCWB	40.9	43.9	46.1	49.4	54.1	58.1	60.7	59.6	57.4	51.3	46.0	41.9	(24)
(25)		10%	DB	48.5	54.5	63.3	69.7	78.7	89.7	95.6	93.4	86.4	71.1	58.0	47.6	(25)
(26)			MCWB	39.1	41.9	44.6	48.0	52.5	57.1	60.0	58.8	56.5	49.5	44.2	39.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.5	49.3	50.5	55.3	59.0	63.0	65.8	64.5	63.3	58.3	51.9	48.1	(27)
(28)			MCDB	58.5	63.3	71.6	80.5	83.5	91.9	90.3	90.8	84.1	79.7	67.8	59.9	(28)
(29)		2%	WB	44.6	47.0	48.5	52.5	56.9	61.2	64.2	62.8	60.9	55.5	49.2	45.2	(29)
(30)			MCDB	53.6	60.3	67.9	74.1	79.9	91.2	90.3	89.7	83.7	74.0	64.6	55.5	(30)
(31)		5%	WB	42.0	44.7	46.9	50.7	55.2	59.5	63.1	61.7	59.1	53.2	47.0	42.4	(31)
(32)			MCDB	50.3	57.0	65.2	70.9	77.7	87.2	90.3	89.5	84.2	70.1	60.5	51.2	(32)
(33)		10%	WB	39.7	42.5	45.3	48.8	53.7	58.1	61.9	60.3	57.3	51.0	44.7	39.7	(33)
(34)			MCDB	47.6	53.5	61.8	67.4	75.0	85.0	89.2	88.5	83.9	67.8	56.8	47.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	23.6	25.2	28.8	29.0	29.5	33.9	35.6	36.1	35.2	31.9	27.7	22.6	(35)
(36)			MCDBR	28.5	31.5	35.4	36.3	36.5	38.6	37.7	37.7	38.9	36.9	34.1	26.2	(36)
(37)			MCWBR	17.5	17.6	17.6	16.3	14.0	13.7	12.4	13.5	16.1	17.4	18.7	15.8	(37)
(38)		5% WB	MCDBR	24.9	28.6	32.1	32.9	32.3	35.7	33.0	34.0	35.2	31.8	31.6	24.4	(38)
(39)			MCWBR	16.0	16.6	16.4	15.0	12.6	12.6	11.0	12.8	14.4	15.0	18.0	15.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.249	0.257	0.266	0.292	0.309	0.306	0.315	0.307	0.290	0.266	0.251	0.247	(40)	
(41)		taud	2.641	2.610	2.588	2.482	2.455	2.486	2.493	2.497	2.536	2.635	2.644	2.635	(41)	
(42)		Ebn at Noon	303	313	318	313	307	306	303	304	305	305	300	296	(42)	
(43)		Edh at Noon	21	25	28	33	35	34	34	33	29	24	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	751	1072	1527	1976	2299	2618	2523	2279	1890	1344	887	633	(44)	
(45)		RadStd	108	92	91	112	173	127	111	97	57	86	43	76	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.65	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	+166	+83

Nomenclature: See separate page