

MONTAUK, NY, USA

WMO: 725014

Lat: 41.073N

Lon: 71.923W

Elev: 7

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 54780

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.2	18.4	-2.2	4.9	16.5	1.1	5.8	20.3	26.0	19.2	24.3	22.3	13.9	320	0.448

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.9	85.4	73.5	82.4	72.5	80.3	71.4	76.3	81.7	75.0	79.7	73.6	77.8	6.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.7	129.7	79.0	73.3	123.6	77.7	72.2	119.4	76.7	39.6	81.6	38.4	79.7	37.1	77.9	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.0	18.8	17.1	9.9	90.9	7.1	3.9	4.8	93.6	0.7	95.9	-3.3	98.1	-8.4	100.9		
			DB	WB	7.7	78.4	5.8	1.8	3.5	79.7	0.1	80.8	-3.1	81.8	-7.3	83.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.3	33.9	34.1	39.3	48.4	57.1	66.4	73.2	73.2	67.3	57.5	48.2	40.0
	DBStd	15.42	8.93	7.65	6.96	5.87	5.70	5.50	4.31	4.45	4.95	6.52	7.12	7.73
	HDD50	1832	499	446	336	96	5	0	0	0	0	13	115	322
	HDD65	4987	963	866	797	499	255	47	1	2	34	244	504	775
	CDD50	3046	1	1	4	47	224	493	720	719	518	246	61	12
	CDD65	725	0	0	0	1	9	91	256	255	101	12	0	0
	CDH74	3130	0	0	0	7	34	337	1271	1245	225	11	0	0
	CDH80	583	0	0	0	1	4	63	274	221	19	1	0	0
Wind	WSAvg	8.0	10.1	9.7	9.3	8.2	6.8	6.0	5.7	5.5	6.4	8.4	9.2	10.1
Precipitation	PrecAvg	44.7	3.5	3.1	4.4	4.0	3.4	3.3	3.2	4.0	4.2	3.9	3.4	4.3
	PrecMax	54.9	6.0	5.6	14.2	7.7	7.7	11.1	11.3	8.2	8.6	13.0	5.6	7.4
	PrecMin	34.5	1.6	1.6	0.5	1.3	1.1	0.0	1.3	1.5	0.9	0.4	0.8	0.9
	PrecStd	5.8	1.2	1.2	2.8	1.9	1.5	2.6	1.9	1.9	1.9	2.6	1.4	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	54.3	60.2	71.5	78.5	86.6	90.2	89.9	82.5	74.8	65.5	61.2
		MCWB	52.9	49.9	51.9	57.5	68.2	72.7	75.9	76.8	72.6	66.5	61.5	57.2
	2%	DB	52.0	50.6	54.5	63.9	72.9	81.3	86.0	84.7	79.0	71.6	63.0	57.4
		MCWB	49.9	47.8	48.4	54.1	63.0	70.3	73.7	73.7	70.3	67.4	58.9	54.9
	5%	DB	49.4	48.1	51.6	59.7	69.6	78.0	82.8	82.1	76.6	69.1	60.8	55.0
		MCWB	46.3	44.6	47.1	51.2	61.3	67.8	72.9	72.9	69.6	64.5	57.0	52.6
	10%	DB	46.4	45.3	48.8	56.5	66.0	74.8	80.3	80.2	74.5	66.6	58.8	52.1
		MCWB	43.1	41.6	44.5	49.9	59.0	66.4	71.3	72.0	68.6	62.6	55.0	49.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.5	52.3	54.4	59.9	68.6	74.6	77.9	78.5	75.5	70.2	63.2	58.5
		MCDB	54.3	53.0	57.4	67.2	75.5	83.8	86.7	85.6	80.1	72.5	64.9	60.0
	2%	WB	50.4	48.4	50.5	56.4	65.5	71.8	76.2	76.7	73.4	67.9	59.9	55.6
		MCDB	51.7	50.2	53.0	60.9	70.7	78.7	82.5	81.2	76.1	70.4	62.0	57.1
	5%	WB	46.7	45.5	47.8	54.0	63.0	70.0	74.8	75.4	71.7	65.7	57.9	52.9
		MCDB	48.6	47.8	50.5	57.5	67.8	75.2	79.9	79.6	74.4	68.1	60.1	54.8
	10%	WB	43.9	42.0	45.4	51.6	60.4	68.4	73.4	74.1	70.1	63.7	55.9	49.6
		MCDB	46.1	44.9	48.3	55.0	64.6	72.9	77.9	78.1	73.0	66.3	58.4	51.9
Mean Daily Temperature Range	5% DB	MDBR	10.8	11.2	11.5	12.4	13.1	12.6	12.2	11.9	11.3	10.7	11.2	10.5
		MCDBR	13.6	14.0	14.5	17.5	18.0	16.7	15.4	13.6	12.7	11.8	12.4	12.7
		MCWBR	14.0	12.8	11.0	9.8	10.1	8.5	6.9	6.4	7.7	9.4	11.6	13.8
	5% WB	MCDBR	13.2	14.3	13.9	14.4	16.1	14.0	13.0	10.8	10.2	10.1	11.2	12.7
		MCWBR	14.3	14.4	12.3	10.3	9.9	8.3	7.0	6.2	7.6	9.7	12.0	14.2
Clear-Sky Solar Irradiance	taub	0.315	0.323	0.343	0.379	0.428	0.466	0.488	0.454	0.385	0.353	0.322	0.312	
	taud	2.498	2.470	2.448	2.382	2.278	2.216	2.160	2.254	2.414	2.508	2.548	2.547	
	Ebn at Noon	268	283	288	283	270	259	252	258	270	268	263	260	
	Edh at Noon	24	28	32	37	42	45	47	42	33	27	23	21	
All-Sky Solar Radiation	RadAvg	580	866	1203	1560	1737	1899	1928	1735	1415	959	650	489	
	RadStd	49	85	96	166	169	187	105	102	109	88	50	44	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+2.07	+2.25	N/A	N/A	N/A	N/A
(47)	Regional (71 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+187	+101

Nomenclature: See separate page