

TETERBORO, NJ, USA

WMO: 725025

Lat: 40.850N

Lon: 74.061W

Elev: 3

StdP: 101.29

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 94741

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.4	-9.1	-21.5	0.5	-9.8	-19.0	0.7	-7.2	11.3	0.3	10.2	-1.4	4.6	330	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	33.7	23.4	32.2	22.7	30.9	22.1	25.2	30.8	24.3	29.3	23.6	28.3	4.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.5	18.3	27.5	22.8	17.5	26.8	22.2	16.9	26.5	76.5	30.7	73.2	29.5	70.3	28.2	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	9.3	8.3	7.5	DB	-14.3	36.4	3.1	1.8	-16.5	37.6	-18.3	38.7	-20.0	39.6	-22.2	40.9
(5)				WB	-15.5	26.7	2.8	1.2	-17.5	27.6	-19.1	28.2	-20.7	28.9	-22.7	29.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.7	-0.1	1.3	5.4	11.5	16.9	22.1	25.1	24.1	20.3	13.9	8.0	3.1	(6)
(7)		DBStd	9.71	5.51	5.00	4.82	4.49	4.16	3.58	2.85	2.82	3.63	4.33	4.53	4.76	(7)
(8)		HDD10.0	1076	316	246	158	32	1	0	0	0	12	91	221		(8)
(9)		HDD18.3	2704	572	478	402	210	79	9	0	1	21	150	311	473	(9)
(10)		CDD10.0	2058	2	2	14	77	214	362	468	438	310	133	30	7	(10)
(11)		CDD18.3	644	0	0	1	6	34	121	209	180	81	12	1	0	(11)
(12)		CDH23.3	5622	0	1	5	71	334	1046	2016	1528	551	70	1	0	(12)
(13)		CDH26.7	1969	0	0	1	19	108	362	798	525	146	11	0	0	(13)
(14)	Wind	WSAvg	3.3	3.8	3.8	4.0	3.7	3.2	3.0	2.9	2.7	2.8	3.0	3.3	3.5	(14)
(15)	Precipitation	PrecAvg	1180	87	71	102	97	95	104	104	117	101	100	90	100	(15)
(16)		PrecMax	1679	178	136	258	286	209	229	238	391	286	377	161	186	(16)
(17)		PrecMin	874	39	20	17	33	29	14	16	30	20	0	29	23	(17)
(18)		PrecStd	185	32	34	51	53	38	53	51	70	65	78	35	37	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	17.7	23.7	29.2	32.3	34.2	36.2	35.0	32.6	28.0	22.1	18.8	(19)
(20)		0.4%	MCWB	13.8	12.4	15.6	18.0	21.3	23.6	24.5	24.7	22.6	20.0	16.3	14.8	(20)
(21)		2%	DB	13.4	13.7	18.8	25.1	29.7	32.4	34.0	32.7	30.2	25.3	19.2	15.4	(21)
(22)		2%	MCWB	11.3	9.1	11.9	15.4	19.9	23.0	23.4	23.3	21.3	19.2	14.7	12.4	(22)
(23)		5%	DB	10.1	11.1	15.6	22.0	27.3	30.6	32.5	31.2	28.0	22.9	17.4	12.6	(23)
(24)		5%	MCWB	7.3	7.0	10.0	14.1	18.9	21.9	22.9	22.4	20.9	17.9	13.7	10.0	(24)
(25)		10%	DB	7.5	8.2	12.7	19.1	24.5	28.7	30.9	29.6	26.6	21.1	15.3	10.2	(25)
(26)		10%	MCWB	5.0	4.9	8.2	12.3	17.3	20.4	22.4	21.5	20.2	16.4	11.8	7.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.8	14.5	16.6	19.8	22.7	25.1	26.3	26.1	25.1	22.5	18.2	15.7	(27)
(28)		0.4%	MCDWB	16.2	17.1	23.1	27.2	29.9	31.6	33.2	32.3	29.2	25.3	20.2	17.8	(28)
(29)		2%	WB	11.7	10.2	13.5	17.4	21.3	24.1	25.2	25.1	23.9	20.5	16.4	13.0	(29)
(30)		2%	MCDWB	13.2	13.1	17.3	22.9	27.6	30.0	31.3	30.3	27.2	24.0	18.3	14.7	(30)
(31)		5%	WB	7.8	7.5	11.0	15.5	20.1	23.1	24.4	24.2	22.8	18.9	14.4	10.4	(31)
(32)		5%	MCDWB	9.4	9.7	14.5	20.2	25.4	28.6	29.7	28.6	26.1	22.1	16.5	12.5	(32)
(33)		10%	WB	5.3	5.3	8.8	13.5	18.6	22.1	23.6	23.3	21.6	17.2	12.3	7.8	(33)
(34)		10%	MCDWB	7.4	8.2	12.5	17.9	23.5	26.9	28.6	27.3	25.1	20.0	14.8	9.6	(34)
(35)	Mean Daily Temperature Range	MDBR	7.6	8.3	8.9	10.1	10.2	9.8	9.5	9.3	9.5	9.6	8.8	7.4	(35)	
(36)		5% DB	MCDBR	10.6	11.9	13.1	14.6	13.9	12.0	11.2	10.9	11.2	12.0	11.2	10.5	(36)
(37)		5% DB	MCWBR	9.3	8.9	8.5	7.7	6.5	5.2	4.3	4.3	5.0	6.7	8.1	9.0	(37)
(38)		5% WB	MCDBR	10.1	10.8	12.1	12.7	12.3	10.7	9.6	9.1	8.9	10.1	9.8	9.7	(38)
(39)		5% WB	MCWBR	9.5	9.0	9.0	8.0	6.5	5.4	4.5	4.3	5.4	7.0	8.6	9.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.315	0.329	0.361	0.384	0.431	0.491	0.495	0.479	0.403	0.363	0.332	0.315	(40)	
(41)		taud	2.448	2.412	2.388	2.360	2.257	2.126	2.129	2.165	2.351	2.472	2.517	2.513	(41)	
(42)		Ebn at Noon	842	883	889	888	849	796	788	789	833	833	818	815	(42)	
(43)		Edh at Noon	79	94	108	119	135	154	152	143	111	88	74	69	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.85	2.75	3.71	4.77	5.29	5.80	5.94	5.18	4.30	2.97	2.08	1.57	(44)	
(45)		RadStd	0.15	0.28	0.30	0.47	0.55	0.53	0.30	0.34	0.42	0.30	0.18	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	-121	+183	+111
(47)	Regional (64 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+67

Nomenclature: See separate page