

NEW YORK LA GUARDIA, NY, USA

WMO: 725030

Lat: 40.779N

Lon: 73.880W

Elev: 11

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14732

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.6	17.9	-4.0	4.4	15.9	-0.2	5.4	20.7	32.1	31.6	28.5	28.3	16.8	300	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.4	92.6	73.9	89.8	72.5	87.2	71.6	76.9	87.2	75.6	84.6	74.5	82.9	11.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.0	126.7	81.2	72.8	121.7	80.4	71.6	116.9	79.6	40.2	87.6	39.0	85.1	37.8	82.7	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.8	24.2	20.9	DB	8.6	97.9	5.6	3.1	4.6	100.1	1.3	101.9	-1.8	103.6	-5.8	105.9	(4)
(5)			WB	6.3	79.2	5.0	1.5	2.7	80.3	-0.2	81.2	-3.0	82.1	-6.6	83.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	56.4	33.7	35.9	42.6	53.3	63.0	72.6	78.5	77.2	70.5	59.4	48.6	39.8	(6)
(7)		DBStd	17.27	9.81	8.83	8.47	7.63	7.29	6.59	5.19	5.00	6.03	7.32	7.83	8.43	(7)
(8)		HDD50	1675	509	401	259	47	1	0	0	0	0	9	117	332	(8)
(9)		HDD65	4476	969	815	695	360	129	13	0	0	18	203	492	782	(9)
(10)		CDD50	4004	5	5	29	146	404	679	884	843	616	302	75	16	(10)
(11)		CDD65	1332	0	0	1	9	67	242	419	378	184	31	1	0	(11)
(12)		CDH74	10483	0	0	6	92	513	1852	3882	3052	971	114	1	0	(12)
(13)		CDH80	3484	0	0	0	25	156	624	1471	978	213	17	0	0	(13)
(14)	Wind	WSAvg	10.9	12.4	12.3	12.4	11.4	10.2	9.7	9.3	9.0	9.9	10.6	11.4	12.0	(14)
(15)	Precipitation	PrecAvg	48.7	3.7	3.3	4.3	4.1	4.2	3.9	4.4	4.2	4.4	3.9	4.3	4.0	(15)
(16)		PrecMax	80.6	11.0	6.2	10.6	14.0	10.2	10.3	12.2	12.4	11.5	16.7	12.9	10.4	(16)
(17)		PrecMin	28.3	0.6	0.7	0.8	1.4	0.6	0.2	0.4	0.2	0.5	0.2	0.4	0.6	(17)
(18)		PrecStd	10.2	2.1	1.4	2.1	2.2	2.4	2.2	2.6	2.5	2.6	2.8	2.7	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.9	63.4	72.2	83.8	90.1	94.3	97.2	95.3	89.9	82.3	70.7	64.5	(19)
(20)			MCWB	54.1	53.1	57.6	64.9	69.0	73.9	75.5	76.1	72.3	67.9	61.5	56.7	(20)
(21)		2%	DB	55.8	56.5	64.2	75.4	84.4	90.1	93.3	90.9	85.2	77.1	66.0	59.3	(21)
(22)			MCWB	51.6	48.4	52.2	59.1	67.5	72.3	74.2	73.7	70.6	66.4	58.4	54.1	(22)
(23)		5%	DB	51.2	51.7	58.8	69.6	79.8	86.7	90.3	87.9	82.1	73.2	63.0	55.4	(23)
(24)			MCWB	46.4	45.0	48.8	55.9	65.1	70.4	73.1	72.5	69.5	64.8	55.9	50.7	(24)
(25)		10%	DB	47.0	47.8	54.3	65.0	75.3	83.3	87.5	85.3	79.4	70.0	60.2	51.6	(25)
(26)			MCWB	41.7	41.6	46.4	52.6	62.2	68.8	72.5	71.5	68.4	61.9	54.2	46.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.7	56.6	60.4	66.3	72.3	76.5	78.5	78.7	76.3	72.1	64.3	59.2	(27)
(28)			MCDWB	59.5	61.1	69.4	80.2	84.2	88.0	91.0	90.0	82.9	76.8	68.5	62.1	(28)
(29)		2%	WB	52.7	50.6	55.0	61.8	69.7	74.7	77.1	76.8	74.6	69.1	60.6	55.2	(29)
(30)			MCDWB	55.1	54.6	61.3	72.3	81.0	85.9	88.4	86.2	80.3	74.6	63.8	58.4	(30)
(31)		5%	WB	46.8	45.8	50.8	58.5	67.3	73.0	75.8	75.5	73.0	66.4	58.2	51.6	(31)
(32)			MCDWB	50.5	50.5	56.4	66.0	77.3	83.2	85.6	83.6	78.7	71.7	61.6	55.2	(32)
(33)		10%	WB	42.4	42.0	47.2	55.1	64.5	71.2	74.5	74.2	71.1	63.5	54.8	47.1	(33)
(34)			MCDWB	46.2	47.2	53.8	62.5	73.3	80.0	83.6	81.8	77.2	68.7	59.1	50.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.0	12.2	13.2	14.7	14.8	14.1	13.4	12.4	12.0	11.8	10.8	10.1	(35)
(36)			MCDBR	16.1	17.7	19.1	22.0	20.7	18.2	16.4	14.9	14.5	15.1	13.9	14.8	(36)
(37)			MCWBR	14.6	13.9	12.6	11.6	9.9	7.8	6.3	6.3	7.3	8.7	10.9	14.0	(37)
(38)		5% WB	MCDWB	16.0	17.2	18.2	20.0	19.4	16.6	14.4	13.0	12.3	13.6	12.8	14.6	(38)
(39)			MCWBR	15.6	15.0	14.3	12.6	10.5	8.4	6.8	6.6	8.3	10.1	12.5	15.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.318	0.330	0.362	0.386	0.434	0.491	0.496	0.480	0.404	0.364	0.334	0.318	(40)	
(41)		taud	2.454	2.425	2.395	2.363	2.258	2.136	2.133	2.171	2.355	2.477	2.519	2.517	(41)	
(42)		Ebn at Noon	266	279	282	281	269	253	250	250	264	264	259	258	(42)	
(43)		Edh at Noon	25	30	34	38	43	49	48	45	35	28	23	22	(43)	
(44)	All-Sky Solar Radiation	RadAvg	589	875	1188	1525	1695	1859	1895	1664	1374	953	666	502	(44)	
(45)		RadStd	49	88	99	151	173	172	95	107	128	95	58	47	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+171	+126		
(47)	Regional (65 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+209	+121		

Nomenclature: See separate page