

LONG ISLAND MACARTHUR, NY, USA

WMO: 725050

Lat: 40.794N

Lon: 73.102W

Elev: 84

StdP: 14.65

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 04781

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.3	15.7	-5.1	4.2	15.0	-0.9	5.3	18.6	28.5	29.6	26.4	28.7	10.4	290	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.8	88.7	73.7	85.9	72.2	83.2	71.3	77.0	83.6	75.6	81.4	74.4	79.8	10.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.1	132.1	80.2	73.6	125.5	78.6	72.5	120.9	77.7	40.4	83.9	39.0	81.6	37.8	79.6	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	20.9	18.9	6.0	94.8	4.1	3.7	3.0	97.5	0.6	99.7	-1.8	101.8	-4.8	104.5
			4.3	79.4	3.9	2.0	1.4	80.9	-0.9	82.0	-3.1	83.1	-5.9	84.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	53.2	31.7	33.2	39.8	49.9	59.4	68.9	75.0	73.7	67.0	56.0	45.7	37.4	(6)
(7)		DBStd	16.72	9.70	8.53	8.07	6.92	6.52	6.15	4.79	4.76	5.88	7.26	7.85	8.41	(7)
(8)		HDD50	2056	569	471	330	83	4	0	0	0	24	174	401		(8)
(9)		HDD65	5169	1031	889	783	455	201	32	1	1	46	293	580	857	(9)
(10)		CDD50	3239	2	1	13	80	294	567	774	734	511	210	44	9	(10)
(11)		CDD65	876	0	0	0	2	26	148	310	270	107	13	0	0	(11)
(12)		CDH74	5733	0	0	2	27	185	887	2311	1805	471	45	0	0	(12)
(13)		CDH80	1464	0	0	0	7	40	226	679	438	67	7	0	0	(13)
(14)	Wind	WSAvg	9.1	10.2	10.3	10.8	10.3	8.9	8.4	8.0	7.5	8.0	8.7	9.3	9.6	(14)
(15)	Precipitation	PrecAvg	46.4	3.7	3.3	4.4	4.1	3.6	3.8	3.5	4.2	3.9	4.0	3.3	4.6	(15)
(16)		PrecMax	59.3	8.4	6.4	9.8	7.2	7.8	8.2	6.7	10.3	8.1	14.8	5.9	8.5	(16)
(17)		PrecMin	37.6	1.9	1.3	0.9	1.6	0.9	0.7	1.5	0.7	1.4	0.4	1.7	1.9	(17)
(18)		PrecStd	5.9	1.4	1.4	2.0	1.7	1.5	2.2	1.4	2.4	1.7	2.9	1.1	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.1	58.3	68.2	77.3	84.5	90.5	94.0	91.0	85.9	79.4	67.3	62.3	(19)
(20)		MCWB	53.9	49.3	54.6	60.0	67.7	73.5	75.8	75.4	72.9	66.3	58.5	55.8	(20)	
(21)		2%	DB	53.8	52.8	59.8	69.7	79.3	85.8	89.8	87.6	81.5	73.3	63.7	57.2	(21)
(22)		MCWB	51.4	47.3	49.6	56.3	64.4	71.4	74.2	73.5	69.6	66.2	58.3	54.2	(22)	
(23)		5%	DB	50.1	49.5	54.9	64.5	74.4	82.0	86.4	84.4	79.0	70.5	61.3	54.1	(23)
(24)		MCWB	46.8	44.9	48.0	52.5	62.6	69.4	72.8	72.1	68.8	64.1	57.2	51.5	(24)	
(25)		10%	DB	46.1	46.0	51.6	61.0	70.5	79.2	83.6	82.0	76.5	67.7	58.5	50.9	(25)
(26)		MCWB	42.6	41.8	45.8	51.1	60.4	67.9	72.0	71.1	68.2	62.1	54.1	47.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.3	53.1	58.0	63.6	70.9	76.1	79.5	78.9	76.0	71.6	63.3	58.5	(27)
(28)		MDCB	57.1	54.7	66.1	75.1	81.2	86.0	89.4	87.2	80.9	73.8	64.9	60.5	(28)	
(29)		2%	WB	51.8	49.3	52.7	59.3	67.8	73.8	77.2	77.2	74.0	68.6	60.6	54.8	(29)
(30)		MDCB	53.1	51.5	56.4	65.4	75.3	81.7	84.6	82.6	77.6	72.1	62.5	56.3	(30)	
(31)		5%	WB	47.5	45.9	49.7	56.2	65.5	72.1	75.7	75.7	72.5	66.0	57.9	51.9	(31)
(32)		MDCB	49.4	48.0	53.5	61.0	71.9	78.6	82.0	80.7	76.0	69.1	60.4	54.0	(32)	
(33)		10%	WB	43.4	42.0	46.4	53.7	62.8	70.4	74.5	74.3	70.7	63.4	55.1	47.8	(33)
(34)		MDCB	45.7	45.7	50.2	57.9	68.3	76.1	80.4	79.0	74.5	66.5	57.9	50.3	(34)	
(35)	Mean Daily Temperature Range	MDBR	13.8	14.7	15.1	16.5	16.5	15.4	14.8	14.6	15.3	16.2	15.2	13.7	(35)	
(36)		5% DB	MCDBR	17.0	18.0	19.8	22.1	22.0	19.1	17.6	16.5	16.4	17.9	16.4	16.2	(36)
(37)		MCWBR	15.5	14.4	13.1	11.8	11.2	8.9	7.1	7.4	8.6	11.5	13.3	15.3	(37)	
(38)		5% WB	MCDBR	16.4	17.2	18.0	17.5	18.7	15.9	14.4	13.0	12.5	14.8	14.3	15.2	(38)
(39)		MCWBR	16.4	16.3	14.3	12.0	10.7	8.7	7.1	6.8	8.2	11.8	13.8	16.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.307	0.314	0.336	0.381	0.431	0.476	0.488	0.467	0.396	0.345	0.317	0.307	(40)	
(41)		taud	2.522	2.502	2.483	2.378	2.272	2.185	2.162	2.215	2.385	2.540	2.567	2.567	(41)	
(42)		Ebn at Noon	272	287	291	283	270	257	252	254	267	272	266	264	(42)	
(43)		Edh at Noon	23	27	31	37	42	46	47	43	34	26	22	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	585	868	1199	1543	1723	1886	1910	1710	1394	959	664	499	(44)	
(45)		RadStd	49	84	101	156	170	180	98	108	112	90	55	44	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144	+86	(46)
(47)	Regional (69 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+202	+113	(47)

Nomenclature: See separate page