

NEW YORK CENTRAL PARK, NY, USA

WMO: 725053

Lat: 40.779N

Lon: 73.969W

Elev: 140

StdP: 14.62

Time Zone: -5.00 (NAE)

Period: 95-19

WBAN: 94728

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.0	17.3	-6.0	4.0	15.5	-1.3	5.1	20.8	25.3	33.0	21.3	33.3	9.8	300	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	90.7	73.6	87.9	72.3	85.3	71.1	76.7	85.3	75.4	82.9	74.2	81.2	5.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.3	128.7	80.0	73.1	123.5	79.0	72.0	118.9	78.3	40.1	85.5	38.9	83.2	37.7	80.8	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.6	17.6	15.3	8.3	95.3	5.4	3.2	4.4	97.6	1.3	99.5	-1.7	101.2	-5.6	103.6		
			DB	WB	8.3	95.3	5.4	3.2	4.4	97.6	1.3	99.5	-1.7	101.2	-5.6	103.6
			WB	5.8	79.2	4.7	1.4	2.4	80.2	-0.3	81.0	-3.0	81.8	-6.5	82.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.3	33.5	35.5	42.1	53.0	62.3	70.9	76.4	75.5	69.0	57.8	47.3	38.9
	DBStd	16.90	9.96	9.11	8.87	8.25	7.39	6.72	5.21	4.99	6.20	7.52	8.07	8.77
	HDD50	1782	517	412	276	57	1	0	0	0	0	16	144	359
	HDD65	4673	977	825	713	371	145	24	0	1	30	247	531	809
	CDD50	3707	5	6	30	148	381	626	817	790	569	257	63	15
	CDD65	1122	0	0	2	11	59	200	352	326	149	22	1	0
	CDH74	7976	0	1	11	112	451	1407	2835	2327	756	75	1	0
	CDH80	2377	0	0	1	30	128	403	956	681	169	9	0	0
Wind	WSAvg	6.6	8.1	8.2	8.1	7.3	6.0	5.5	5.3	4.7	5.4	6.2	7.0	7.6
Precipitation	PrecAvg	48.7	3.7	3.3	4.3	4.1	4.2	3.9	4.4	4.2	4.4	3.9	4.3	4.0
	PrecMax	80.6	11.0	6.2	10.6	14.0	10.2	10.3	12.2	12.4	11.5	16.7	12.9	10.4
	PrecMin	28.3	0.6	0.7	0.8	1.4	0.6	0.2	0.4	0.2	0.5	0.2	0.4	0.6
	PrecStd	10.2	2.1	1.4	2.1	2.2	2.4	2.2	2.6	2.5	2.6	2.8	2.7	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.3	63.8	73.2	84.2	88.8	91.0	95.2	94.1	89.4	80.7	70.1	66.1
		MCWB	56.6	55.1	58.4	65.8	69.9	74.0	74.6	75.0	72.7	67.5	62.0	58.0
	2%	DB	56.3	57.2	64.2	76.6	83.6	87.8	91.4	89.5	84.4	75.5	65.6	60.0
		MCWB	51.5	49.6	53.1	60.1	67.9	72.4	74.1	73.5	70.4	66.2	59.1	54.2
	5%	DB	51.2	52.3	59.0	70.8	79.3	84.5	88.1	86.3	81.2	72.0	62.2	55.4
		MCWB	46.4	45.3	49.4	56.7	65.3	70.6	72.8	71.9	69.0	64.4	56.4	50.9
	10%	DB	46.9	48.1	54.6	65.6	74.6	81.7	85.2	83.6	78.4	68.7	59.1	51.6
		MCWB	42.0	42.3	46.4	52.9	62.7	69.0	71.7	71.0	68.0	61.7	53.6	46.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.7	58.1	63.0	67.4	72.3	76.5	78.4	78.4	76.2	71.6	64.7	60.2
		MCDB	61.1	62.7	70.4	81.5	84.4	85.9	89.8	87.7	82.9	75.4	68.2	63.9
	2%	WB	52.9	51.3	55.7	62.5	69.9	74.9	76.8	76.7	74.3	68.6	60.8	55.5
		MCDB	55.4	55.3	61.5	72.5	80.5	83.7	86.5	84.2	79.4	73.6	63.8	58.9
	5%	WB	47.1	46.3	51.4	59.3	67.7	73.2	75.4	75.3	72.9	65.9	58.1	52.2
		MCDB	50.2	50.7	57.1	67.0	76.3	81.1	83.7	81.9	77.7	70.9	61.0	55.4
	10%	WB	42.7	42.4	47.5	55.8	64.9	71.4	74.1	73.9	70.8	63.1	54.7	47.1
		MCDB	46.4	47.5	53.5	62.8	72.3	79.0	81.6	80.2	76.1	67.2	58.2	50.7
Mean Daily Temperature Range	5% DB	MDBR	11.3	12.5	13.6	15.4	15.6	14.3	13.7	13.1	13.1	12.3	11.5	10.4
		MCDBR	16.2	17.4	18.8	22.7	21.1	17.2	16.8	15.9	15.8	15.1	14.2	15.2
		MCWBR	14.8	14.2	12.7	11.9	10.7	8.4	7.0	6.8	7.9	8.9	11.7	15.0
	5% WB	MCDBR	16.0	16.7	17.9	19.9	19.4	15.4	13.9	13.0	12.5	13.3	13.1	15.1
		MCWBR	15.8	15.6	14.5	12.8	11.2	8.9	7.4	6.9	8.8	9.8	13.0	16.1
Clear-Sky Solar Irradiance	taub	0.315	0.328	0.359	0.383	0.430	0.488	0.492	0.476	0.401	0.362	0.331	0.315	
	taud	2.458	2.426	2.397	2.366	2.263	2.139	2.140	2.175	2.358	2.480	2.522	2.520	
	Ebn at Noon	267	281	283	282	270	253	251	251	265	265	260	259	
	Edh at Noon	25	30	34	37	43	48	48	45	35	28	23	22	
All-Sky Solar Radiation	RadAvg	589	875	1184	1521	1689	1853	1891	1655	1371	950	665	501	
	RadStd	49	88	98	150	174	170	94	107	130	95	58	48	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (64 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+209	+121

Nomenclature: See separate page