

NEW YORK CENTRAL PARK, NY, USA

WMO: 725053

Lat: 40.779N

Lon: 73.969W

Elev: 43

StdP: 100.81

Time Zone: -5.00 (NAE)

Period: 95-19

WBAN: 94728

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.5	-8.2	-21.1	0.6	-9.2	-18.5	0.7	-6.2	11.3	0.5	9.5	0.7	4.4	300	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.6	32.6	23.1	31.1	22.4	29.6	21.7	24.8	29.6	24.1	28.3	23.5	27.3	2.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.4	26.7	22.8	17.6	26.1	22.2	17.0	25.7	75.5	29.7	72.5	28.4	69.8	27.1	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	7.9	6.8	-13.2	35.2	3.0	1.8	-15.3	36.4	-17.1	37.5	-18.7	38.5	-20.9	39.8		
			-14.5	26.2	2.6	0.8	-16.4	26.8	-18.0	27.2	-19.5	27.7	-21.4	28.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	0.8	2.0	5.6	11.7	16.8	21.6	24.6	24.2	20.5	14.3	8.5	3.8
	DBStd	9.39	5.53	5.06	4.93	4.58	4.11	3.73	2.89	2.77	3.44	4.18	4.48	4.87
	HDD10.0	990	287	229	153	32	1	0	0	0	0	9	80	199
	HDD18.3	2596	543	458	396	206	81	13	0	1	17	137	295	449
	CDD10.0	2059	3	3	17	82	212	348	454	439	316	143	35	8
	CDD18.3	623	0	0	1	6	33	111	196	181	83	12	1	0
	CDH23.3	4431	0	1	6	62	251	782	1575	1293	420	42	1	0
	CDH26.7	1321	0	0	1	17	71	224	531	378	94	5	0	0
Wind	WSAvg	3.0	3.6	3.7	3.6	3.3	2.7	2.5	2.4	2.1	2.4	2.8	3.1	3.4
Precipitation	PrecAvg	1238	94	83	108	105	107	98	113	107	112	98	109	101
	PrecMax	2046	280	157	268	356	260	261	311	314	292	425	328	265
	PrecMin	718	15	18	20	35	16	5	11	5	12	4	9	15
	PrecStd	258	53	35	53	56	61	56	66	63	65	72	68	56
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.8	17.7	22.9	29.0	31.5	32.8	35.1	34.5	31.9	27.1	21.2	18.9
		MCWB	13.7	12.8	14.7	18.8	21.1	23.3	23.7	23.9	22.6	19.7	16.6	14.4
	2%	DB	13.5	14.0	17.9	24.8	28.7	31.0	33.0	32.0	29.1	24.2	18.7	15.6
		MCWB	10.8	9.8	11.7	15.6	19.9	22.4	23.4	23.0	21.3	19.0	15.1	12.3
	5%	DB	10.6	11.3	15.0	21.5	26.3	29.2	31.2	30.1	27.3	22.2	16.8	13.0
		MCWB	8.0	7.4	9.7	13.7	18.5	21.4	22.7	22.2	20.6	18.0	13.5	10.5
	10%	DB	8.3	8.9	12.6	18.7	23.6	27.6	29.5	28.7	25.8	20.4	15.1	10.9
		MCWB	5.6	5.7	8.0	11.6	17.0	20.6	22.0	21.7	20.0	16.5	12.0	8.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.3	14.5	17.2	19.6	22.4	24.7	25.8	25.8	24.6	22.0	18.2	15.7
		MCDB	16.2	17.0	21.3	27.5	29.1	29.9	32.1	30.9	28.3	24.1	20.1	17.7
	2%	WB	11.6	10.7	13.2	16.9	21.1	23.9	24.9	24.8	23.5	20.4	16.0	13.0
		MCDB	13.0	12.9	16.4	22.5	26.9	28.7	30.3	29.0	26.3	23.1	17.7	14.9
	5%	WB	8.4	8.0	10.8	15.2	19.9	22.9	24.1	24.1	22.7	18.8	14.5	11.2
		MCDB	10.1	10.4	14.0	19.4	24.6	27.3	28.7	27.7	25.4	21.6	16.1	13.0
	10%	WB	6.0	5.8	8.6	13.2	18.3	21.9	23.4	23.3	21.5	17.3	12.6	8.4
		MCDB	8.0	8.6	12.0	17.1	22.4	26.1	27.6	26.8	24.5	19.5	14.5	10.4
Mean Daily Temperature Range	5% DB	MDBR	6.3	7.0	7.6	8.6	8.7	8.0	7.6	7.3	7.3	6.8	6.4	5.8
		MCDBR	9.0	9.7	10.5	12.6	11.7	9.6	9.3	8.8	8.8	8.4	7.9	8.4
		MCWBR	8.2	7.9	7.0	6.6	5.9	4.7	3.9	3.8	4.4	5.0	6.5	8.3
	5% WB	MCDBR	8.9	9.3	9.9	11.0	10.8	8.6	7.7	7.2	6.9	7.4	7.3	8.4
		MCWBR	8.8	8.7	8.1	7.1	6.2	4.9	4.1	3.8	4.9	5.5	7.2	8.9
Clear-Sky Solar Irradiance	taub	0.315	0.328	0.359	0.383	0.430	0.488	0.492	0.476	0.401	0.362	0.331	0.315	
	taud	2.458	2.426	2.397	2.366	2.263	2.139	2.140	2.175	2.358	2.480	2.522	2.520	
	Ebn at Noon	843	885	891	890	851	799	791	792	835	836	820	816	
	Edh at Noon	78	93	107	118	134	152	151	142	110	88	73	69	
All-Sky Solar Radiation	RadAvg	1.86	2.76	3.73	4.79	5.33	5.84	5.96	5.22	4.32	3.00	2.10	1.58	
	RadStd	0.15	0.28	0.31	0.47	0.55	0.54	0.30	0.34	0.41	0.30	0.18	0.15	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (64 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+116	+67

Nomenclature: See separate page